

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING February 2018

PARAMETER VIOLATED

REPORTED VIOLATIONS

PARAMETER VIOLATED

TSS LDG MO AVG	TSS CONC MO AVG	TSS CONC 7 DAY AVG MAX	TSS CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	CI2 DAILY MAX	CI2 DAILY MAX	CI2 DAILY MAX
193.6	15.8	41.0	42.0	16.2	12.3	0.08	0.10	0.05
148.9	15.0	22.5	22.5	9.0	9.0	0.011	0.011	0.011

WEEK OF

Feb 26 18    Feb 27 18    Feb 13 18    Feb 14 18    Feb 12 18    2/14/18    2/28/18

*Please fill out the following information*

CAUSE OF VIOLATION Washout Due to heavy rainfall

DURATION OF VIOLATIO Month of February

CORRECTIVE ACTION Adjusting Wasting

EXPECTED COMPLIANCI March 1st

*Jon Kopp*

3/21/2017

SIGNATURE / DATE