

Commissioners:  
Gary Little (Chair)  
Leroy Johnson  
Ronnie Pierce  
Bill Wilcoxson  
Matt Nichols

# City Water Works

216 S.W. 4<sup>th</sup> Street

Walnut Ridge, Arkansas 72476

PH: 870-886-2312 - FAX: 870-886-7824

Jon Kopp  
Manager


To Whom It May Concern:

On May 4, 2015 an email was received by The City Water Works of Walnut Ridge regarding the Walnut Ridge Wastewater Treatment Plant (permit # AR0046566). The attached letter stated that the treatment plant has been in violation of the NPDES permit via total chlorine residual excursions for the second, third and fourth quarter of the 2014 year.

It was my understanding that 0.1mg/l CL2 residual was within the allowable limits and that 0.11 mg/l or over was a violation of the permit. After careful review of our permit I realize that a mistake was made on my behalf as residual limits for my treatment plant are written as \*no detectable limits\* which is clearly defined as >0.1 mg/l CL2 residual. This problem is a result of operator error and WILL BE CORRECTED IMMEDIATELY via adjustment of chemical feed rates and aeration adjustment. This should take care of any further problems with CL2 residual limits.

If there is anything else that needs to be done please feel free to contact me at any time regarding this issue as well as any other involving the Walnut Ridge Wastewater Treatment Plant.

Sincerely,



Jon Kopp

Superintendent

City Water Works of Walnut Ridge

Office: 870-886-2312

Cell: 501-454-4958

Fax: 870-886-7824

Email: [jonathan.kopp@yahoo.com](mailto:jonathan.kopp@yahoo.com)