



ARKANSAS
Department of Environmental Quality

February 12, 2019

Gary J. Little, Chairman
City of Walnut Ridge
216 Southwest Fourth Street
Walnut Ridge, AR 72476

CERTIFIED MAIL: 9489 0090 0027 6060 6620 24

**RE: Permit Number: AR0046566, AFIN: 38-00040
City of Walnut Ridge**

Dear Mr. Little:

A review of the Permit file for the above mentioned facility for the period of January 1, 2018 through December 31, 2018 reveals the following compliance issues:

The facility has reported **9 effluent violations** of Part I, Section A of Permit No. AR0046566:

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit	Vio %
12/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	9.86	6	64%
12/31/2018	001-A	Nitrogen, ammonia, total [as N], 7 DA AVG, mg/L	18.9	9	110%
11/30/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	13.4	6	123%
11/30/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	13.4	6	123%
11/30/2018	001-A	Nitrogen, ammonia, total [as N], 7 DA AVG, mg/L	21.6	9	140%
10/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	79.47	39.7	100%
10/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	12.8	4	220%
10/31/2018	001-A	Nitrogen, ammonia, total [as N], 7 DA AVG, mg/L	18.3	6	205%
10/31/2018	001-A	Chlorine, total residual, INST MAX, mg/L	0.08	<0.011	627%

Non-compliance reports with corrective actions were received by the Department. Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0649, or you may e-mail me at rathe@adeq.state.ar.us.

Sincerely,

Rebecca Rathe
Enforcement Analyst
Office of Water Quality

