



ARKANSAS
Department of Environmental Quality

November 12, 2013

Jonathan Kopp
City of Walnut Ridge
1609 Holly Street
Walnut Ridge, AR 72476

RE: NPDES Permit Number AR0046566, AFIN 38-00040
NPDES Permit Effluent Violations

Dear Mr. Kopp,

A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending September 31, 2013:

Attachment A
DMR Effluent Violations Since 7/31/13
AR0046566 - WALNUT RIDGE, CITY OF-WWTP / Major POTW

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Permit Limit	Vio %	Parameter Code
07/31/2013	001-A	Coliform, fecal general (7 DA GEO, #/100mL)	850	400	113%	74055-1-0
08/31/2013	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	4.2	4	5%	00610-1-0
08/31/2013	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	13.6	6	127%	00610-1-0
09/30/2013	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	8.7	4	118%	00610-1-0
09/30/2013	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	19.5	6	225%	00610-1-0
09/30/2013	001-A	Chlorine, total residual (INST MAX, mg/L)	0.1	.1	0%	50060-1-0

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0823 or e-mail at suel@adeq.state.ar.us.

Sincerely,

Kevin Suel
Enforcement Analyst
Water Division, Enforcement Branch