

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
 PERMIT NUMBER AR0046566 001-A
 PERIOD ENDING December 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	
REPORTED VIOLATIONS	9.86	13.5	12.0	18.9	18.4	11.0	10.6	11.300	
PARAMETER VIOLATED	6.0	9	9.0	9.0	9.0	9.0	9	9.0	
<i>WEEK OF</i>		<i>Dec 05</i>	<i>Dec 10</i>	<i>Dec 11</i>	<i>Dec 12</i>	<i>Dec 24</i>	<i>Dec 28</i>	<i>Dec 28</i>	

Please fill out the following information

CAUSE OF VIOLATION Lack of BioMass

DURATION OF VIOLATIO Month of December

CORRECTIVE ACTION Adjust Wasting and add food source

EXPECTED COMPLIANCI January 1 2019

Jon Kopp 01/21/2019