

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WW TREATMENT PLANT

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING December 2017

PARAMETER VIOLATED

Cl2 DAILY MAX							
------------------	--	--	--	--	--	--	--

REPORTED VIOLATIONS

0.07							
------	--	--	--	--	--	--	--

PARAMETER VIOLATED

0.011							
-------	--	--	--	--	--	--	--

WEEK OF Dec 28 17

*Please fill out the following information*

CAUSE OF VIOLATION Chemical Feed line Stopped up

DURATION OF VIOLATION Dec. 28

CORRECTIVE ACTION Replace Feed line

EXPECTED COMPLIANCE DATE Dec. 29

*Jon Koop*

01/24/2017

SIGNATURE / DATE