

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/21/21	TRC INSTANTANEOUS MAX		0.15	< 0.011
12/27/21	TRC INSTANTANEOUS MAX		0.45	< 0.011


We feel this problem was due to:

FLOWED ONLY 10 DAYS, USED AVERAGE FLOW FOR THE 1ST-21ST
Flow meter was down due to construction
of new Outlet Chambers

We plan on correcting the problem in this manner:

Time estimated that it will take to correct problem:

Sincerely,



Submitted By:

Date

1-25-22

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NCR Form 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
DECEMBER	FLOWED ONLY 10 DAYS		10/30	5/7
12/8/21	TRC INSTANTANEOUS MAX		0.63	< 0.011
12/13/21	TRC INSTANTANEOUS MAX		0.04	< 0.011
12/15/21	TRC INSTANTANEOUS MAX		0.29	< 0.011


We feel this problem was due to:

FLOWED ONLY 10 DAYS, USED AVERAGE FLOW FOR THE 1ST-21ST
Flow Meter was down due to construction
of new Contact Chamber

We plan on correcting the problem in this manner:

Time estimated that it will take to correct problem:

Sincerely,



Submitted By:

Date

1-25-22

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

Netform 2