

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 809-1240

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/30/23	pH MINIMUM		5.97	6.0
2/21/23	TSS 7 DAY AVERAGE		28.0	22.5
FEBRUARY	NH3 MONTHLY AVERAGE		8.5	6.0
2/6/23	NH3 7 DAY AVERAGE		10.5	9.0

We feel this problem was due to:

are Infiltration & acclimation to new plant


We plan on correcting the problem in this manner:

smoke testing & patiently waiting on biomass to build

Time estimated that it will take to correct problem:

Soon

Sincerely,



3-22-2023

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 809-1240

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/8/23	NH3 7 DAY AVERAGE		12.3	9.0
2/15/23	NH3 7 DAY AVERAGE		9.1	9.0
2/20/23	NH3 7 DAY AVERAGE		13.6	9.0
2/21/23	NH3 7 DAY AVERAGE		12.8	9.0

We feel this problem was due to:

Infiltration & acclimation to new plants


We plan on correcting the problem in this manner:

Smoke testing & waiting on business to build

Time estimated that it will take to correct problem:

Already doing significantly better

Sincerely,



Submitted By:

3-22-2023
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 809-1240

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/3/23	CBOD 7 DAY AVERAGE		19.5	15.0
2/21/23	CBOD 7 DAY AVERAGE		25.9	15.0
2/22/23	CBOD 7 DAY AVERAGE		16.9	15.0

We feel this problem was due to:

Infiltration & acclimation to new plant


We plan on correcting the problem in this manner:

smoke testing & waiting on biomass to build

Time estimated that it will take to correct problem:

Already doing significantly better

Sincerely,



Submitted By:

3-22-2023
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 809-1240

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/8/23	NH3 7 DAY AVERAGE		12.3	9.0
2/15/23	NH3 7 DAY AVERAGE		9.1	9.0
2/20/23	NH3 7 DAY AVERAGE		13.6	9.0
2/21/23	NH3 7 DAY AVERAGE		12.8	9.0

We feel this problem was due to:

Infiltration & acclimation to new plant

We plan on correcting the problem in this manner:

Smoke testing & building biomass

Time estimated that it will take to correct problem:

Already doing significantly better

Sincerely,



Submitted By:

3-22-2023
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 809-1240

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/3/23	CBOD 7 DAY AVERAGE		19.5	15.0
2/21/23	CBOD 7 DAY AVERAGE		25.9	15.0
2/22/23	CBOD 7 DAY AVERAGE		16.9	15.0

We feel this problem was due to:

Filtration & acclimation to new plant


We plan on correcting the problem in this manner:

smoke testing & building biomass

Time estimated that it will take to correct problem:

Already doing significantly better

Sincerely,



Submitted By:

3-22-2023
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)