

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 886.2312

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/24/23	DO MINIMUM		5.14	6.0
JANUARY	NH3 MONTHLY AVERAGE		10.6	6.0
1/23/23	NH3 7 DAY AVERAGE		14.0	9.0
1/24/23	NH3 7 DAY AVERAGE		15.2	9.0

We feel this problem was due to:

Infiltration & decommissioning old wastewater plant.

We plan on correcting the problem in this manner:

Smoke testing & building of new wastewater plant

Time estimated that it will take to correct problem:

New plant online

Sincerely,



Submitted By:

2-22-2023  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 886-2312

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/24/23	CBOD 7 DAY AVERAGE		31.9	15.0
1/25/23	CBOD 7 DAY AVERAGE		21.9	15.0

We feel this problem was due to:

Infiltration & decommissioning of old wastewater plant

We plan on correcting the problem in this manner:

smoke testing & building of new wastewater plant

Time estimated that it will take to correct problem:

new plant online

Sincerely,



Submitted By:

2-22-2023  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A2

Facility: CITY OF WALNUT RIDGE - WALNUT RIDGE WWTP

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Jeremy Lewis Phone: 870 886-2312

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
JANUARY	MERCURY MONTHLY AVERAGE	0.0258		0.00014
JANUARY	CBOD MONTHLY AVERAGE	189.6		104.3
JANUARY	CBOD MONTHLY AVERAGE		29.1	10.0
1/23/23	CBOD 7 DAY AVERAGE		33.4	15.0

We feel this problem was due to:

Infiltration & decommissioning of old wastewater plant


We plan on correcting the problem in this manner:

smoke testing & building of new wastewater plant

Time estimated that it will take to correct problem:

new plant online!

Sincerely,



Submitted By:

2.22.2023  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)