

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Phone:

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/2/22	TSS DAILY MAXIMUM		24.0	22.5
5/3/22	TSS DAILY MAXIMUM		32.0	22.5
5/9/22	TSS DAILY MAXIMUM		30.0	22.5
5/24/22	TSS DAILY MAXIMUM		48.0	22.5

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Replace Air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
Facility: WALNUT RIDGE WW TREATMENT PLANT
Address: 1002 OAK ST
City: WALNUT RIDGE State: AR Zip: 72476
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/25/22	TSS DAILY MAXIMUM		24.0	22.5
MAY	NH3 MONTHLY AVERAGE	89.27		39.7
MAY	NH3 MONTHLY AVERAGE		10.0	4.0
5/2/22	NH3 7 DAY AVERAGE		7.5	6.0

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Repace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/3/22	NH3 7 DAY AVERAGE		9.0	6.0
5/4/22	NH3 7 DAY AVERAGE		7.8	6.0
5/9/22	NH3 7 DAY AVERAGE		8.7	6.0
5/10/22	NH3 7 DAY AVERAGE		9.1	6.0

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

Date

6-27-22

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/9/22	BOD 7 DAY AVERAGE		25.8	15.0
5/10/22	BOD 7 DAY AVERAGE		19.9	15.0
5/11/22	BOD 7 DAY AVERAGE		32.4	15.0
5/16/22	BOD 7 DAY AVERAGE		25.2	15.0

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,


Submitted By: _____

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
MAY	BOD MONTHLY AVERAGE		20.5	10.0
5/2/22	BOD 7 DAY AVERAGE		21.1	15.0
5/3/22	BOD 7 DAY AVERAGE		20.1	15.0
5/4/22	BOD 7 DAY AVERAGE		23.9	15.0

We feel this problem was due to:

Hail Storm Tore Air lines

We plan on correcting the problem in this manner:

Replace air lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/3/22	FECAL 7 DAY GEO		>2000.0	400.0
5/4/22	FECAL 7 DAY GEO		>2000.0	400.0
5/9/22	FECAL 7 DAY GEO		>2000.0	400.0
5/10/22	FECAL 7 DAY GEO		>2000.0	400.0

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,


Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
Facility: WALNUT RIDGE WW TREATMENT PLANT
Address: 1002 OAK ST
City: WALNUT RIDGE State: AR Zip: 72476
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/18/22	DO INSTANTANEOUS MINIMUM		2.99	5.0
5/25/22	DO INSTANTANEOUS MINIMUM		4.13	5.0
MAY	TSS MONTHLY AVERAGE	252.0		148.9
MAY	TSS MONTHLY AVERAGE	22.9		15.0

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,


Submitted By: _____

6-27-28
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK ST
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
MAY	MERCURY MONTHLY AVERAGE	0.095076		0.000133
MAY	MERCURY MONTHLY AVERAGE		0.019	0.0134
MAY	FECAL 30 DAY GEO		3044.0	200.0
5/2/22	FECAL 7 DAY GEO		>2000.0	400.0

We feel this problem was due to:

Hail Storm Tore air lines

We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

Date

6-27-22

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 _____ Discharge Number: 001-A _____

Facility: WALNUT RIDGE WW TREATMENT PLANT _____

Address: 1002 OAK ST _____

City: WALNUT RIDGE _____ State: AR _____ Zip: 72476 _____

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/17/22	BOD 7 DAY AVERAGE		25.2	15.0
5/18/22	BOD 7 DAY AVERAGE		17.2	15.0
5/24/22	BOD 7 DAY AVERAGE		15.7	15.0

We feel this problem was due to:

Hail Storm Tore Air Lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/11/22	FECAL 7 DAY GEO		>2000.0	400.0
5/16/22	FECAL 7 DAY GEO		>2000.0	400.0
5/17/22	FECAL 7 DAY GEO		>2000.0	400.0
5/18/22	FECAL 7 DAY GEO		>2000.0	400.0

We feel this problem was due to:

Hail Storm Tore Air lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,


Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/23/22	FECAL 7 DAY GEO		8600	400.0
5/24/22	FECAL 7 DAY GEO		12900	400.0
5/25/22	FECAL 7 DAY GEO		11150	400.0
MAY	BOD MONTHLY AVERAGE	178.2		99.2

We feel this problem was due to:

Hail storm Tore air lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,


Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: Phone:

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/11/22	NH3 7 DAY AVERAGE		8.5	6.0
5/16/22	NH3 7 DAY AVERAGE		17.3	6.0
5/17/22	NH3 7 DAY AVERAGE		17.1	6.0
5/18/22	NH3 7 DAY AVERAGE		12.0	6.0

We feel this problem was due to:

Hail Storm Tore air Lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/23/22	FECAL 7 DAY GEO		8600	400.0
5/24/22	FECAL 7 DAY GEO		12900	400.0
5/25/22	FECAL 7 DAY GEO		11150	400.0
MAY	BOD MONTHLY AVERAGE	178.2		99.2

We feel this problem was due to:

Hail storm Tore air lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/24/22	NH3 7 DAY AVERAGE		12.9	6.0
5/25/22	NH3 7 DAY AVERAGE		6.6	6.0
5/17/22	TRC INSTANTANEOUS MAX		0.09	0.011
5/24/22	TRC INSTANTANEOUS MAX		0.13	0.011

We feel this problem was due to:

Hail Storm Tore air lines


We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/10/22	DO INSTANTANEOUS MINIMUM		4.63	5.0
5/11/22	DO INSTANTANEOUS MINIMUM		4.28	5.0
5/16/22	DO INSTANTANEOUS MINIMUM		0.42	5.0
5/17/22	DO INSTANTANEOUS MINIMUM		3.02	5.0

We feel this problem was due to:

Hail Storm Tore Air Lines

We plan on correcting the problem in this manner:

Replace air Lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/2/22	DO INSTANTANEOUS MINIMUM		3.55	5.0
5/3/22	DO INSTANTANEOUS MINIMUM		1.86	5.0
5/4/22	DO INSTANTANEOUS MINIMUM		3.73	5.0
5/9/22	DO INSTANTANEOUS MINIMUM		3.65	5.0

We feel this problem was due to:

Hail Storm Tore air lines


We plan on correcting the problem in this manner:

replace air lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,


Submitted By: _____

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A

Facility: WALNUT RIDGE WW TREATMENT PLANT

Address: 1002 OAK ST

City: WALNUT RIDGE State: AR Zip: 72476

Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/17/22	BOD 7 DAY AVERAGE		25.2	15.0
5/18/22	BOD 7 DAY AVERAGE		17.2	15.0
5/24/22	BOD 7 DAY AVERAGE		15.7	15.0

We feel this problem was due to:

Hail Storm Blowing out Air lines


We plan on correcting the problem in this manner:

Replaced Air lines

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

6-27-22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)