

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING November 2018

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
	91.2	13.4	12.1	13.2	13.8	20.6	19.5	21.6	19
PARAMETER VIOLATED	59.5	6	9	9	9	9	9	9	9
WEEK OF			Nov 12	Nov 13	Nov 16	Nov 19	Nov 20	Nov 21	Nov 26

Please fill out the following information

CAUSE OF VIOLATION Clarifier Curtain Malfunction

DURATION OF VIOLATION Month of november

CORRECTIVE ACTION Repair both East and Middle Clarifier Curtains

EXPECTED COMPLIANCE December 1st

Jon Kepp

12/25/18

SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
PERMIT NUMBER AR0046566 001-A
PERIOD ENDING November 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX								
REPORTED VIOLATIONS	17.0								
PARAMETER VIOLATED	9.0								

WEEK OF 11/28/2018

Please fill out the following information

CAUSE OF VIOLATION Clarifier Curtain Malfunction

DURATION OF VIOLATION Month of november

CORRECTIVE ACTION Repair both East and Middle Clarifier Curtains

EXPECTED COMPLIANCE December 1st

Jon Kepp 12/25/18
 SIGNATURE / DATE