

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING October 2018

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	53.1	14.8	6.7	10.3	14.9	16.4	15.5	17.0	14.8
PARAMETER VIOLATED	39.7	4	6.0	6.0	6.0	6.0	6	6	6
<i>WEEK OF</i>			<i>Oct 02</i>	<i>Oct 03</i>	<i>Oct 08</i>	<i>Oct 09</i>	<i>Oct 10</i>	<i>Oct 15</i>	<i>Oct 16</i>

*Please fill out the following information*

CAUSE OF VIOLATION Lack of BIOMASS

DURATION OF VIOLATIO Month of October

CORRECTIVE ACTION Adjust Air Feed Supplement food source

EXPECTED COMPLIANC January 1 2019

*Jon Kopp*

11/22/2018

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING October 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	CHLORINE, TOTAL RESIDUAL	
REPORTED VIOLATIONS	10.0	9.3	10.0	10.6	15.1	18.3	17.2	0.080	
PARAMETER VIOLATED	6.0	6	6.0	6.0	6.0	6.0	6	0.011	

**WEEK OF**    10/17/2018    Oct 22    Oct 23    Oct 24    Oct 29    Oct 30    Oct 31    Oct 17

*Please fill out the following information*

CAUSE OF VIOLATION Lack of BIO MASS

---



---



---

DURATION OF VIOLATIO Month of October

CORRECTIVE ACTION Adjust Air Feed Supplement food source

---



---



---

EXPECTED COMPLIANCE January 1 2019

Jon Kopp                      11/22/2018