

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
SEPTEMBER	FECAL 30 DAY GEO		1418.0	200.0
8/30/21	FECAL 7 DAY GEO		2790.0	400.0
8/31/21	FECAL 7 DAY GEO		1800.0	400.0
9/1/21	FECAL 7 DAY GEO		1984.0	400.0

We feel this problem was due to:

Under Feeding CL2


We plan on correcting the problem in this manner:

Raising Feed Rate on CL2 as well as Dechlor

Time estimated that it will take to correct problem:

ASAP

Sincerely,


 Submitted By:

10-25-21

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

MCR Form 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9/7/21	FECAL 7 DAY GEO		930.0	400.0
9/8/21	FECAL 7 DAY GEO		3180.0	400.0
9/14/21	FECAL 7 DAY GEO		2050.0	400.0
9/15/21	FECAL 7 DAY GEO		> 2000.0	400.0

We feel this problem was due to:

Under Feeding CL2


We plan on correcting the problem in this manner:

Raising Feed Rate on CL2 & Dechlor

Time estimated that it will take to correct problem:

ASAP

Sincerely,



10-25-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

MCRform 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9/20/21	FECAL 7 DAY GEO		1550.0	400.0
9/21/21	FECAL 7 DAY GEO		4100.0	400.0
9/22/21	FECAL 7 DAY GEO		3060.0	400.0
9/27/21	FECAL 7 DAY GEO		3160.0	400.0

We feel this problem was due to:

Under Feeding CL2


We plan on correcting the problem in this manner:

Raising feed rate on CL2 & Dechlor

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

10-25-21
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

MCR Form 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
Facility: WALNUT RIDGE WW TREATMENT PLANT
Address: 1002 OAK STREET
City: WALNUT RIDGE State: AR Zip: 72476
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9/28/21	FECAL 7 DAY GEO		1330.0	400.0
9/29/21	FECAL 7 DAY GEO		990.0	400.0

We feel this problem was due to:

Under Feeding CL2


We plan on correcting the problem in this manner:

Raising Feed Rate on CL2 & Dechlor

Time estimated that it will take to correct problem:

ASAP

Sincerely,



Submitted By:

10-25-21

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NetForm 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: WALNUT RIDGE WW TREATMENT PLANT
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9/28/21	FECAL 7 DAY GEO		1330.0	400.0
9/29/21	FECAL 7 DAY GEO		990.0	400.0

We feel this problem was due to:

Under Feeding CL2


We plan on correcting the problem in this manner:

Raising Feed Rate on CL2 + Dechlor

Time estimated that it will take to correct problem:

ASAP

Sincerely,



10-25-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NetForm 2