

REPORT OF NON COMPLIANCE

NAME OF FACILITY: WALNUT RIDGE, CITY OF

PERMIT NUMBER: AR0046566

PERIOD ENDING: April 2020

001-A

PARAMETER VIOLATED	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG	C/BOD CONC 7 DAY AVG
REPORTED VIOLATIONS	420.0	704.0	1436.0	14.9	18.9	15.7	19.8	16.1	17.9	16.4	34.1
PARAMETER VIOLATED	400.0	400.0	400.0	10.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0
WEEK OF	04/14/20	04/22/20	04/29/20	04/06/20	04/07/20	04/13/20	04/14/20	04/20/20	04/28/20	04/29/20	

CAUSE OF VIOLATION: Lack of Biological Mass

Please fill out the following information

DURATION OF VIOLATION: Month of May

CORRECTIVE ACTION: Feed Plant, Adjust Chem feed

EXPECTED COMPLIANCE DATE: June 1


 SIGNATURE / DATE 6-8-20

REPORT OF NON COMPLIANCE

NAME OF FACILITY: WALNUT RIDGE, CITY OF

PERMIT NUMBER: AR0046566 001-A

PERIOD ENDING: April 2020

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	Mercury total recoverable CONC Mo Avg
REPORTED VIOLATIONS	24.2	28.3	11.3	11.0	12.0	13.7	19.2	14.1	17.5	19.1	19.0	0.026
PARAMETER VIOLATED	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	0.0134
WEEK OF	04/07/20	04/08/20	04/13/20	04/14/20	04/15/20	04/20/20	04/21/20	04/22/20	04/27/20	04/28/20	04/29/20	


Please fill out the following information

CAUSE OF VIOLATION: Leak of Bio-Mass

DURATION OF VIOLATION: Month of May

CORRECTIVE ACTION: Feed Molasses

EXPECTED COMPLIANCE DATE: June 1



 SIGNATURE / DATE: Jonathan 6-8-20

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING 04/30/20

PARAMETER VIOLATED	TSS CONC	TSS CONC	TSS CONC	TSS CONC	TSS CONC	TSS CONC	NITROGEN AMMONIA LDG	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC
	MG AVG	7 DAY AVG	7 DAY AVG	7 DAY AVG	7 DAY AVG	7 DAY AVG	MO. AVG	MO. AVG	7 DAY AVG
REPORTED VIOLATIONS	18.2	24.0	31.0	31.0	24.5	44.0	72.7	15	16.3
PARAMETER VIOLATED	15.0	22.5	22.5	22.5	22.5	225.0	59.5	6.0	9.0
WEEK OF	03/30/20		03/31/20	04/01/20	04/13/20	04/29/20	04/06/20		

Please fill out the following information

CAUSE OF VIOLATION Lack of Bio Mass

DURATION OF VIOLATIO Month of May

CORRECTIVE ACTION Feed Plant

EXPECTED COMPLIANCI June 1st

Jon Koff 6-8-20
SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
PERMIT NUMBER AR0046566 001-A
PERIOD ENDING 04/30/20

PARAMETER VIOLATED	Mercury, total recoverable Edg Mo Avg	FECAL 30DA GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO
REPORTED VIOLATIONS	0.0008	437.0	5580.0	9540.0	4310.0	420.0	2120.0	7400.0
PARAMETER VIOLATED	0.000133	200.0	400.0	400.0	400.0	400.0	400.0	400.0
WEEK OF		03/30/20	03/31/20	04/01/20	04/06/20	04/08/20	04/13/20	


Please fill out the following information

CAUSE OF VIOLATION Not Available

DURATION OF VIOLATION Month of May

CORRECTIVE ACTION N-A

EXPECTED COMPLIANCE June 1

 6-8-20
 SIGNATURE / DATE