

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
PERMIT NUMBER AR0046566 001-A
PERIOD ENDING April 2017

PARAMETER VIOLATED	C/BOD CONC 7 DAY AVG MAX	C/BOD CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	15.60	25.10	12.0	13.30	11.6	13.1	13.30	12.00
PARAMETER VIOLATED	15.0	15.0	6.0	9.0	9.0	9.0	9.0	9.0
WEEK OF	Apr 17 17	Apr 18 17	Apr 03 17	Apr 04 17	Apr 05 17	Apr 10 17	4/11/2017	


Please fill out the following information

CAUSE OF VIOLATION Washout Due to Heavy Rainfall

DURATION OF VIOLATION Month of April

CORRECTIVE ACTION Shut Down Wastage & Feed
Feed Source to boost bio Mass

EXPECTED COMPLIANCE DATE June 1st 2017

 5-24-17
 SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING April 2017

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX				
REPORTED VIOLATIONS	16.6	11.50	20.8	12.60				
PARAMETER VIOLATED	9	9.0	9.0	9.0				

WEEK OF Apr 13 17 Apr 18 17 Apr 19 17 Apr 27 17


Please fill out the following information

CAUSE OF VIOLATION WASHOUT DUE TO HEAVY RAINFALL

DURATION OF VIOLATION MONTH of APRIL

CORRECTIVE ACTION SHUT DOWN WASTING + FEED
Food Source to Boost Bio Mass

EXPECTED COMPLIANCE DATE June 1st 2017

 5-24-17
SIGNATURE / DATE