

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF-WWTP

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING April 2018

PARAMETER VIOLATED

NITROGEN AMMONIA CONC 7 DAY AVG MAX	FECAL 7 DAY GEO						
9.60	673						
9.0	400						

REPORTED VIOLATIONS

PARAMETER VIOLATED

WEEK OF 4/9/2018 Apr 01 18

Please fill out the following information

CAUSE OF VIOLATION Low BioMass

DURATION OF VIOLATION Month of April

CORRECTIVE ACTION Adjust Wasting. Moving toward construction of new treatment facility in 2019

EXPECTED COMPLIANCE DATE May 1 2018

Jon Kopp

05/24/2018

SIGNATURE / DATE