

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING August 2017

PARAMETER VIOLATED	Cl2 DAILY MAX						
REPORTED VIOLATIONS	0.080						
PARAMETER VIOLATED	0.011						

WEEK OF Aug 09 17

Please fill out the following information

CAUSE OF VIOLATION Operational Error

DURATION OF VIOLATION August 9th

CORRECTIVE ACTION Adjust chemical feed rates

EXPECTED COMPLIANCE DATE August 10th

Jon Kepp

09/20/2017

SIGNATURE / DATE