

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: CITY OF WALNUT RIDGE WWTP
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
DECEMBER	NH3 MONTHLY AVERAGE	59.78		59.5
DECEMBER	NH3 MONTHLY AVERAGE		15.57	6.0
11/30/20	NH3 7 DAY AVERAGE		14.6	9.0
12/1/20	NH3 7 DAY AVERAGE		14.0	9.0

We feel this problem was due to:
Low MLSS

We plan on correcting the problem in this manner:
The limit is on its way down due to continued work on diffusers and aeration

Time estimated that it will take to correct problem:
Month of January

Sincerely,

Jon Kopp

2-14-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

MCR Form 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: CITY OF WALNUT RIDGE WWTP
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/02/20	NH3 7 DAY AVERAGE		16.5	9.0
12/07/20	NH3 7 DAY AVERAGE		19.4	9.0
12/08/20	NH3 7 DAY AVERAGE		13.1	9.0
12/09/20	NH3 7 DAY AVERAGE		14.0	9.0

We feel this problem was due to:
Low MLSS

We plan on correcting the problem in this manner:
The limit is on its way down due to continued work on diffusers and aeration.

Time estimated that it will take to correct problem:
The Month of January

Sincerely,

Jon Kopp

2-14-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

Netform 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
Facility: CITY OF WALNUT RIDGE WWTP
Address: 1002 OAK STREET
City: WALNUT RIDGE State: AR Zip: 72476
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/16/20	NH3 7 DAY AVERAGE		10.6	9.0
12/21/20	NH3 7 DAY AVERAGE		21.3	9.0
12/22/20	NH3 7 DAY AVERAGE		20.2	9.0
12/23/20	NH3 7 DAY AVERAGE		19.4	9.0

We feel this problem was due to:
Low MLSS

We plan on correcting the problem in this manner:
The limit is on its way down due to continued work on diffusers and aeration

Time estimated that it will take to correct problem:
Month of January

Sincerely,

Jon Kopp
Submitted By:

2-14-21
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

ACRform 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
Facility: CITY OF WALNUT RIDGE WWTP
Address: 1002 OAK STREET
City: WALNUT RIDGE State: AR Zip: 72476
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/28/20	NH3 7 DAY AVERAGE		23.3	9.0
12/29/20	NH3 7 DAY AVERAGE		17.9	9.0
12/30/20	NH3 7 DAY AVERAGE		17.5	9.0
11/30/20	CHLORINE INSTANTANEOUS MAXIMUM		0.34	0.011

We feel this problem was due to:

Low MLSS and a Frozen declore line

Jon Kopp

We plan on correcting the problem in this manner:

The limit is on its way down due to continued work on diffusers and aeration. New line installed for Declore

Time estimated that it will take to correct problem:

Month of January

Sincerely,

Jon Kopp

2-14-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

ncrform 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: CITY OF WALNUT RIDGE WWTP
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/30/20	CHLORINE INSTANTANEOUS MAXIMUM		0.08	0.011
DECEMBER	BOD MONTHLY AVERAGE	14.91		10.0
12/07/20	BOD 7 DAY AVERAGE		17.2	15.0
12/09/20	BOD 7 DAY AVERAGE		17.8	15.0

We feel this problem was due to:
Low MLSS

We plan on correcting the problem in this manner:

The limit is on its way down due to continued work on diffusers and aeration

Time estimated that it will take to correct problem:

Month of January

Sincerely,

Jon Kopp

2-14-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NCR Form 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality - Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
Facility: CITY OF WALNUT RIDGE WWTP
Address: 1002 OAK STREET
City: WALNUT RIDGE State: AR Zip: 72476
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/21/20	BOD 7 DAY AVERAGE		20.7	15.0
12/22/20	BOD 7 DAY AVERAGE		17.4	15.0
12/23/20	BOD 7 DAY AVERAGE		15.1	15.0
12/28/20	BOD 7 DAY AVERAGE		19.1	15.0

We feel this problem was due to:

Low MLSS

We plan on correcting the problem in this manner:

The limit is on its way down due to continued work on diffusers and aeration

Time estimated that it will take to correct problem:

The Month of January

Sincerely,

Jon Kepp

Submitted By:

2-14-21

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NCR Form 2

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0046566 Discharge Number: 001-A
 Facility: CITY OF WALNUT RIDGE WWTP
 Address: 1002 OAK STREET
 City: WALNUT RIDGE State: AR Zip: 72476
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/29/20	BOD 7 DAY AVERAGE		25.0	15.0
12/30/20	BOD 7 DAY AVERAGE		16.5	15.0

We feel this problem was due to:
Low MLSS

We plan on correcting the problem in this manner:

The limit is on its way down due to continued work on diffusers and aeration.

Time estimated that it will take to correct problem:
Month of January

Sincerely,

Jon Kepp
 Submitted By:

2-14-21
 Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NCR Form 2