

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING February 2019

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7-DAY AVG MAX								
REPORTED VIOLATIONS	9.20								
PARAMETER VIOLATED	2.0								

WEEK OF 2/27/2019

Please fill out the following information

CAUSE OF VIOLATION Lack of BioMass

DURATION OF VIOLATIO Feb-March

CORRECTIVE ACTION Supplemental food source and adjust wasting

EXPECTED COMPLIANCI April 1st

Jon Koops

03-25-2019