

REPORT OF NON COMPLIANCE

NAME OF FACILITY

WALNUT RIDGE, CITY OF

PERMIT NUMBER

AR0046566 001-A

PERIOD ENDING

June 2020

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	Mercury, total recoverable Ldg Mo Avg	FECAL 7 DAY GEO	FECAL 7 DAY GEO	C/BOD CONC 7 DAY AVG
REPORTED VIOLATIONS	24.9	29.8	35.9	21.5	22.7	19.2	0.0180	550.0	1224.0	31.0
PARAMETER VIOLATED	6.0	6.0	6.0	6.0	6.0	6.0	0.0134	400.0	400.0	15.0
WEEK OF	06/15/20	06/16/20	06/17/20	06/22/20	06/23/20	06/24/20		06/01/20	06/09/20	06/17/20

CAUSE OF VIOLATION

Please fill out the following information
 Feed - Injection Malfunction on Chlorine.

DURATION OF VIOLATION

Month of June

CORRECTIVE ACTION

Working with Civil Engineers, Feeding Plant

EXPECTED COMPLIANCE DATE

Aug 1

SIGNATURE / DATE

[Signature] 7/20/20

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
 PERMIT NUMBER AR0046566 001-A
 PERIOD ENDING 06/30/20

PARAMETER VIOLATED	TSS CONC 7 DAY AVG	NITROGEN AMMONIA LBG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	24.0	70.0	21.5	16.3	20.1	25.9	21.8	19.0
PARAMETER VIOLATED	22.5	39.7	4.0	6.0	6.0	6.0	6.0	6.0
WEEK OF	06/01/20			06/02/20	06/03/20	06/08/20	06/09/20	06/10/20


Please fill out the following information

CAUSE OF VIOLATION Low Bio - Mass

DURATION OF VIOLATIO Most of June

CORRECTIVE ACTION Working With Crist Eng. & Feeding Plant

EXPECTED COMPLIANCE Aug 1

 7-20-20
 SIGNATURE / DATE