

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING July 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	
REPORTED VIOLATIONS	11.8	20.3	18.4	18.7	30.5	23.6	17.6	7.3	
PARAMETER VIOLATED	4.0	6.0	6.0	6.0	6.0	6.0	6.0	6	
<i>WEEK OF</i>		<i>Jul 02</i>	<i>Jul 03</i>	<i>Jul 06</i>	<i>Jul 09</i>	<i>Jul 10</i>	<i>Jul 11</i>	<i>Jul 16</i>	

*Please fill out the following information*

CAUSE OF VIOLATION Lack of BioMass

DURATION OF VIOLATIO Through the 16th of July

CORRECTIVE ACTION Feed Caustic Soda and Dried Mollasses

EXPECTED COMPLIANCI July 16th 2018

*Jon Kopp*

08/19/2018

SIGNATURE / DATE

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING July 2018

PARAMETER VIOLATED	FECAL 30DA GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO	
REPORTED VIOLATIONS	371	600	544	827	518	632	460.0	498.0	
PARAMETER VIOLATED	200	400	400	400	400	400	400	400	
<i>WEEK OF</i>		<i>Jul 02</i>	<i>Jul 03</i>	<i>Jul 09</i>	<i>Jul 10</i>	<i>Jul 11</i>	<i>Jul 16</i>	<i>Jul 25</i>	

*Please fill out the following information*

CAUSE OF VIOLATION Chemical feed rate

DURATION OF VIOLATIO Month of July

CORRECTIVE ACTION Raise CL2 feed rate and Sodium Bisulfite feed rate

EXPECTED COMPLIANCI July 30th 2018

*Jon Kopp*

08/19/2018

SIGNATURE / DATE