

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WWTP

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING June 2017

	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX			
PARAMETER VIOLATED								
REPORTED VIOLATIONS	4.60	7.30	11.90	16.30	7.6			
PARAMETER VIOLATED	4.0	6.0	6.0	6.0	6.0			
WEEK OF		<i>May 30 17</i>	<i>May 31 17</i>	<i>Jun 01 17</i>	<i>Jun 05 17</i>			


Please fill out the following information

CAUSE OF VIOLATION lack of BioMass

DURATION OF VIOLATION Month of June

CORRECTIVE ACTION Feed supplemental food source and repair and replace aeration lines

EXPECTED COMPLIANCE DATE July 1st

 07/24/2017

 SIGNATURE / DATE