

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING June 2019

PARAMETER VIOLATED	NITROGEN AMMONIA LDG	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC
	MO AVG	MO AVG	7 DAY AVG	7 DAY AVG	7 DAY AVG	7 DAY AVG	MO AVG	7 DAY AVG	7 DAY AVG
REPORTED VIOLATIONS	57.90	19.4	15.60	17.1	18.5	12.80	11.2	15.6	20.0
PARAMETER VIOLATED	39.1	4.0	6.0	6.0	6.0	6.0	6	6.0	6
WEEK OF			Jun 03	Jun 04	Jun 05	Jun 10	Jun 11	Jun 12	06/17

*Please fill out the following information*

CAUSE OF VIOLATION Low Bio Mass

DURATION OF VIOLATIO Month of June

CORRECTIVE ACTION Replace and repair air lines, feed supplemental food source, adjust wasting

EXPECTED COMPLIANCI July 2019

*Jon Kepp*

07/25/2019

SIGNATURE / DATE

# REPORT OF NON COMPLIANCE

NAME OF FACILITY

WALNUT RIDGE, CITY OF

PERMIT NUMBER

AR0046566 001-A

PERIOD ENDING

June 2019

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	FECAL 7 DAY GEO	C/BOD CONC MO AVG	C/BOD CONC 7 DAY AVG
REPORTED VIOLATIONS	28.1	28.3	27.4	20.9	17	824	16	19.1
PARAMETER VIOLATED	6	6	6	6	6	400	10	15
WEEK OF	18-Jun	19-Jun	24-Jun	25-Jun	26-Jun			24-Jun

Please fill out the following information

CAUSE OF VIOLATION

low Bio Mass

DURATION OF VIOLATION

Month of June

CORRECTIVE ACTION

Replace & Repair air lines, Feed Supplemental Food source & Adjust Watering

EXPECTED COMPLIANCE DATE

July 2019

SIGNATURE / DATE

*[Signature]* 7/25/19