

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING May 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	9.7	7.1	9.2	9.4	9.9	14.9	10.6	10.8
PARAMETER VIOLATED	4.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0
WEEK OF	May 07	May 08	May 09	May 15	May 16	May 21	May 22	May 23

Please fill out the following information

CAUSE OF VIOLATION Lack of Biomass

DURATION OF VIOLATIO Month of May

CORRECTIVE ACTION Adjust Air, sludge wasting,

EXPECTED COMPLIANCI July 1st.

Jon Kopp 06/18/2018
SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING May 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	NITROGEN AMMONIA CONC	C12 DAILY MAX	C12 DAILY MAX	FECAL 7 DAY GEO	FECAL 7 DAY GEO		
	7 DAY AVG MAX	7 DAY AVG MAX	7 DAY AVG MAX						
REPORTED VIOLATIONS	13.9	18.0	20.7	0.08	0.09	1020	814		
PARAMETER VIOLATED	6.0	6.0	6.0	0.11	0.11	400	400		
WEEK OF	May 29 18	May 30	May 31	May 01	May 14	May 21	May 23		

Please fill out the following information

CAUSE OF VIOLATION Lack of BioMass

DURATION OF VIOLATIO Month of May

CORRECTIVE ACTION Adjust Air, and sludge wasting

EXPECTED COMPLIANCI July 1


 06/18/2018

 SIGNATURE / DATE