

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WW TREATMENT PLANT

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING November 2017

PARAMETER VIOLATED	Cl2 DAILY MAX						
REPORTED VIOLATIONS	0.05						
PARAMETER VIOLATED	0.011						

WEEK OF Nov 22 17

Please fill out the following information

CAUSE OF VIOLATION Operator Error

DURATION OF VIOLATION November 22

CORRECTIVE ACTION Adjust feed rate of DeChlorination

EXPECTED COMPLIANCE DATE November 23

Jon Kopp

12/21/2017

SIGNATURE / DATE