

REPORT OF NON COMPLIANCE

NAME OF FACILITY

WALNUT RIDGE, CITY OF

PERMIT NUMBER

AR0046566 001-A

PERIOD ENDING

December 2019

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG	CHLORINE TOTAL		CHLORINE TOTAL		CHLORINE TOTAL		CHLORINE TOTAL		CHLORINE TOTAL		CHLORINE TOTAL		CHLORINE TOTAL	
		RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL	RESIDUAL
REPORTED VIOLATIONS	19.4	0.07	0.07	0.04	0.08	0.08	0.08	0.12	0.04	0.04	0.04	0.07	0.07	0.88	
PARAMETER VIOLATED	9	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	
WEEK OF	12/27/19	12/02/19	12/03/19	12/04/19	12/09/19	12/10/19	12/11/19	12/16/19	12/17/19	12/18/19	12/23/19	12/27/19			

Please fill out the following information

CAUSE OF VIOLATION

Ammonia is caused by low Bio-Mass

Cl₂ is unknown. We are running 3X our normal amount of De-chloro and still receiving violations. Walnut Ridge will be doing a BMR QA study to perform Cl₂ in house as we believe the contracted lab is not doing accurate analysis on Cl₂.

DURATION OF VIOLATION

Month of Dec

CORRECTIVE ACTION

EXPECTED COMPLIANCE DATE

Feb 28 2020

 1-23-20
SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
 PERMIT NUMBER AR0046566 001-A
 PERIOD ENDING December 2019

PARAMETER VIOLATED	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG	NITROGEN AMMONIA CONC 7 DAY AVG
REPORTED VIOLATIONS	12.70	11.40	13.30	13.10	15.00	13.70	13.30	16.50	20.90
PARAMETER VIOLATED	6.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
WEEK OF	12/09/19	12/10/19	12/11/19	12/16/19	12/17/19	12/18/19	12/23/19	12/26/19	

Please fill out the following information

CAUSE OF VIOLATION Washout / Low Bio Mass

DURATION OF VIOLATIO Month of Dec

CORRECTIVE ACTION Feed Food Source (Rice Bran / Molasses)

EXPECTED COMPLIANCE Feb 2020


 SIGNATURE / DATE 1/23/2020