

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
PERMIT NUMBER AR0046566 001-A
PERIOD ENDING January 2017

PARAMETER VIOLATED	C12	C12	C12	C12	C12		
	DAILY MAX	DAILY MAX	DAILY MAX	DAILY MAX	DAILY MAX		
REPORTED VIOLATIONS	0.03	0.03	0.03	0.04	0.05		
PARAMETER VIOLATED	0.011	0.011	0.011	0.011	0.011		

WEEK OF Jan 03 17 Jan 10 17 Jan 18 17 Jan 23 17 Jan 24 17


Please fill out the following information

CAUSE OF VIOLATION Unknown

DURATION OF VIOLATION Jan 2017

CORRECTIVE ACTION Adjust Chem Feed Rates

EXPECTED COMPLIANCE DATE Feb 2017

 1-23-17
 SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF
PERMIT NUMBER AR0046566 001-A
PERIOD ENDING January 2017

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC MO AVG
REPORTED VIOLATIONS	10.00	11.90	11.20	12.90	15.20	16.30	9.60
PARAMETER VIOLATED	9.000	9.000	9.000	9.000	9.0	9.0	6.0

WEEK OF Jan 10 17 Jan 11 17 Jan 16 17 Jan 23 17 Jan 24 17 Jan 25 17


Please fill out the following information

CAUSE OF VIOLATION Low Bio-Mass

DURATION OF VIOLATION Month of January

CORRECTIVE ACTION Adjust Wasting & Feed.

EXPECTED COMPLIANCE DATE Feb. 2017

 1-23-17
 SIGNATURE / DATE