

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WWTP

PERMIT NUMBER 46566 001-A

PERIOD ENDING January 2018

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	CL2 DAILY MAX	CL2 DAILY MAX					
REPORTED VIOLATIONS	9.40	0.06	0.05					
PARAMETER VIOLATED	9.00	0.011	0.011					

WEEK OF Jan 22 18 Jan 24 18 Jan 30 18

*Please fill out the following information*

CAUSE OF VIOLATION Not known at this time

DURATION OF VIOLATION Ammonia= Week of January 22 2018

CL2 was out 2 days for the month of January

CORRECTIVE ACTION adjust wasteing and chemical feed rate

EXPECTED COMPLIANCE DATE February 1st

Jon Kopp 2/25/2018  
SIGNATURE / DATE