

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WW TREATMENT PLANT

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING November 2017

PARAMETER VIOLATED	Cl2 DAILY MAX						
REPORTED VIOLATIONS	0.05						
PARAMETER VIOLATED	0.011						

WEEK OF Nov 22 17

*Please fill out the following information*

CAUSE OF VIOLATION Operator Error

DURATION OF VIOLATION November 22

CORRECTIVE ACTION Adjust feed rate of DeChlorination

EXPECTED COMPLIANCE DATE November 23

*Jon Kopp*

12/21/2017

SIGNATURE / DATE