

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF  
 PERMIT NUMBER AR0046566      001-A  
 PERIOD ENDING JUNE 2012

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX				
REPORTED VIOLATIONS	40.5	6.7	13.4	12.8				
PERMIT CONDITION	39.7	4.0	6.0	6.0				
WEEK OF	Jun 06 12		Jun 13 12					

*Please fill out the following information*

CAUSE OF VIOLATION Agitated Aeration Basin Due to Rehabilitation of Air Lines.

DURATION OF VIOLATION June 4<sup>th</sup> through June 17<sup>th</sup>


CORRECTIVE ACTION Allow Basin to adjust to newly introduced air quantity

EXPECTED COMPLIANCE DATE June 18<sup>th</sup>

A. J. Henry, Jr. 07/23/2012  
 SIGNATURE / DATE



City Water Works  
216 S.W. 4<sup>th</sup> St.  
Walnut Ridge, AR 72476



ADEQ  
NPDES Enforcement  
5301 Northshore Drive  
North Little Rock, AR 72118

7211835317 R015

