


## Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: Walnut Ridge NPDES Permit No.: AP0046566 Monitoring Period (Month/Year): Jan / 2016

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location

  
 \_\_\_\_\_  
 Signature of Cognizant or Ranking Official

\_\_\_\_\_  
 Date 2-18-16

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

# REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE

PERMIT NUMBER AR0046566      001-A

PERIOD ENDING January 2016

PARAMETER VIOLATED	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	9.21	10.4	10.6	10.9	11.6	12.8	9.2	14.7
PARAMETER VIOLATED	6.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
WEEK OF		Jan 05 16	Jan 06 16	Jan 13 16	Jan 18 16	Jan 19 16	Jan 20 16	Jan 01 00


*Please fill out the following information*

CAUSE OF VIOLATION Washout Due to Heavy RainFall

DURATION OF VIOLATION January 1<sup>st</sup> through the Month of February

CORRECTIVE ACTION Feed Rice Bran + Dehydrated Molasses to try and boost Biomass. Adjust Wastewg.

EXPECTED COMPLIANCE DATE March 1<sup>st</sup>


  
 2-18-16  
 SIGNATURE / DATE

City Water Works  
216 S. W. 4th St.  
Walnut Ridge, AR 72476



**ADEQ**  
**NPDES ENFORCEMENT**  
5301 Northshore Drive  
North Little Rock, AR 72118

7211885317 R015

