

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE, CITY OF

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING APRIL 2012

PARAMETER VIOLATED	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX			
REPORTED VIOLATIONS	13.1	16.6	13.7	9.8	14.3			
PERMIT CONDITION	6.0	9.0	9.0	9.0	9.0			

WEEK OF

Apr 04 12 Apr 11 12 Apr 16 12 Apr 25 12


Please fill out the following information

CAUSE OF VIOLATION _____

DURATION OF VIOLATION Month of April

CORRECTIVE ACTION Adjust Wastings

EXPECTED COMPLIANCE DATE May 1st


05-23-2012
 SIGNATURE / DATE