

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WWTP

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING April 2016

PARAMETER VIOLATED	C/BOD CONC MO AVG	C/BOD CONC 7 DAY AVG MAX	C/BOD CONC 7 DAY AVG MAX	C/BOD CONC 7 DAY AVG MAX	C/BOD CONC 7 DAY AVG MAX	TSS CONC MO AVG	TSS CONC 7 DAY AVG MAX	TSS CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	13.6	24	30.7	23.50	20.2	19.4	25.0	25.0
PARAMETER VIOLATED	10	15	15.0	15.0	15	15.0	22.5	22.5
WEEK OF	Apr 13 16		Apr 18 16	Apr 19 16	Apr 20 16	Apr 11 16		4/12/2016


Please fill out the following information

CAUSE OF VIOLATION N-A

DURATION OF VIOLATION N-A

CORRECTIVE ACTION As Per (CAP) an Engineering Firm has been contracted to resolve this issue as standard procedure used in the past is not resolving our issues.

EXPECTED COMPLIANCE DATE N/A

 5-24-16
 SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WWTP
PERMIT NUMBER AR0046566 001-A
PERIOD ENDING April 2016

PARAMETER VIOLATED	TSS CONC 7 DAY AVG MAX	TSS CONC 7 DAY AVG MAX	TSS CONC 7 DAY AVG MAX	TSS CONC 7 DAY AVG MAX	DO CONC INST MIN	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	32.0	34.00	30.0	28.70	5.9	100.99	20.5	12.6
PARAMETER VIOLATED	22.5	22.5	22.5	22.5	6	59.5	6.0	9.0
WEEK OF	Apr 13 16	Apr 18 16	Apr 19 16	Apr 20 16	Apr 20 16			4/5/2016


Please fill out the following information

CAUSE OF VIOLATION N-A

DURATION OF VIOLATION N-A

CORRECTIVE ACTION As Per CAP request
An Engineering Consultant has been
Contracted to resolve this issue as we are unable
to resolve the Problem using standard Procedure that
has always worked in the Past

EXPECTED COMPLIANCE DATE N-A

 5-24-16
SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WWTP

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING April 2016

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX
REPORTED VIOLATIONS	14.0	24.9	29.5	30.20	30.0	25.50	25.4	16.3
PARAMETER VIOLATED	9.0	9.0	9.0	9.0	9	9.0	9.0	9.0
WEEK OF	Apr 06 16	Apr 11 16	Apr 12 16	Apr 13 16	Apr 18 16	Apr 19 16	Apr 20 16	4/25/2016


Please fill out the following information

CAUSE OF VIOLATION N/A

DURATION OF VIOLATION N/A

CORRECTIVE ACTION As per (CAP) request An Engineering Consultant has contracted to resolve the issue as standard Procedure used in the Past is not working.

EXPECTED COMPLIANCE DATE N/A

 5-24-16
 SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY WALNUT RIDGE WWTP

PERMIT NUMBER AR0046566 001-A

PERIOD ENDING April 2016

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX					
	REPORTED VIOLATIONS	17.5	19.6				
PARAMETER VIOLATED	9.0	9.0					
WEEK OF	Apr 26 16	Apr 27 16					


Please fill out the following information

CAUSE OF VIOLATION N/A

DURATION OF VIOLATION N/A



CORRECTIVE ACTION As per (CAP) Request An Engineering Firm has been contracted to resolve the issue as standard Procedure used in the Past is not working.

EXPECTED COMPLIANCE DATE _____



 SIGNATURE / DATE 5-24-16

CWW
216 S.W. 4th
Walnut Ridge



ADEQ
NPDES Enforcement
5301 Northshore Drive
North Little Rock, AR 72118