

# REPORT OF NON COMPLIANCE

**NAME OF FACILITY** WALNUT RIDGE, CITY OF  
**PERMIT NUMBER** AR0046566      001-A  
**PERIOD ENDING** JUNE 2012

PARAMETER VIOLATED	NITROGEN AMMONIA LDG MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX				
REPORTED VIOLATIONS	40.5	6.7	13.4	12.8				
PERMIT CONDITION	39.7	4.0	6.0	6.0				
WEEK OF			Jun 06 12	Jun 13 12				

*Please fill out the following information*

**CAUSE OF VIOLATION** Agitated Aeration Basin Due to Rehabilitation of Air Lines.

**DURATION OF VIOLATION** June 4<sup>th</sup> through June 17<sup>th</sup>

**CORRECTIVE ACTION** Allow Basin to adjust to newly introduced air quantity

**EXPECTED COMPLIANCE DATE** June 18<sup>th</sup>

A. J. Henry, Jr.      07/23/2012  
 SIGNATURE / DATE