

**CITY OF CONWAY**  
**CONWAY CORPORATION**  
**WASTEWATER TREATMENT PLANT**  
**NPDES PERMIT NO.: AR0051951**  
**NON-COMPLYING DISCHARGE REPORT**

DATE OF ANALYSIS	PARAMETER	7 DAY AVG. OR 30 DAY AVG.	QUANTITY PERMIT MAXIMUM	QUANTITY ACTUAL	CAUSE OF NON-COMPLIANCE	ESTIMATED LENGTH OF NON-COMPLIANCE	STEPS BEING TAKEN TO COMPLY WITH PERMIT
7/8/15	Dissolved Oxygen	INSTANTANEOUS MINIMUM of 2	INSTANTANEOUS MINIMUM of 2	1.6	Return Pump MALFUNCTION	1 hour	Monitor D.O. more closely

CONWAY CORPORATION: RICHARD ARNOLD, CEO

Signed: David Bradley