

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0051951 Discharge Number: 23-01095
Facility: Conway Corp Tupelo Bayou WWTP
Address: 1405 Lollie Road
City: Conway State: AR Zip: 72034
Contact: Lee Tedford Phone: (501)548-3041

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>March 30 day avg</u>	<u>TSS</u>	<u>30.5</u>	<u>mg/l</u>	<u>30 mg/L</u>

We feel this problem was due to:

Excessive rainfall due to I/I caused increased flow at the plant.

We plan on correcting the problem in this manner:

Currently reviewing data from system wide flow monitoring study that has identified areas of increased I/I. We will work toward a plan to correct I/I in the noted areas with repair solutions

Time estimated that it will take to correct problem:

1 year.

Sincerely,

Lee Tedford

4/14/2022

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)