

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0051951 Discharge Number: \_\_\_\_\_  
Facility: Tupelo Bayou WWTP  
Address: 1405 Lollie Road  
City: Conway State: AR Zip: 72034  
Contact: Lee Tedford Phone: (501)548-3041

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>6-13-2022</u>	<u>pH</u>		<u>5.94</u>	<u>6.0 ≥ 9.0</u>

We feel this problem was due to:

Nitrification and filamentous bacteria.

We plan on correcting the problem in this manner:

Increased WAS rate and lowered DO in aeration basin.

Time estimated that it will take to correct problem:

Problem was corrected by the next morning.

Sincerely,

Lee Tedford

Submitted By:

7-21-2022  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)