

ADEQ

A R K A N S A S
Department of Environmental Quality

June 21, 2016

CERTIFIED MAIL: 91 7199 9991 7036 5030 0802

David Bradley, Manager, Water Systems
Conway Corporation–Tupelo Bayou WWTP
P.O. Box 99
Conway, AR 72033

RE: NPDES Permit Number: AR0051951, AFIN 23-01095
Notice of Sanitary Sewer Overflows

Dear Mr. Bradley:

The Department has conducted a file review of the above referenced permit and determined your facility reported thirteen (13) Sanitary Sewer Overflows (SSOs) from June 1, 2013 through May 31, 2016. A detailed list is included as Appendix A. SSOs constitute unpermitted discharges, which violate Ark. Code Ann. § 8-4-217(a)(3).

The Department is requesting a written response that includes current issues with the system and the sanitary system management plan (including corrective actions and preventative measures). Please submit your written response no later than **July 11, 2016**.

Thank you for your attention to this matter. Please refer to NPDES Permit Number AR0051951 and AFIN 23-01095 in any written correspondence to this Department. Should you have any questions, feel free to call me at 501-682-0823 or e-mail me at barber@adeq.state.ar.us.

Sincerely,



Kyle Barber
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Appendix A

NPID	FacilityName	Location	DateSSOFormReceived	DateOverflowStarted	DateOverflowStopped	TimeOverflowStarted	TimeOverflowStopped	Volume	Stream	IsSSO	IsBypass	Description	Comments
AR0051951		Parkway Street & Prince Street (behind Sherman Williams store) - Manhole 5052M9 - receiving water	3/10/2016 0:00	3/10/2016 0:00		12:30 PM		10000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Manhole number 5253M21 College Street by the Railroad Tracks	12/28/2015 0:00	12/27/2015 0:00	12/28/2015 0:00	8:00 PM	10:00 AM	20000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Manhole number 5052M9 at corner of Prince and Parkway behind Sherman Williams paint store	12/28/2015 0:00	12/27/2015 0:00	12/28/2015 0:00	8:00 PM	10:00 AM	20000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Manhole number 5252M14 on Prairie Street near the Kitchen Store	12/28/2015 0:00	12/27/2015 0:00	12/28/2015 0:00	8:00 PM	10:00 AM	20000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Prince & Parkway - Manhole 5052M9 - overflow to river, stream	7/10/2015 0:00	7/7/2015 0:00	7/7/2015 0:00	9:00 PM	11:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		@ Corner of Prairie near Kitchen Store - Manhole 5252	7/10/2015 0:00	7/7/2015 0:00	7/7/2015 0:00	9:00 PM	11:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Manhole 5253M21 at College Ave, near St Joseph Gym	7/10/2015 0:00	7/7/2015 0:00	7/7/2015 0:00	9:00 PM	11:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Prince Street and Parkway - MH #5052M9 - manhole overflowed into Drainage Ditch	5/11/2015 0:00	5/11/2015 0:00	5/11/2015 0:00	9:00 AM	1:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Manhole # 5253M21 at At college Street near St. Joesphs school Gym, manhole overflowed into Drainage Ditch	5/11/2015 0:00	5/11/2015 0:00	5/11/2015 0:00	9:00 AM	1:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		Prairie St. near Conway Corp. office - Manhole # 5252M9 - overflowed into Drainage Ditch	5/11/2015 0:00	5/11/2015 0:00	5/11/2015 0:00	9:00 AM	1:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		MH5052M9 Manhole behind Sherman Williams on Prince Street Near Railroad tracks Flow went into drainage Ditch beside the railroad tracks	3/16/2015 0:00	3/13/2015 0:00	3/13/2015 0:00	10:00 AM	4:00 PM	10000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		MH5253M21 College Avenue in front of St. Joseph Gym Flow went into the near by drainage ditch by railroad	3/16/2015 0:00	3/13/2015 0:00	3/13/2015 0:00	10:00 AM	4:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		
AR0051951		MH 5252 M14 Prairie Street in front of Conway Corporation's Offices Overflow went into storm drain Inlet near the manhole	3/16/2015 0:00	3/13/2015 0:00	3/13/2015 0:00	10:00 AM	4:00 PM	5000	SSO Reached Receiving Water (river,stream)	TRUE	FALSE		

Total: 120000 gallons