

ADEQ

ARKANSAS
Department of Environmental Quality

August 1, 2006

CERTIFIED MAIL RETURN RECEIPT REQUESTED (7004 2510 0004 6936 0043)

Mr. Craig Noble, General Manager
Russellville City Corporation
P.O. Box 3186
Russellville, AR 72811

RE: Application Permit Number: AR0021768C

Dear Mr. Noble:

This letter constitutes notice of the Department's final permit decision and a copy of the final permit is enclosed. There were no comments received during the comment period which necessitated any changes to the draft permit.

CERTIFICATE OF SERVICE

I, Martin Maner, hereby certify that a copy of this permit has been mailed by first class mail to Mr. Craig Noble, General Manager, Russellville City Corporation, P.O. Box 3186, Russellville, AR 72811 on or before the 1st day of August 2006.



Martin Maner, P.E.
Chief, Water Division

MM:cr

Enclosure

Cc: Patricia Goff, Commission Secretary
Shane Byrum

CONSTRUCTION PERMIT
Permit Number: AR0021768C

TO:

Russellville City Corporation
P.O. Box 3186
Russellville, AR 72811

Consulting Engineer:

Garver Engineers, LLC
P.O. Box 50
Little Rock, AR 72203

This permit is your authority to construct or modify the wastewater treatment system in accordance with the permit application and plans and specifications which were received on February 14, 2006. This permit is issued subject to the provisions of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Annotated, § 8-4-101 et seq.), and the following terms and conditions:

1. This permit shall automatically terminate unless construction of this project has been commenced within one year from the effective date and completed with all reasonable diligence. The permittee shall **notify** the Department when construction **begins**. The treatment/disposal system shall be constructed or modified in accordance with the final plans and specifications as approved by the Arkansas Department of Environmental Quality. In case any statement or representation in the aforementioned documents is found to be incorrect, this Approval may be revoked.
2. Within **thirty (30)** days of completion of construction, the Professional Engineer (PE) registered in Arkansas shall submit written certification to the Department (Enforcement Section of Water Division) that the facility has been constructed or modified in accordance with the approved plans and specifications.
3. This permit is issued in reliance upon the statements and representations made in the application and the plans and specifications and the Department has no responsibility for adequacy or proper functioning of the disposal system. Approval of the plans and specifications by the Department does not constitute assurance that the disposal system will achieve the effluent limitations required by the final NPDES permit, or that a NPDES discharge permit will be issued.
4. The equalization basin must have a permeability of less than 0.0000001 cm/sec. before the start of operation in accordance with Part 2.04 of Section 02500 of the specifications.
5. If the construction site will disturb in excess of one (1) acre, the permittee must comply with the terms of ARR150000 prior to the start of construction.
6. This facility is located as follows: Latitude: 35° 14' 56" Longitude: 93° 06' 50"; 404 Jimmy Lile Road, approximately 2 miles south of Russellville in Section 22, Township 7 North, Range 20 West in Pope County, Arkansas.
7. The receiving waters named: Whig Creek thence to the Arkansas River in Segment 3F of the Arkansas River Basin. The outfall is located at the following coordinates:
Outfall 001: Latitude: 35° 14' 44"; Longitude: 93° 06' 50"
8. Proposed Construction will include: a 12 million gallon stormwater equalization basin, a flow diversion structure, and moving the Whig Creek outfall approximately 700 feet downstream. The existing treatment system is: screening, primary clarifiers, biotowers, intermediate clarifiers, trickling filters, activated sludge, final clarifiers, and chlorine disinfection with a design flow of 7.3 MGD.

This permit shall become effective on August 1, 2006.

Signed this 31st day of July, 2006.



Martin Maner, P.E.
Chief, Water Division