

# ADEQ

ARKANSAS  
Department of Environmental Quality

December 15, 2008

CERTIFIED MAIL: RETURN RECEIPT REQUESTED ( 7006 3450 0003 4073 7913 )

Mr. Gary Smith, Director of Utilities  
City of Van Buren - Main Plant  
P.O. Box 1269  
Van Buren, AR 72957

RE: Discharge Permit Number AR0021482 – AFIN 17-00062

Dear Mr. Smith:

Enclosed is the public notice, Fact Sheet, and a copy of the draft permit which the Arkansas Department of Environmental Quality (ADEQ) has prepared under the authority of the National Pollutant Discharge Elimination System and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision.


In accordance with Arkansas Pollution Control and Ecology Commission (APCEC) Regulation No. 8, Part 2.1.6, the enclosed public notice will be published by ADEQ in a newspaper of general circulation for one (1) day only. An invoice for the cost of publishing the public notice and proof of publication will be sent to you by the advertising newspaper. The permittee must send proof of publication and payment to the following address as soon as possible but no later than 30 days from the above date. Until this Department receives proof of publication of the public notice, no further action will be taken on the issuance of your discharge permit.

Arkansas Department of Environmental Quality  
Discharge Permits Section-Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317  
501-682-0622 Fax: 501-682-0910

Comments must be received at ADEQ prior to the close of the public comment period as shown in the enclosed public notice. The public comment period will begin on the date of publication and will end no sooner than 30 days from that date. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the draft permit, please contact Marysia Jastrzebski, P.E. at (870) 446-5939.

Sincerely,



Steven L. Drown  
Chief, Water Division

SD:mj

Enclosure

PUBLIC NOTICE OF DRAFT DISCHARGE PERMIT  
AND 208 Plan  
PERMIT NUMBER AR0021482, AFIN 17-00062

This is to give notice that the Permits Branch of the Water Division of the Arkansas Department of Environmental Quality (ADEQ), 5301 Northshore Drive, North Little Rock, Arkansas 72118-5317 at telephone number (501) 682-0622, proposes a draft renewal of the permit for which an application was received on 6/2/2008 for the following applicant under the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act.

Applicant: City of Van Buren - Main Plant, 1401 Port Road, Van Buren, AR 72956. Location: approximately 1/2 mile south of I-540 overpass off Highway 59 South; Latitude: 35° 25' 09.04"; Longitude: 94° 20' 19.35" in Crawford County, Arkansas.

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan has been revised to change the design flow, change the effluent limitations for Total Suspended Solids, and add the effluent limitations for Dissolved Oxygen:

May-October:           CBOD5/TSS/NH3-N/DO = 25/30/5/2 mg/l  
November-March:      BOD5/TSS/DO = 30/30/2 mg/l  
Design flow (Q):       4.0 MGD  
Background Flow of the receiving stream (7Q10): 700 cfs

The discharge from this existing facility is made into Arkansas River in Segment 3H of the Arkansas River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 11110104 and reach # 001 is a Water of the State classified for primary contact recreation; raw water source for domestic (public and private), industrial, and agricultural water supplies; propagation of desirable species of fish and other aquatic life; and other compatible uses. The outfall is located at the following coordinates: Latitude: 35° 25' 3.27" Longitude: 94° 20' 27.18". The receiving stream is listed on the 303(d) list. Sludge will be applied at the following land application site:

Field number	New/old	Range	Township	Sections	Total Acres	Available Acres	Crop Cover	Loading Rate
I	Old	31	8	6, 7, & 8	200	150	Hay	6 DT /acre

Under North American Industry Classification System (NAICS) code of 221320, the applicant's activities are the operation of a sewage treatment plant.

ADEQ's contact person for submitting written comments, requesting information regarding the draft permit, or obtaining copy of the permit and the Fact Sheet is Marysia Jastrzebski, P.E., at the above address and telephone number. For those with Internet access, a copy of the proposed draft permit may be found on the ADEQ's website at: [http://www.adeq.state.ar.us/water/branch\\_npdes/pn\\_permits/pnpermits.asp](http://www.adeq.state.ar.us/water/branch_npdes/pn_permits/pnpermits.asp).

The last day of the comment period is 30 days after the publication date. If the last day of the comment period is a Saturday, Sunday or legal holiday, the public comment period shall expire on the next day that is not a Saturday, Sunday or legal holiday. The permit will become effective approximately two weeks after the close of the comment period unless comments are received and/or a public hearing is requested prior to the close of the comment period requiring a delay of the effective date. Comments and public hearing procedures may be found at 40 CFR Parts 124.10 through 124.12 and APCEC Regulation No. 8. All persons, including the permittee, who wish to comment on ADEQ's draft permitting decision must submit written comments to ADEQ, along with their name and mailing address. After the public comment period, and public hearing, if one is held, ADEQ will issue a final permitting decision. A Public Hearing will be held when ADEQ finds a significant degree of public interest. ADEQ will notify the applicant and each person who has submitted written comments or requested notice of the final permitting decision. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the APCEC Regulation No. 8 (Administrative Procedures).

# DRAFT

## Fact Sheet

for renewal of the draft discharge Permit Number AR0021482 to discharge to Waters of the State

### 1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317

### 2. APPLICANT.

The applicant's mailing address is:

City of Van Buren - Main Plant  
P.O. Box 1269  
Van Buren, AR 72957

The facility address is:

City of Van Buren - Main Plant  
1401 Port Road  
Van Buren, AR 72956

### 3. PREPARED BY.

The permit was prepared by:

Marysia Jastrzebski, P.E.  
Staff Engineer  
Discharge Permits Section, Water Division  
(870)446-5939  
E-mail: marysia@adeq.state.ar.us

### 4. PERMIT ACTIVITY.

Previous Permit Effective Date: December 1, 2003  
Previous Permit Expiration Date: November 30, 2008

The permittee submitted a permit renewal application on 6/2/2008 and the additional information on September 26, 2008. It is proposed that the current discharge permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

# DRAFT

## DMR Review:

The Discharge Monitoring Reports (DMR's) from the previous permit cycle were reviewed during the permit renewal process. There were several violations of Fecal Coliform Bacteria(2), Carbonaceous Biochemical Oxygen Demand(1), Biochemical Oxygen Demand (8), Total Residual Chlorine(6), and Ammonia Nitrogen(10) noted during the period of April 2003 through May 2008. The facility is in process of modifying the existing treatment facility. The proposed construction approved by the Department in February 2008 includes a new screening unit, two secondary clarifiers, UV disinfection unit and modification of the existing aerated lagoon system into an activated sludge system.

No action is necessary. It is assumed that the facility will be in compliance with all effluent limitations after the proposed improvements are completed.

## Legal Order Review:

The facility is currently under CAO No. 05-067 signed March 24, 2005. The facility is in compliance with the required schedule. According to the progress reports required by the CAO, construction began prior to the required date of February 10, 2008. The construction must be accomplished by August 3, 2009 and the compliance with the final effluent limitations for Ammonia Nitrogen must be achieved by November 3, 2009.

## **5. SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.**

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. The facility mailing address has been changed.
2. The facility physical address has been added.
3. The coordinates for the facility location and Outfall 001 have been corrected.
4. Two sets of the final limitations for the same Outfall 001 have been included: one for the existing treatment system with the design flow of 3.1 mgd and the second for the proposed treatment system with the design flow of 4.0 mgd.
5. A list of treatment units has been included for Outfall 001 on Pages 1 and 2 of Part IA.
6. An effluent limitation for Dissolved Oxygen has been included.
7. The effluent limitations for pH have been changed from 6-9 s.u. to 6.0-9.0 s.u.
8. The coordinates and narrative description of monitoring locations have been included.
9. The monitoring frequencies for all parameters except flow and biomonitoring for Outfall 001 with the design flow of 3.1 mgd have been revised.
10. The sample type for Carbonaceous Biochemical Oxygen Demand (5-day), Biochemical Oxygen Demand (5-day), Total Suspended Solids, and Ammonia Nitrogen for Outfall 001 with the design flow of 3.1 mgd has been revised.

# DRAFT

11. The 7-day Average effluent limitation for Ammonia Nitrogen for Outfall 001 with the design flow of 3.1 mgd have been slightly revised.
12. A requirement for monitoring and reporting for Total Dissolved Solids, Chlorides, Total Phosphorus and Nitrite + Nitrate Nitrogen has been included.
13. A schedule of compliance regarding TRC has been deleted.
14. A special condition requiring a Class III operator has been added in Part II of the permit.
15. A special condition describing the transition period resulting from the construction of a new treatment system that will increase the facility's design flow from 3.1 MGD to 4.0 MGD was added in Part II of the permit.
16. New critical dilution and effluent dilution series for whole effluent toxicity testing has been established for Outfall 001 with design flow of 4.0 MGD in Condition 13 of Part II of the permit.
17. Part II, Part III, and Part IV of the permit have been revised.

## 6. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.

The outfall is located at the following coordinates based on the submitted application:

Latitude: 35° 25' 03.27" Longitude: 94° 20' 27.18"

The receiving waters named:

Arkansas River in Segment 3H of the Arkansas River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 11110104 and reach # 001 is a Water of the State classified for primary contact recreation, raw water source for domestic (public and private), industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

## 7. 303(d) LIST AND ENDANGERED SPECIES CONSIDERATIONS.

### a. 303(d) List:

This facility discharges to the Arkansas River in reach # 001 of HUC 11110104. This reach is listed on the 2008 303(d) list for Total Dissolved Solids (TDS) and Chlorides. The final permit will not include any specific limitations for Total Dissolved Solids and Chlorides pending completion of the TMDL, however, in order to ensure that monitoring information is available to assess further water quality requirements for this facility, and to assist in identifying pollutant sources in this waterbody, the proposed permit will include monitoring for these parameters.

# DRAFT

A reopener clause is established in Part II of the permit, which allows the permit to be modified, if necessary, to conform with an approved waste load allocation (WLA) as part of a Total Maximum Daily Load (TMDL).

**b. Endangered Species:**

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Fact Sheet will be sent to the USF&WS for their review.

## **8. OUTFALL AND TREATMENT PROCESS DESCRIPTION.**

The following is a description of the existing treatment facility described in the application:

- a. Design Flow: 3.1 MGD
- b. Type of Treatment: screening unit, 4-cell aerated lagoon system with chlorine disinfection and dechlorination.
- c. Discharge Description: treated municipal wastewater
- d. Facility Status: This facility is classified as a Major municipal since the design flow of the facility is > 1.0 MGD.

**Transition Period:**

The permittee is proposing to modify the existing wastewater treatment facility which will increase the design flow from 3.1 MGD to 4.0 MGD.

**The permittee must notify the ADEQ when the modified treatment system is complete and no later than 30 days after the discharge at the new design flow has begun.**

The following is a description of the **new** treatment described in the application:

- a. Design Flow: 4.0 MGD
- b. Type of Treatment: screening unit, activated sludge system, secondary clarifiers, UV disinfection unit
- c. Discharge Description: treated municipal wastewater

# DRAFT

## 9. ACTIVITY.

Under the Standard Industrial Classification (SIC) code of 4952 or North American Industry Classification System (NAICS) code of 221320, the applicant's activities are the operation of a sewage treatment plant.

## 10. INDUSTRIAL WASTEWATER CONTRIBUTIONS.

This facility receives process wastewater from the following five non-categorical Significant Industrial Users and three Categorical Industrial Users:

Industrial Contributor	Principal Product	Process Wastewater Flow
Arkansas Lamp Mfg.	Lamps for hospitality Industry	800 gallons/month
FabTech, Inc.	Precision sheet metal components	230 gallons/month
River City Coatings, Inc.	Electrostatic powder coated metal parts	1776 gallons/day
Simmons Foods, Inc.	Poultry products	215,012 gallons/day
Simmons Poultry Farms, Inc.	Further Process & Par-fry Poultry products	154,747 gallons/day
Tate & Lyle	Starches –edible and industrial	46,000 gallons/day
Tyson Foods, Inc.	Poultry Products	246,470 gallons/day
Van Buren Pipe Company	PVC Pipe	1,741 gallons/day

Based on the applicant's effluent compliance history and the type of industrial contributions, standard Pretreatment Program implementation conditions are deemed appropriate at this time.

## 11. SEWAGE SLUDGE PRACTICES.

Sludge will be applied at the following land application site:

Field number	New /old	Range	Township	Sections	Total Acres	Available Acres	Crop Cover	Loading Rate
1	Old	31	8	6, 7, & 8	200	150	Hay	6 DT /acre*

\* Dry tones/acre

## 12. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a determination to issue a draft permit for the discharge described in the application. Permit requirements are based on federal regulations (40 CFR Parts 122, 124, and Subchapter N), the National Pretreatment Regulation in 40 CFR Part 403 and regulations promulgated pursuant to the Arkansas Water

# DRAFT

and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et. seq.).

a. **Final Effluent Limitations - Design Flow of 3.1 MGD**

Outfall 001(design flow of 3.1 MGD)- treated municipal wastewater

i. **Conventional and/or Toxic Pollutants**

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)					
(May-Oct)	646.4	25	40	three/week	24-hr composite
Biochemical Oxygen Demand (BOD5)					
(Nov-Apr)	775.6	30	45	three/week	24-hr composite
Total Suspended Solids (TSS)	2326.9	90	135	three/week	24-hr composite
Ammonia Nitrogen (NH3-N)					
(May-Oct)	129.3	5	7.5	three/week	24-hr composite
Dissolved Oxygen	N/A	2.0, (Inst. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Residual Chlorine (TRC)	N/A	<0.1 mg/l (Inst. Max.)		once/weekday	grab
pH	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	three/week	grab
Total Dissolved Solids	Report	Report	Report	once/month	grab
Chlorides	Report	Report	Report	once/month	grab
Total Phosphorus	Report	Report	Report	three/week	grab
Nitrite + Nitrate Nitrogen	Report	Report	Report	three/week	grab
Acute WET Testing	N/A	N/A	N/A	once/quarter	24-hr composite



# DRAFT

- ii. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

b. **Final Effluent Limitations - Design Flow of 4.0 MGD**

Outfall 001(design flow of 4.0 MGD)- treated municipal wastewater

i. **Conventional and/or Toxic Pollutants**

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)					
(May-Oct)	834	25	40	three/week	24-hr composite
Biochemical Oxygen Demand (BOD5)					
(Nov-Apr)	1000.8	30	45	three/week	24-hr composite
Total Suspended Solids (TSS)	1000.8	30	45	three/week	24-hr composite
Ammonia Nitrogen (NH3-N)					
(May-Oct)	166.8	5	7.5	three/week	24-hr composite
Dissolved Oxygen	N/A	2.0, (Inst. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab
Total Dissolved Solids	Report	Report	Report	once/month	grab
Chlorides	Report	Report	Report	once/month	grab
Total Phosphorus	Report	Report	Report	three/week	grab
Nitrite + Nitrate Nitrogen	Report	Report	Report	three/week	grab
Acute WET Testing	N/A	N/A	N/A	once/quarter	24-hr composite

# DRAFT

- ii. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

## 13. BASIS FOR PERMIT CONDITIONS.

The following is an explanation of the derivation of the conditions of the draft permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the decisions as required under 40 CFR Part 124.7 (48 FR 1413, April 1, 1983).

### Technology-Based Versus Water Quality-Based Effluent Limitations And Conditions

Following regulations promulgated at 40 CFR Part 122.44 (1)(2)(ii), the draft permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44 (a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44 (d), whichever are more stringent as follows:

Parameter	Water Quality-Based		Technology-Based/BPJ		Previous Permit		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
CBOD5								
(May-Oct)	25*	40*	25	40	25	40	25	40
BOD5								
(Nov-April)	30*	45*	30	45	30	45	30	45
TSS(design flow 3.1 mgd)	N/A	N/A	90	135	90	135	90	135
TSS(design flow 4.0 mgd)	N/A	N/A	30	45	N/A	N/A	30	45
NH3-N								
(May-Oct)	5	7.5	N/A	N/A	5	8	5	7.5
Dissolved Oxygen	2.0(Inst. Min.)		N/A		N/A		2.0(Inst. Min.)	
FCB (col/100 ml)								
(Apr-Sept)	200	400	N/A	N/A	200	400	200	400
(Oct-Mar)	1000	2000	N/A	N/A	1000	2000	1000	2000

# DRAFT

Parameter	Water Quality-Based		Technology-Based/BPJ		Previous Permit		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
TRC (Inst. Max)(design flow 3.1 mgd only)	N/A		< 0.1 mg/l		<0.1 mg/l		<0.1 mg/l	
Total Dissolved Solids	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Chlorides	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Total Phosphorus	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Nitrite + Nitrate Nitrogen	N/A	N/A	Report	Report	N/A	N/A	Report	Report
pH	6.0-9.0 s.u.		6.0-9.0 s.u.		6-9 s.u.		6.0-9.0 s.u.	

\* These effluent limitations for BOD5 and CBOD5 are based 40 CFR 133.102.

Parameter	Water Quality or Technology	Justification
CBOD5	Technology	40 CFR 133.102
BOD5	Technology	40 CFR 133.102
TSS <sup>1</sup>	Technology	40 CFR 133.102
NH3-N <sup>2</sup>	Water Quality	Section 2.512 of Regulation No. 2/ MultiSMP Model dated May 1, 2008
DO <sup>3</sup>	Water Quality	Section 2.505 of Regulation No. 2
Fecal Coliform Bacteria	Water Quality	Section 2.507 of Regulation No. 2
TRC <sup>4</sup>	Technology	Previous permit, 40 CFR 122.44 (l)(2)(i)
Total Dissolved Solids <sup>5</sup>	BPJ/Technology	303(d) list
Chlorides <sup>5</sup>	BPJ/Technology	303(d) list
Phosphorus <sup>6</sup>	BPJ/Technology	Appendix D of the 2000 Continuous Planning Process
Nitrite + Nitrate Nitrogen <sup>6</sup>	BPJ/Technology	Appendix D of the 2000 Continuous Planning Process
pH <sup>7</sup>	Water Quality	Section 2.504 of Regulation No. 2

## 1 TSS

The effluent limitations of 90/135 mg/l (Monthly Avg/7-Day Avg) for Outfall 001(design flow of 3.1 MGD) are continued for the previous permit. Since the existing aerated lagoon system will be modified to an activated sludge system and two

secondary clarifiers will be added, the effluent limitations of 30/45 mg/l (Monthly Avg/7-Day Avg) are included for Outfall 001(design flow of 4.0 MGD).

## 2 NH3-N

The Daily Maximum Effluent Limitations for NH3-N have been slightly revised in accordance with the following equation:

Daily Maximum limits = Monthly average limits X 1.5

## 3 Dissolved Oxygen

The Instantaneous Minimum effluent limitation for Dissolved Oxygen of 2 mg/l has been included to ensure that the in-stream Dissolved Oxygen does not fall below established criteria based on APCEC Regulation No. 2 Section 2.505.

It is the best engineering judgment of the permit writer that the existing facility is capable of meeting the proposed limit. No schedule of compliance is included. The final limitation must be met on the effective date of the permit.

## 4 TRC

The effluent limitations of 0.1 mg/l are continued for the previous permit for Outfall 001(design flow of 3.1 MGD). The effluent limitations for TRC are not included for Outfall 001 (design flow of 4.0 MGD) since the chlorine disinfection unit used in 3.1 MGD facility will be replaced by an UV disinfection unit when the 4.0 MGD plant is completed.

## 5 Total Dissolved Solids and Chlorides

In order to ensure that monitoring information is available to assess further water quality requirements for this facility, and to assist in identifying pollutant sources in this waterbody, a requirement for monitoring and reporting of these parameters has been included.

## 6 Phosphorus and Nitrite and Nitrate

In order to establish a data base of point source loadings of nutrients to waters of the state of Arkansas, a requirement for monitoring and reporting of these parameters have been included based on 2000 CPP, Appendix D.

## 7 pH

The effluent limitations for this parameter have been revised from 6-9 s.u. to 6.0-9.0 s.u. to be consistent with Reg.2.504 of Regulation No. 2.

### a. Anti-backsliding

The draft permit is consistent with the requirements to meet Anti-backsliding provisions of the Clean Water Act (CWA), Section 402(o) [40 CFR 122.44(l)]. The final effluent limitations for reissuance permits must be as stringent as those in the previous permit, unless the less stringent limitations can be justified using exceptions listed in 40 CFR 122.44 (l)(2)(i).

The draft permit maintains the requirements of the previous permit with the following exceptions:

1. Mass limitations for CBOD5, BOD5, and NH3-N for Outfall 001(design flow of 4.0 MGD) are less stringent than mass limitations imposed in the previous permit. This increase in mass limitations does not constitute backsliding based on 40 CFR 122.44 (l)(2)(i)(B)(1) - information is available which was not available at the time of permit issuance (the design flow of the facility will increase from 3.1 MGD to 4.0 MGD) & 40 CFR 122.45(f).
2. The effluent limitations for TRC are not included at Outfall 001(design flow of 4.0 MGD). This change does not constitute backsliding based on 40 CFR 122.44 (l)(2)(i)(B)(1) - information is available which was not available at the time of permit issuance (there is no need to continue the effluent limitations for TRC after chlorination unit is replaced by UV disinfection unit).
3. A sample type for CBOD5, BOD5, TSS, and NH3-N has been changed from 12-hr composite to 24-hr composite. This requirement is considered to be more stringent than recommended 6-hr composite sample type for self-monitoring of discharges within the flow of 1.00 to 4.99 MGD. This change does not constitute backsliding based on 40 CFR 122.44 (l)(2)(i)(B)(2) – technical mistake was made in the previous permit.

### b. Limits Calculations

#### i. Mass limits:

The calculation of the loadings (lbs per day) uses a design flow of 3.1 MGD and 4.0 MGD and the following equation:

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

ii. Daily Maximum Limits:

Daily Maximum limits = Monthly average limits X 1.5

iii. Ammonia-Nitrogen (NH<sub>3</sub>-N):

The water quality effluent limitations for Ammonia are based either on DO-based effluent limits or on toxicity-based standards, whichever are more stringent. The toxicity-based effluent limitations are based on Chapter 5, Section 2.512 of APCEC Regulation No. 2 and an ADEQ internal memo dated March 28, 2005. The following formula has been used to calculate toxicity based Ammonia limits:

$$C_d = (IWC(Q_d + Q_b) - C_b Q_b) / Q_d,$$

Where:

C<sub>d</sub> = effluent limit concentration

IWC = Ammonia toxicity standard for Ecoregion

Q<sub>d</sub> = design flow

Q<sub>b</sub> = Critical flow of the receiving stream. This flow is 25 percent of the 7-day, 10-year low-flow (7Q<sub>10</sub>) for the receiving stream.

C<sub>b</sub> = background concentration

c. **208 Plan (Water Quality Management Plan)**

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan has been revised to revise the design flow, change the effluent limitations for Total Suspended Solids, and add the effluent limitations for Dissolved Oxygen:

May-October: CBOD<sub>5</sub>/TSS/NH<sub>3</sub>-N/DO = 25/30/5/2 mg/l

November-March: BOD<sub>5</sub>/TSS/DO = 30/30/2 mg/l

Design flow (Q): 4.0 MGD

Background Flow of the receiving stream (7Q<sub>10</sub>): 700 cfs

d. **Toxics Pollutants**

i. Post Third Round Policy and Strategy

Section 101 of the Clean Water Act (CWA) states that "...it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited...". To insure that the

CWA's prohibitions on toxic discharges are met, EPA has issued a "Policy for the Development of Water Quality-Based Permit Limitations by Toxic Pollutants"(49 FR 9016-9019,3/9/84). In support of the national policy, Region 6 adopted the "Policy for post Third Round Permitting" and the "Post Third Round Permit Implementation Strategy" on October 1, 1992. The Regional policy and strategy are designed to insure that no source will be allowed to discharge any wastewater which (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical State water quality standard resulting in non-conformance with the provisions of 40 CFR Part 122.44(d); (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation which threatens human health.

ii. Implementation

The State of Arkansas is currently implementing EPA's Post Third-Round Policy in conformance with the EPA Regional strategy. The 5-year discharge permits contain technology-based effluent limitations reflecting the best controls available. Where these technology-based permit limits do not protect water quality or the designated uses, or where there are no applicable technology-based limits, additional water quality-based effluent limitations and/or conditions are included in the discharge permits. State narrative and numerical water quality standards from Regulation No. 2 are used in conjunction with EPA criteria and other available toxicity information to determine the adequacy of technology-based permit limits and the need for additional water quality-based controls.

iii. Priority Pollutant Scan (PPS)

In accordance with the regional policy ADEQ has reviewed and evaluated the effluent in evaluating the potential toxicity of each analyzed pollutant:

- (a) The results were evaluated and compared to EPA's Minimum Quantification Levels (MQLs) to determine the potential presence of a respective toxic pollutant. Those pollutants which are greater than or equal to the MQLs are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- (b) Those pollutants with one datum shown as "non-detect" (ND), providing the level of detection is equal to or lower than MQL are determined to be not potentially present in the effluent and eliminated from further evaluation.
- (c) Those pollutants with a detectable value even if below the MQL are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.

# DRAFT

- (d) For those pollutants with multiple data values and all values are determined to be non-detect, therefore no further evaluation is necessary. However, where data set includes some detectable concentrations and some values as ND, one-half of the detection level is used for those values below the level of detection to calculate the geometric mean of the data set.

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards, Reg. No. 2 and with the aquatic toxicity, human health, and drinking water criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)". The following expression was used to calculate the pollutant instream waste concentration(IWC):

$$IWC = ((C_e \times Q_e) + (C_b \times Q_b)) / (Q_e + Q_b)$$

where:

IWC = instream concentration of pollutant after mixing with receiving stream ( $\mu\text{g/l}$ )

$C_e$  = pollutant concentration in effluent ( $\mu\text{g/l}$ )

$Q_e$  = effluent flow of facility (cfs)

$C_b$  = background concentration of pollutant in receiving stream ( $\mu\text{g/l}$ )

$Q_b$  = background flow of receiving stream (cfs)

The following values were used in the IWC calculations:

$C_e$  = varies with pollutant. A single value from the Priority Pollutant Screen (PPS) submitted by the permittee as part of the discharge permit application or the geometric mean of a group of data points (less than 20 data points) is multiplied by a factor of 2.13. This factor is based on EPA's Region VI procedure (See attachment IV of Continuing Planning Process(CPP)) to extrapolate limited data sets to better evaluate the potential toxicity for higher effluent concentrations to exceed water quality standards. This procedure employs a statistical approach which yields an estimate of a selected upper percentile value (the 95th percentile) of an effluent data set which would be expected to exceed 95% of effluent concentrations in a discharge. If 20 or more data points during the last two years are available, do not multiply by 2.13, but instead use the maximum reported values.

$Q_e$  = 4.0 MGD = 6.2 cfs

$C_b$  = varies, based on the highest recorded value at station ARK0038, Arkansas River near Ft. Smith in  $\mu\text{g/l}$



$Q_b =$  (See below):

## I. Aquatic Toxicity

Chronic Toxicity: Flow = 175 cfs, for comparison with chronic aquatic toxicity. This flow is 25 percent of the 7-day, 10-year low-flow (7Q10) for the receiving stream. The 7Q10 of 700 cfs is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.

Acute Toxicity: Flow = 42 cfs, for comparison with acute aquatic toxicity. This flow is 6 percent of the 7Q10 for the receiving stream.

## II. Bioaccumulation

Flow = 1353 cfs, for comparison with bioaccumulation criteria. This flow is the harmonic mean of the receiving stream which is based on EPA's STORET (Storage and retrieval), Water Quality Data Base System, utilizing ADEQ accumulated data for Station ARK0038.

## III. Drinking Water

Flow = 700 cfs, for comparison with drinking water criteria. This flow is the 7Q10 for the receiving stream.

The following values were used to determine limits for the pollutants:

Hardness = 125 mg/l, based on attachment VI of CPP.

TSS = 12 mg/l, based on attachment V of CPP

pH = 7.45 s.u., based on compliance data from Arkansas Water Quality Inventory Report "305(b)" for station ARK0038.

### iv. Water Quality Standards for Metals and Cyanide

Standards for Chromium (VI), Mercury, Selenium, and Cyanide are expressed as a function of the pollutant's water-effect ratio (WER), while standards for cadmium, chromium (III), copper, lead, nickel, silver, and zinc are expressed as a function of the pollutant's water-effect ratio, and as a function of hardness.

The Water-effect ratio (WER) is assigned a value of 1.0 unless scientifically defensible study clearly demonstrates that a value less than 1.0 is necessary or a value greater than 1.0 is sufficient to fully protect the designated uses of the receiving stream from the toxic effects of the pollutant.

The WER approach compares bioavailability and toxicity of a specific pollutant in receiving water and in laboratory test water. It involves running toxicity tests for at least two species, measuring LC50 for the pollutant using the local receiving water collected from the site where the criterion is being implemented, and laboratory toxicity testing water made comparable to the site water in terms of chemical hardness. The ratio between site water and lab water LC50 is used to adjust the national acute and chronic criteria to site specific values.

v. Conversion of Dissolved Metals Criteria for Aquatic Life to Total Recoverable Metal

Metals criteria established in APCEC Regulation No. 2, Section 2.508 for aquatic life protection are based on dissolved metals concentrations and hardness values. However, Federal Regulations cited at 40 CFR Part 122.45(c) require that effluent limitations for metals in discharge permits be expressed as total recoverable based on Attachment V of CPP. Therefore a dissolved to the total recoverable metal conversion must be implemented. This involves determining a linear partition coefficient for the metal of concern and using this coefficient to determine the fraction of metal dissolved, so that the dissolved metal ambient criteria may be translated to a total effluent limit. The formula for converting dissolved metals to total recoverable metals for streams and lakes are provided in Attachment V of CPP and Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.

vi. Comparison of the submitted information with the water quality standards and criteria

The following pollutants were determined to be present in the effluent for each pollutant as reported by the permittee.

Pollutant	Concentration Reported, µg/l	MQL, µg/l
Copper, Total Recoverable	4.4*	0.5
Lead, Total Recoverable	2.7*	0.5
Mercury, Total Recoverable	0.0097*	0.005
Nickel, Total Recoverable	3.1*	0.5
Silver, Total Recoverable	0.67*	0.5
Zinc, Total Recoverable	41*	20
Phenols, Total Recoverable	10**	5
Delta- BHC	0.044*	0.05
Alpha-endosulphan	ND (0.014)*****	0.01

- \* single data point submitted in PPS faxed on September 26, 2008
- \*\* geometric mean of three data points: 0.023 mg/l(October 2007), 0.016 mg/l (January 2008), and ND(0.005 mg/l –June 2008)
- \*\*\* Since the achieved detection level was above the required MQL, the detection level was used as actual concentration

However, ADEQ has determined from the information submitted by the permittee that no water quality standards or Gold Book criteria are exceeded. Therefore no permit action is necessary to maintain these standards or criteria (See Attachment 1.)

#### **14. TOTAL RESIDUAL CHLORINE (TRC) REQUIREMENTS.**

##### Outfall 001(design flow of 3.1 MGD)

The effluent shall contain NO MEASURABLE TRC at any time. NO MEASURABLE will be defined as no detectable concentration of TRC as determined by any approved method established in 40 CFR Part 136 as less than 0.1 mg/l . Thus, the “no measurable TRC concentration” for chlorine becomes the permit limit. The effluent limitation for TRC is the instantaneous maximum and cannot be averaged for reporting purposes. TRC shall be measured with fifteen (15) minutes of sampling. This effluent limitation is continued from the previous permit.

##### Outfall 001(design flow of 4.0 MGD)

Since chlorination disinfection will be replaced by UV disinfection, there is no final effluent limitation included at Outfall 001(design flow of 4.0 MGD).

#### **15. WHOLE EFFLUENT TOXICITY.**

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent toxicity (WET) testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992.

# DRAFT

Whole effluent toxicity testing of the effluent is thereby required as a condition of this permit to assess potential toxicity. The whole effluent toxicity testing procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS	FREQUENCY
Acute WET	Once/quarter

Requirements for measurement frequency are based on appendix D of CPP.

Since 7Q10 is greater than 100 cfs (ft<sup>3</sup>/sec) and dilution ratio is greater than 100:1, acute WET testing requirements will be included in the permit.

The calculations for dilution used for the acute WET testing are as follows:

$$\text{Critical Dilution (CD)} = (Q_d / (Q_d + Q_b)) \times 100$$

Outfall 001(design flow of 3.1 MGD):

$$\begin{aligned} Q_d &= \text{Design Flow} = 3.1 \text{ MGD} = 4.8 \text{ cfs} \\ 7Q_{10} &= 700 \text{ cfs} \\ Q_b &= \text{Background flow} = 0.1 \times (0.25) \times 7Q_{10} = 17.5 \text{ cfs} \\ \text{CD} &= ((4.8) / (4.8 + 17.5)) \times 100 = 22 \% \end{aligned}$$

Outfall 001(design flow of 4.0 MGD):

$$\begin{aligned} Q_d &= \text{Design Flow} = 4.0 \text{ MGD} = 6.2 \text{ cfs} \\ 7Q_{10} &= 700 \text{ cfs} \\ Q_b &= \text{Background flow} = 0.1 \times (0.25) \times 7Q_{10} = 17.5 \text{ cfs} \\ \text{CD} &= ((6.2) / (6.2 + 17.5)) \times 100 = 26 \% \end{aligned}$$

Toxicity tests shall be performed in accordance with protocols described in "Methods for Measuring the Acute Toxicity of Effluent to Freshwater and Marine Organisms", EPA/600/4-90/027. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests.

For Outfall 001(design flow of 3.1 MGD):

These additional effluent concentrations are **9%, 12%, 17%, 22%, and 29%** (See **Attachment I** of CPP). The low-flow effluent concentration (critical dilution) is defined as **22%** effluent.

For Outfall 001(design flow of 4.0 MGD):

These additional effluent concentrations are **11%, 15%, 20%, 26%, and 35%** (See **Attachment I** of CPP). The low-flow effluent concentration (critical dilution) is defined as **26%** effluent.

# DRAFT

The requirement for acute WET tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species are representative of organisms indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The WET testing frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen, conductivity, and alkalinity shall be reported according to EPA/600/4-90/027 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further WET testing studies, Toxicity Reduction Evaluation (TRE) and/or effluent limits if WET testing data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

### Administrative Records

The following information summarized toxicity test submitted by the permittee during the term of the current permit at outfall **001**:

### **WHOLE EFFLUENT TOXICITY TESTING FREQUENCY RECOMMENDATION AND RATIONALE FOR ADDITIONAL REQUIREMENTS**

Permit Number: **AR0021482**      AFIN: **17-00062**  
Facility Name: **City of Van Buren - Main Plant**  
Outfall Number: **001**  
Previous Critical Dilution: **22%**      Proposed Critical Dilution: **26%**  
Date of Review: **8/19/08**      Name of Reviewer: **Barnett**

Number of tests performed during previous 5 years by species:

***Pimephales promelas* (Fathead minnow): 18**

***Daphnia pulex* (water flea): 18**

Failed test dates during previous 5 years by species:

***Pimephales promelas* (Fathead minnow):**

Lethal

None

***Daphnia pulex* (water flea):**

Lethal

# DRAFT

Page 20 of Fact Sheet  
Permit Number: AR0021482

12/04

Previous TRE activities: None

Frequency recommendation by species:

***Pimephales promelas* (Fathead minnow): four/year**

***Daphnia pulex* (water flea): four/year**

Additional requirements (including WET Limits) rationale/comments concerning permitting:

Rationale: According to the EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies: "All major dischargers, and those minor dischargers specifically identified by EPA or the State permitting authority (based on available information on a case-by case basis) as posing a significant unaddressed toxic risk, will be required to perform Whole Effluent Toxicity testing at a frequency of once per quarter for the vertebrate and invertebrate tests species for the first year of a new or reissued permit."

## **Reasonable Potential Calculation**

# DRAFT

Facility Name City of Van Buren - Main Plant  
 NPDES Permit Number AR0021482 Outfall Number 001  
 Proposed Critical Dilution\* 26

**\*Critical Dilution in draft permit, do not use % sign.**  
 Enter data in yellow shaded cells only. Fifty percent should be entered as 50, not 50%.

**Test Data**

Date (mm/yyyy)	VERTEBRATE				INVERTEBRATE			
	Lethal NOEC	Sublethal NOEC	Lethal TU	Sublethal TU	Lethal NOEC	Sublethal NOEC	Lethal TU	Sublethal TU
Mar-04	29		3.45		29		3.45	
Jun-04	29		3.45		29		3.45	
Sep-04	29		3.45		29		3.45	
Dec-04	29		3.45		17		5.88	
Mar-05	29		3.45		29		3.45	
Jun-05	29		3.45		29		3.45	
Sep-05	29		3.45		29		3.45	
Dec-05	29		3.45		29		3.45	
Mar-06	29		3.45		29		3.45	
Jun-06	29		3.45		29		3.45	
Sep-06	29		3.45		29		3.45	
Dec-06	29		3.45		29		3.45	
Mar-07	29		3.45		29		3.45	
Jun-07	29		3.45		29		3.45	
Sep-07	29		3.45		29		3.45	
Dec-07	29		3.45		29		3.45	
Mar-08	29		3.45		29		3.45	
Jun-08	29		3.45		29		3.45	

	29	0	3.45	#DIV/0!	17	0	5.88	#DIV/0!
Count	18	0			18	0		
Mean	29.000	#DIV/0!			28.333	#DIV/0!		
Std. Dev.	0.000	#DIV/0!			2.828	#DIV/0!		
CV	0	0.6			0.1	0.6		
RPMF	#N/A	6.2			1.1	6.2		
		3.846	Reasonable Potential Acceptance Criteria					
Vertebrate Lethal	#N/A	#N/A						
Invertebrate Lethal	1.682	No Reasonable Potential exists. Permit requires WET monitoring, but no WET limit.						

## 16. SAMPLE TYPE AND FREQUENCY.

Regulations require permits to establish monitoring requirements to yield data representative of the monitored activity [40 CFR Part 122.48(b)] and to ensure compliance with permit limitations [40 CFR Part 122.44(i)(1)].

The requirements for sampling frequencies for all parameters except Total Dissolved Solids, Total Phosphorus, and Nitrite + Nitrate Nitrogen have been based on recommended frequencies for self-monitoring of discharges within the flow of 1.0 to 4.99 MGD.

The requirements for sample type for Fecal Coliform Bacteria, Total Residual Chlorine (Outfall 001 with design flow of 3.1 MGD), and pH have been based on the previous permit.

# DRAFT

The requirements for sample frequency for Total Residual Chlorine (Outfall 001 with design flow of 3.1 MGD) have been based on the previous permit.

The requirements for sample type for Carbonaceous Biochemical Oxygen Demand (5 day), Biochemical Oxygen Demand (5 day), Total Suspended Solids, and Ammonia Nitrogen have been changed from 12-hr composite to 24-hr composite in response to a request from the permittee. It is the best engineering judgment of the permit writer that this new requirement is more stringent than typically required for the major municipal facility with the design capacity of 1.0 to 4.99 MGD, therefore, no anti-backsliding regulations are being violated.

The requirements for sample type and sampling frequencies for Total Phosphorus, and Nitrite + Nitrate Nitrogen, Chlorides, and Total Dissolved Solids have been based on CPP and the best engineering judgment of the permit writer.

Parameter	Previous Permit		Draft Permit	
	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
Flow	once/day	totalizing meter	once/day	totalizing meter
CBOD5				
(May-Oct)	once/week	12-hr composite	three/week	24-hr composite
BOD5				
(Nov-Apr)	once/week	12-hr composite	three/week	24-hr composite
TSS	once/week	12-hr composite	three/week	24-hr composite
NH3-N				
(May-Oct)	once/week	12-hr composite	three/week	24-hr composite
Dissolved Oxygen	N/A	N/A	three/week	Grab
FCB				
(Apr-Sept)	once/week	grab	three/week	grab
(Oct-Mar)	once/week	grab	three/week	grab
TRC*	once/weekday	grab	once/weekday	grab
TDS	N/A	N/A	once/month	grab
Chlorides	N/A	N/A	once/month	grab
Phosphorus, Total	N/A	N/A	three/week	grab
Nitrite + Nitrate	N/A	N/A	three/week	grab



# DRAFT

Parameter	Previous Permit		Draft Permit	
	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
pH	once/week	grab	three/week	grab
AcuteWET Testing	Once/quarter	24-hr composite	once/quarter	24-hr composite

\* only Outfall 001(design flow of 3.1 MGD)

## 17. STORMWATER POLLUTION PREVENTION PLAN REQUIREMENTS.

In lieu of storm water pollution prevention plan requirements, the permittee submitted a “No exposure certification for exclusion from NPDES Storm water.” This certification was approved by the Department on September 16, 2008 and tracking permit No. ARR00413 was assigned to this permittee.

## 18. PERMIT COMPLIANCE.

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

1. Final Limits:

Compliance is required on the effective date of the permit.

2. During the month of October the permittee shall submit an updated pretreatment program status report to the ADEQ containing the information described in Condition 12. d. of Part II of the permit.
3. The permittee shall submit annual reports including the biosolids and soil analyses conducted under Condition 11.b (1) and 11.b (2) of the permit prior to May 1.

## 19. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis and report the results monthly. The monitoring results will be available to the public.

# DRAFT

Permit Number: AR0021482

## AUTHORIZATION TO DISCHARGE WASTEWATER UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. § 1251 et seq.),

The applicant's mailing address is:

City of Van Buren - Main Plant  
P.O. Box 1269  
Van Buren, AR 72957

The facility address is:

City of Van Buren - Main Plant  
1401 Port Road  
Van Buren, AR 72956

is authorized to discharge from a facility located as follows: approximately 1/2 mile south of I-540 overpass and south of Highway 59 South in Crawford County, Arkansas.

Latitude: 35° 25' 9.04"; Longitude: 94° 20' 19.35"

to receiving waters named:

Arkansas River in Segment 3H of the Arkansas River Basin.

The outfall is located at the following coordinates:

Outfall 001: Latitude: 35° 25' 3.27"; Longitude: 94° 20' 27.18"

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, III, and IV hereof.

Issue Date:

Effective Date:

Expiration Date:

---

Steven L. Drown  
Chief, Water Division  
Arkansas Department of Environmental Quality

## PART I PERMIT REQUIREMENTS

### SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001(design flow of 3.1 MGD)<sup>1</sup> - treated municipal wastewater.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001(design flow of 3.1 MGD). Such discharges shall be limited and monitored by the permittee as specified below from a treatment system consisting of a screening unit, 4-cell aerated lagoon system with chlorine disinfection and dechlorination with a design flow of 3.1 MGD.

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)					
(May-Oct)	646.4	25	40	three/week	24-hr composite
Biochemical Oxygen Demand (BOD5)					
(Nov-Apr)	775.6	30	45	three/week	24-hr composite
Total Suspended Solids (TSS)	2326.9	90	135	three/week	24-hr composite
Ammonia Nitrogen (NH3-N)					
(May-Oct)	129.3	5	7.5	three/week	24-hr composite
Dissolved Oxygen <sup>2</sup>	N/A	2.0, (Inst. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Residual Chlorine (TRC) <sup>3</sup>	N/A	<0.1 mg/l (Inst. Max.)		once/weekday	grab
Total Dissolved Solids	Report	Report	Report	once/month	grab
Chlorides	Report	Report	Report	once/month	grab
Total Phosphorus	Report	Report	Report	three/week	grab
Nitrite + Nitrate Nitrogen	Report	Report	Report	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab

# DRAFT

Permit Number: AR0021482

Page 2 of Part IA

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass(lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample type
		Monthly Avg.	Monthly Avg.		
Acute WET Testing <sup>4</sup>	N/A	N/A	N/A	once/quarter	24-hr composite
<b><u>Pimephales promelas (Acute)</u></b> <sup>4</sup> Pass/Fail Lethality (48-Hr NOEC) <b>TEM6C</b> Survival (48-Hr NOEC) <b>TOM6C</b> Coefficient of Variation (48-Hr NOEC) <b>TQM6C</b>		<u>48-hr Minimum</u> Report (Pass=0/Fail=1) Report % Report %		once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite
<b><u>Daphnia pulex (Acute)</u></b> <sup>4</sup> Pass/Fail Lethality (48-Hr NOEC) <b>TEM3D</b> Survival (48-Hr NOEC) <b>TOM3D</b> Coefficient of Variation (48-Hr NOEC) <b>TQM3D</b>		<u>48-hr Minimum</u> Report (Pass=0/Fail=1) Report % Report %		once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite

1 See Condition No. 9 of Part II (Transition). Mass effluent limitations have been calculated using a flow of 3.1 MGD.

2 See item #27(b) of Part IV (Dissolved Oxygen).

3 See Condition No. 10 of Part II (TRC Condition).

4 See Condition No. 13 of Part II (WET Testing Condition).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken from the following location – flow measurement/sampling building located at the following coordinates: Latitude: 35° 25' 03.6; Longitude: 94° 20' 16.8"

## PART I PERMIT REQUIREMENTS

### SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001(design flow of 4.0 MGD)<sup>1</sup> - treated municipal wastewater.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001(design flow of 4.0 MGD). Such discharges shall be limited and monitored by the permittee as specified below from a treatment system consisting of a screening unit, activated sludge system, final clarifiers, and UV disinfection with a design flow of 4.0 MGD.

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)					
(May-Oct)	834	25	40	three/week	24-hr composite
Biochemical Oxygen Demand (BOD5)					
(Nov-Apr)	1000.8	30	45	three/week	24-hr composite
Total Suspended Solids (TSS)	1000.8	30	45	three/week	24-hr composite
Ammonia Nitrogen (NH3-N)					
(May-Oct)	166.8	5	7.5	three/week	24-hr composite
Dissolved Oxygen <sup>2</sup>	N/A	2.0, (Inst. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Dissolved Solids	Report	Report	Report	once/month	grab
Chlorides	Report	Report	Report	once/month	grab
Total Phosphorus	Report	Report	Report	three/week	grab
Nitrite + Nitrate Nitrogen	Report	Report	Report	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass(lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample type
		Monthly Avg.	Monthly Avg.		
Acute WET Testing <sup>3</sup>	N/A	N/A	N/A	once/quarter	24-hr composite
<b><u>Pimephales promelas (Acute)</u></b> <sup>3</sup> Pass/Fail Lethality (48-Hr NOEC) <b>TEM6C</b> Survival (48-Hr NOEC) <b>TOM6C</b> Coefficient of Variation (48-Hr NOEC) <b>TQM6C</b>		<u>48-hr Minimum</u> Report (Pass=0/Fail=1) Report % Report %		once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite
<b><u>Daphnia pulex (Acute)</u></b> <sup>3</sup> Pass/Fail Lethality (48-Hr NOEC) <b>TEM3D</b> Survival (48-Hr NOEC) <b>TOM3D</b> Coefficient of Variation (48-Hr NOEC) <b>TQM3D</b>		<u>48-hr Minimum</u> Report (Pass=0/Fail=1) Report % Report %		once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite

- 1 See Condition No. 9 of Part II (Transition). Mass effluent limitations have been calculated using a flow of 4.0 MGD.
- 2 See item #27(b) of Part IV (Dissolved Oxygen).
- 3 See Condition No. 13 of Part II (WET Testing Condition).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken from the following location – after the final treatment unit at the following coordinates: Latitude: 35° 25' 02.3"; Longitude: 94° 20' 16.3"

## SECTION B. PERMIT COMPLIANCE

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

1. Final Limits:

Compliance is required on the effective date of the permit.

2. During the month of October the permittee shall submit an updated pretreatment program status report to the ADEQ containing the information described in Condition 12. d. of Part II.
3. The permittee shall submit annual reports including the biosolids and soil analyses conducted under Condition 11.b (1) and 11.b (2) prior to May 1.

## PART II OTHER CONDITIONS

1. The operator of this wastewater treatment facility shall be licensed as Class III by the State of Arkansas in accordance with Act 211 of 1971, Act 1103 of 1991, Act 556 of 1993, and APCEC Regulation No. 3, as amended.
2. For publicly owned treatment works, the 30-day average percent removal for Biochemical Oxygen Demand (BOD5) and Carbonaceous Biochemical Oxygen Demand (CBOD5) shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR Part 133.102, as adopted by reference in APCEC Regulation No. 6 (this condition applies only to the existing wastewater treatment facility with a design flow of 3.1 MGD).
3. For publicly owned treatment works, the 30-day average percent removal for Biochemical Oxygen Demand (BOD5) and Carbonaceous Biochemical Oxygen Demand (CBOD5) and Total Suspended Solids shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR Part 133.102, as adopted by reference in APCEC Regulation No. 6 (this condition applies only to the modified wastewater treatment plant with a design flow of 4.0 MGD).
4. Produced sludge shall be disposed of by land application only when meeting the following criteria:
  - a. Sewage sludge from treatment works treating domestic sewage (TWTDS) must meet the applicable provisions of 40 CFR Part 503; and
  - b. The sewage sludge has not been classified as a hazardous waste under state or federal regulations.
5. The permittee shall give at least 120 days prior notice to the Director of any change planned in the permittee's sludge disposal practice or land use applications, including types of crops grown (if applicable).
6. The permittee shall report all overflows with the Discharge Monitoring Report (DMR) submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: the date, time, duration, location, estimated volume, and cause of overflow; observed environmental impacts from the overflow; action taken to address the overflow; and ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary). All overflows which endanger health or the environment shall be orally reported to this department (Enforcement Section of the Water Division), within 24 hours from the time the permittee becomes aware of the circumstance. A written report of overflows which endanger health or the environment, shall be provided within 5 days of the time the permittee becomes aware of the circumstance.



7. In accordance with 40 CFR Parts 122.62 (a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.

## 8. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the Permits Section of the Water Division of the ADEQ for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or acceptable to the Director; and
- All associated devices are installed, calibrated, and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

## 9. Transition Period:

The permittee has proposed to modify the existing wastewater plant which will increase the design flow from 3.1 MGD to 4.0 MGD.

- a. Beginning on the effective date of the permit, the permittee must submit a Discharge Monitoring Report (DMR) for each permitted design flow (i.e., 3.1 MGD and 4.0 MGD) on a monthly basis. The DMR for the 4.0 MGD design flow can be marked and submitted as "No Discharge", until such time as the modified treatment system is fully operational. The permittee must continue to submit two (2) monthly DMRs until the report required in Part II.9.b below is received.

# DRAFT

Permit Number: AR0021482  
Page 3 of Part II

- b. The permittee must notify the ADEQ when the modified treatment system is complete and no later than 30 days after the discharge at the new design flow has begun.

## 10. Total Residual Chlorine (applies to Outfall 001(design flow of 3.1 MGD) only):

If TRC test results are less than Detection Level Achieved (DL), a value of zero (0) may be used for the Discharge Monitoring Report (DMR) calculations and reporting requirements.

Total residual chlorine (TRC) in the effluent composite sample shall be measured and reported both at the time of sample termination and at the time of toxicity test initiation. The permittee shall ensure that the effluent composite used in toxicity testing is representative of normal facility residual chlorine discharge concentration.

## 11. Additional Conditions for Land Application of Municipal Wastewater Biosolids

### a. GENERAL REQUIREMENTS:

- (1) Only biosolids which are not classified as a hazardous waste under state or federal regulations may be land applied.
- (2) Plant Available Nitrogen (PAN) will not be applied at a rate exceeding the annual nitrogen uptake of the crop. At no time will the nitrogen application rate (PAN/acre-year) be allowed to exceed the site specific rate approved by the Department.
- (3) Biosolids with Polychlorinated Biphenyls (PCB's) concentrations equal or greater than 50 mg/kg (dry basis) will not be land applied at any time.
- (4) CEILING CONCENTRATIONS (milligrams per kilogram, dry weight basis): If the biosolids to be land applied exceed any of the pollutant concentrations listed in **Table 1** below, the biosolids shall not be land applied.

<b>TABLE 1</b>	
<b>Element</b>	<b>Concentration (mg/kg)</b>
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4,300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7,500

- (5) **POLLUTANTS LIMITS:** When bulk biosolids are applied to agricultural land, forest, a public contact site, or reclamation site, the permittee shall not exceed the Cumulative Pollutant Loading Rate values listed in **Table 2**, or the Pollutant Concentration values listed in **Table 3**.

<b>TABLE 2</b>		
<b>Element</b>	<b>Cumulative Pollutant Loading Rate</b>	
	<b>Kg/ha</b>	<b>lbs/ac</b>
Arsenic	41	37
Cadmium	39	35
Chromium	3000	2677
Copper	1,500	1,350
Lead	300	270
Mercury	17	15
Nickel	420	378
Selenium	100	90
Zinc	2,800	2,520

<b><u>Element</u></b>	<b>Monthly Average Concentration (mg/kg)</b>
<b>Arsenic</b>	41
Cadmium	39
Chromium	1200
Copper	1,500
Lead	300
Mercury	17
Nickel	420
Selenium	36
Zinc	2,800

- (6) The biosolids generator must issue a signed certification stating that the Pathogen Reduction, Vector Attraction Reduction, and Pollutant Concentration Limits have been met. The State requirements on Pathogen Reduction, Vector Attraction Reduction, and Pollutant Concentration Limits are the same as those listed in 40 CFR Part 503. All the above information must be made available to the land-applicator before the biosolids materials are delivered. Concurrently, a signed copy of each certification must be also submitted to the ADEQ Water Division.
- (7) Biosolids can only be stored in accordance with the permit and the approved waste management plan, if provisions are made in the plan for that purpose. The utilization of improvised field storage sites or any other site not approved by the Department is strictly prohibited.
- (8) Transportation of the biosolids must be such that will prevent the attraction, harborage or breeding of insects or rodents. It must not produce conditions harmful to public health, the environment, odors, unsightliness, nuisances, or safety hazards.
- (9) The containers used for the transportation of the biosolids must be of the closed type. Transportation equipment must be leak-proof and kept in a top sanitary condition at all times. Biosolids must be enclosed or covered as to prevent littering, vector attraction, or any other nuisances.
- (10) The permittee will be responsible for assuring that the land owner, of any land application site not owned by the permittee, and the waste applicator, if different from the permittee, abide by the conditions of this permit.

# DRAFT

- (11) Biosolids will be spread evenly over the application area and in no way biosolids will be allowed to enter the waters of the State.
- (12) Biosolids will not be applied to slopes with a gradient greater than 15%; or to soils that are saturated, frozen or covered with snow, during rain, or when precipitation is imminent.
- (13) The permittee will not cause any underground drinking water source to exceed the limitations in 40 CFR Part 257, Appendix I.
- (14) The permittee will not cause or contribute to the taking of life or the destruction or adverse modification of the critical habitat of any known endangered or threatened species of plant, fish or wildlife.
- (15) The permittee will take all necessary measures to reduce obnoxious and offensive odors. Equipment will be maintained and operated to prevent spillage and leakage.
- (16) Disposal of biosolids in a flood plain shall not increase the level of the base flood by one foot or more, to avoid increasing the velocity of the flow downstream of the site, reducing the temporary storage capacity of the flood plain, or increasing the levels of the flood waters.
- (17) Biosolids will not be spread within 50 feet of rock outcrops and property lines; 100 feet of lakes, ponds, springs, streams, wetlands and sinkholes; 200 feet of drinking water wells; 300 feet of occupied buildings and streams classified as an "extraordinary resource water body."
- (18) All new land application sites must have a waste management plan approved by the Department prior to land application of wastewater biosolids. This change normally requires a permit modification.

b. MONITORING AND REPORTING REQUIREMENTS:

The permittee will be responsible for the biosolids analyses, soil analyses, and a reporting schedule that must include the following:

- (1) Biosolids Analysis
  - i. Biosolids samples collected must be representative of the treated biosolids to be land applied. The samples are to be stored in appropriate containers and kept refrigerated or frozen to prevent any change in composition.

# DRAFT

- ii. Quarterly representative samples of the land-applied biosolids will be analyzed and results expressed in dry basis in mg/kg, except as otherwise indicated:

Volatile Solids(%)	Total Kjeldahl Nitrogen
Total Solids(%)	Total Phosphorus
Nitrate +Nitrate Nitrogen	Total Potassium
Ammonia Nitrogen	Arsenic
Cadmium	Copper
Lead	Mercury
Nickel	Selenium
Zinc	pH (SU)

(2) Soils Analysis

Each land application site will be soil tested in the Spring prior to application for the following parameters:

Nitrate-Nitrogen	Potassium
Phosphorus	Magnesium
Arsenic	Cadmium
Copper	Lead
Mercury	Nickel
Selenium	Zinc
pH	
Cation Exchange Capacity (me/100g)	
Salt Content (micro-mhos/cm)	

(3) Reporting

- i. Annual reports will be sent to the Department and to the owner of the land receiving biosolids prior to May 1, which must include the following:

The biosolids and soil analyses conducted under section a. above (including a statement that the analyses were performed in accordance with EPA Document SW-846, "Test Methods for Evaluation of Solid Waste," or other procedures approved by the Director), application dates and locations, volumes of biosolids applied (in dry tons/acre-year and gallons/acre-year of biosolids), methods of disposal, identity of hauler, and type of crop grown, amounts of nitrogen applied, total elements added that year (lbs/acre), total elements applied to date, and copies of soil analyses for each site.

# DRAFT

- ii. The permittee will also maintain copies of the above records for Department personnel review at the biosolids generating facility.

Sludge will be applied at the following land application site:

Field number	New/old	Range	Township	Section	Total Acres	Available Acres	Crop Cover	Loading Rate
1	Old	31	8	6, 7, & 8	200	150	Hay	6 Dry tones /acre

## 12. CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

- a. The permittee shall operate an industrial pretreatment program in accordance with Section 402(b)(8) of the Clean Water Act, the General Pretreatment Regulations (40 CFR Part 403) and the approved POTW pretreatment program submitted by the permittee. The pretreatment program was approved on 10/01/1981 and modified on 03/06/1997. The POTW pretreatment program is hereby incorporated by reference and shall be implemented in a manner consistent with the following requirements:
  - i. Industrial user information shall be updated at a frequency adequate to ensure that all IUs are properly characterized at all times;
  - ii. The frequency and nature of industrial user compliance monitoring activities by the permittee shall be commensurate with the character, consistency and volume of waste. The permittee must inspect and sample the effluent from each Significant Industrial User in accordance with 40 CFR 403.8(f)(2)(v). This is in addition to any industrial self-monitoring activities;
  - iii. The permittee shall enforce and obtain remedies for noncompliance by any industrial users with applicable pretreatment standards and requirements;
  - iv. The permittee shall control through permit, order, or similar means, the contribution to the POTW by each Industrial User to ensure compliance with applicable Pretreatment Standards and Requirements. In the case of Industrial Users identified as significant under 40 CFR 403.3 (v), this control shall be achieved through individual or general control mechanisms, in accordance with 40 CFR 403.8(f)(1)(iii). Both individual and general control mechanisms must be enforceable and contain, at a minimum, the following conditions:

# DRAFT

1. Statement of duration (in no case more than five years);
  2. Statement of non-transferability without, at a minimum, prior notification to the POTW and provision of a copy of the existing control mechanism to the new owner or operator;
  3. Effluent limits, including Best Management Practices, based on applicable general Pretreatment Standards, categorical Pretreatment Standards, local limits, and State and local law;
  4. Self-monitoring, sampling, reporting, notification and recordkeeping requirements, including an identification of the pollutants to be monitored (including the process for seeking a waiver for a pollutant neither present nor expected to be present in the Discharge in accordance with § 403.12(e)(2), or a specific waiver for a pollutant in the case of an individual control mechanism), sampling location, sampling frequency, and sample type, based on the applicable general Pretreatment Standards in 40 CFR 403, categorical Pretreatment Standards, local limits, and State and local law;
  5. Statement of applicable civil and criminal penalties for violation of Pretreatment Standards and requirements, and any applicable compliance schedule. Such schedules may not extend the compliance date beyond federal deadlines; and Requirements to control slug discharges, if determined by the POTW to be necessary.
- v. The permittee shall evaluate, whether each Significant Industrial User needs a plan or other action to control slug discharges, in accordance with 40 CFR 403.8(f)(2)(vi);
  - vi. The permittee shall provide adequate staff, equipment, and support capabilities to carry out all elements of the pretreatment program; and
  - vii. The approved program shall not be modified by the permittee without the prior approval of ADEQ.
- b. The permittee shall establish and enforce specific limits to implement the provisions of 40 CFR Parts 403.5(a) and (b), as required by 40 CFR Part 403.5(c). POTWs may develop Best Management Practices (BMPs) to implement paragraphs 40 CFR 403.5 (c)(1) and (c)(2). Such BMPs shall be considered local limits and Pretreatment Standards. Each POTW with an approved pretreatment program shall continue to develop these limits as necessary and effectively enforce such limits.



# DRAFT

All specific prohibitions or limits developed under this requirement are deemed to be conditions of this permit. The specific prohibitions set out in 40 CFR Part 403.5(b) shall be enforced by the permittee unless modified under this provision.

- c. The permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in 40 CFR 122 Appendix D (NPDES Application Testing Requirements) Table II at least once/year and the toxic pollutants in Table III at least 4 times/year (quarterly). If, based upon information available to the permittee, there is reason to suspect the presence of any toxic or hazardous pollutant listed in Table V, or any other pollutant, known or suspected to adversely affect treatment plant operation, receiving water quality, or solids disposal procedures, analysis for those pollutants shall be performed at least 4 times/year (quarterly) on both the influent and the effluent.

The influent and effluent samples collected shall be composite samples consisting of at least 12 aliquots collected at approximately equal intervals over a representative 24 hour period and composited according to flow. Sampling and analytical procedures shall be in accordance with guidelines established in 40 CFR 136. Where composite samples are inappropriate, due to sampling, holding time, or analytical constraints, at least 4 grab samples, taken at equal intervals over a representative 24 hour period, shall be taken.

- d. The permittee shall prepare annually a list of Industrial Users which during the preceding twelve months were in significant noncompliance with applicable pretreatment requirements. For the purposes of this Part, significant noncompliance shall be determined based upon the more stringent of either criteria established at 40 CFR Part 403.8(f)(2)(viii) [rev. 10/14/05] or criteria established in the approved POTW pretreatment program. This list is to be published annually in the newspaper of general circulation that provides meaningful public notice within the jurisdiction(s) served by the POTW during the month of October.

In addition, during the month of October the permittee shall submit an updated pretreatment program status report to the ADEQ containing the following information:

- i. An updated list of all significant industrial users and identify which Industrial Users are Non-Significant Categorical Industrial Users (NSCIUs) or Middle Tier CIUs. The list must also identify:
  - (a) Industrial Users subject to categorical Pretreatment Standards that are subject to reduced monitoring and reporting requirements under 40 CFR 403.12(e)(2) & (3),
  - (b) Industrial Users subject to the following categorical Pretreatment Standards [Organic Chemicals, Plastics, and Synthetic Fibers (OCPSF) (40 CFR Part 414), Petroleum Refining (40 CFR Part 419), and Pesticide Chemicals (40 CFR Part 455)] and for which the Control Authority has chosen to use the concentration-

# DRAFT

based standards rather than converting them to flow-based mass standards as allowed at 40 CFR 403.6(c)(6).

- (c) Categorical Industrial Users subject to concentration-based standards for which the Control Authority has chosen to convert the concentration-based standards to equivalent mass limits, as allowed at 40 CFR 403.6(c)(5).
- (d) General Control Mechanisms used for similar groups of SIUs along with the substantially similar types of operations and the types of wastes that are the same, for each separate General Control Mechanism, as allowed at 40 CFR 403.8(f)(1)(iii).
- (e) Best Management Practices or Pollution Prevention alternatives required by a categorical Pretreatment Standard or as a local limit requirement that are implemented and documentation to demonstrate compliance, as required at 40 CFR 403 (b), (e) and (h).

(2) For each industrial user listed the following information shall be included:

- (a) Standard Industrial Classification (SIC) and NAICS code and categorical determination;
- (b) Control document status. Whether the user has an effective control document, and the date such document was last issued, reissued, or modified, (indicate which industrial users were added to the system (or newly identified) within the previous 12 months);
- (c) A summary of all monitoring activities performed within the previous 12 months. The following information shall be reported:
  - \* total number of inspections performed;
  - \* total number of sampling visits made;
- (d) Status of compliance with both effluent limitations and reporting requirements. Compliance status shall be defined as follows:
  - \* Compliant (C) - no violations during the previous 12 month period;
  - \* Non-compliant (NC) - one or more violations during the previous 12 months but does not meet the criteria for significantly noncompliant industrial users;
  - \* Significant Noncompliance (SNC) - in accordance with requirements described in d. above; and

# DRAFT

- (e) For significantly noncompliant industrial users, indicate the nature of the violations, the type and number of actions taken (notice of violation, administrative order, criminal or civil suit, fines or penalties collected, etc.) and current compliance status. If ANY industrial user was on a schedule to attain compliance with effluent limits, indicate the date the schedule was issued and the date compliance is to be attained;
  - (3) A list of all significant industrial users whose authorization to discharge was terminated or revoked during the preceding 12 month period and the reason for termination;
  - (4) A report on any interference, pass through, upset or POTW permit violations known or suspected to be caused by industrial contributors and actions taken by the permittee in response;
  - (5) The results of all influent and effluent analyses performed pursuant to paragraph (c) above;
  - (6) A copy of the newspaper publication of the significantly noncompliant industrial users giving the name of the newspaper and the date published;
  - (7) The information requested may be submitted in tabular form as per the example tables provided for your convenience (See Attachment A, B and C); and
  - (8) The monthly average water quality based effluent concentration necessary to meet the state water quality standards as developed in the approved technically based local limits.
- E. The permittee shall provide adequate notice of the following:
- (1) Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Act if it were directly discharging those pollutants; and
  - (2) Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Adequate notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

# DRAFT

## 13. WHOLE EFFLUENT TOXICITY TESTING (48-HOUR ACUTE NOEC FRESHWATER)

### 1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL: **001(design flow of 3.1 MGD)**

CRITICAL DILUTION (%): **22 %**

EFFLUENT DILUTION SERIES (%): **9%, 12%, 17%, 22%, 29%**

COMPOSITE SAMPLE TYPE: Defined at Part I

TEST SPECIES/METHODS: 40 CFR Part 136

APPLICABLE TO FINAL OUTFALL: **001(design flow of 4.0 MGD)**

CRITICAL DILUTION (%): **26 %**

EFFLUENT DILUTION SERIES (%): **11%, 15%, 20%, 26%, 35%**

COMPOSITE SAMPLE TYPE: Defined at Part I

TEST SPECIES/METHODS: 40 CFR Part 136

*Daphnia pulex* acute static renewal 48-hour definitive toxicity test using EPA/600/4-90/027F, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

*Pimephales promelas* (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA/600/4-90/027F, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Acute lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.

- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
- d. Test failure is defined as a demonstration of statistically significant lethal effects to a test species at or below the effluent critical dilution.

## 2. PERSISTENT LETHALITY

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal effects at or below the critical dilution. Significant lethal effects are herein defined as a statistically significant difference at the 95% confidence level between the survival of the appropriate test organism in a specified effluent dilution and the control (0% effluent).

### a. Part I Testing Frequency Other Than Monthly

- i. The permittee shall conduct a total of two (2) additional tests for any species that demonstrates significant lethal effects at or below the critical dilution. The two additional tests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional tests in lieu of routine toxicity testing. The full report shall be prepared for each test required by this section in accordance with procedures outlined in Item 4 of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.
- ii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 6 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.
- iii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall henceforth increase the frequency of testing for this species to once per quarter for the life of the permit.

iv. The provisions of Item 2.a are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in Item 6 of this section when any two of three consecutive monthly toxicity tests exhibit significant lethal effects at or below the critical dilution. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- ii. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: *Daphnia pulex* survival test; and Fathead minnow survival test.
- iii. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for: *Daphnia pulex* survival test; and Fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

b. Statistical Interpretation

For the *Daphnia pulex* survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect

Concentration (NOEC) as described in EPA/600/4-90/027F or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
  - (A) toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
  - (B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.
  
- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
  - (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
  - (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);
  - (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 4 below; and
  - (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the

discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect two flow-weighted composite samples from the outfall(s) listed at Item 1.a above.
- ii. The permittee shall collect a second composite sample for use during the 24-hour renewal of each dilution concentration for both tests. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to 6 degrees Centigrade during collection, shipping, and/or storage.
- iii. The permittee must collect the composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 4 of this section.
- v. MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in Item 1.a above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.



## 4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA/600/4-90/027F, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of Part II.C.7 of this permit. The permittee shall submit full reports to the Department. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for review.
- b. A valid test for each species must be reported on the DMR during each reporting period specified in Part I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of WET testing data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for ADEQ review.
- c. The permittee shall report the following results of each valid toxicity test on DMR for that reporting period in accordance with Part II.D.4 of this permit. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.
  - i. *Pimephales promelas* (Fathead minnow)
    - (A) If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
    - (B) Report the NOEC value for survival, Parameter No. TOM6C.
    - (C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.
  - ii. *Daphnia pulex*
    - (A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.

- (B) Report the NOEC value for survival, Parameter No. TOM3D.
- (C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

## 5. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters of testing for one or both test species, with no lethal effects demonstrated at or below the critical dilution without a major modification. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the *Daphnia pulex*).
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in Item 3.a above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the Department will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the Permit Compliance System section to update the permit reporting requirements.
- c. SURVIVAL FAILURES - If any test fails the survival endpoint at any time during the life of this permit, two monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.
- d. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.

## 6. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days of confirming lethality in the retests, the permittee shall submit a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity

Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The TRE Action Plan shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:

- i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA-600/6-91/003) or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (800)553-6847 or by writing:

U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161

- ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and

# DRAFT

conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 24 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
  - iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
- c. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
- i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
  - ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
  - iii. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.
- d. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the

# DRAFT

Permit Number: AR0021482  
Page 22 of Part II

critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.

- e. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).

## PART III STANDARD CONDITIONS

### SECTION A – GENERAL CONDITIONS

#### 1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. **Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.**

#### 2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than twenty-five thousand dollars (\$25,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

#### 3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- a. Violation of any terms or conditions of this permit; or
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- e. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part III.A.10. herein.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

# DRAFT

Permit Number: AR0021482

Page 3 of Part III

private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

## 9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

## 10. Permit Fees

The permittee shall comply with all applicable permit fee requirements for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5 (d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

## SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

### 1. Proper Operation and Maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

### 2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

# DRAFT

### 3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

### 4. Bypass of Treatment Facilities

#### a. Bypass not exceeding limitation

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts II.B.4.b. and 4.c.

#### b. Notice

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part III.D.6. (24-hour notice).

#### c. Prohibition of bypass

- (1) Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
  - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and
  - (c) The permittee submitted notices as required by Part III.B.4.b.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part III.B.4.c.(1).

### 5. Upset Conditions

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements



of Part III.B.5.b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

- b. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the specific cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated.
  - (3) The permittee submitted notice of the upset as required by Part III.D.6.; and
  - (4) The permittee complied with any remedial measures required by Part III.B.3.
- c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

## **6. Removed Substances**

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of waste waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. Written approval must be obtained from the ADEQ for land application only.

## **7. Power Failure**

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

## **SECTION C – MONITORING AND RECORDS**

### **1. Representative Sampling**

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharges shall be monitored.

### **2. Flow Measurement**

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted

# DRAFT

capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

### 3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

### 4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

### 5. Reporting of Monitoring Results

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (EPA No. 3320-1 and other approved Form by ADEQ). Permittees are required to use preprinted DMR forms provided by ADEQ, unless specific written authorization to use other reporting forms is obtained from ADEQ. Monitoring results obtained during the previous calendar month shall be summarized and reported on a DMR form postmarked no later than the 25<sup>th</sup> day of the month following the completed reporting period to begin on the effective date of the permit. Duplicate copies of DMR forms signed and certified as required by Part III.D.11. and all other reports required by Part III.D., shall be submitted to the Director at the following address:

Permits Enforcement Branch  
Water Division  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

## 6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

## 7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

## 8. Record Contents

Records and monitoring information shall include:

- a. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- b. The individuals(s) who performed the sampling or measurements;
- c. The date(s) and time analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The measurements and results of such analyses.

## 9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- d. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

## SECTION D – REPORTING REQUIREMENTS

### 1. Planned Changes

The permittee shall give notice and provide plans and specification to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. Notice is required only when:

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges of pollutants) must be reported to the permitting authority. In no case are any new connections, increased flows, or significant changes in influent quality permitted that cause violation of the effluent limitations specified herein.

### 2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

### 3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

### 4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part III.C.5. **Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.**

### 5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

### 6. Twenty-four Hour Report

a. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be

provided within 5 days of the time the permittee becomes aware of the circumstances.

The written submission shall contain the following information:

- (1) a description of the noncompliance and its cause;
  - (2) the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
  - (3) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- b. The following shall be included as information which must be reported within 24 hours:
- (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
  - (2) Any upset which exceeds any effluent limitation in the permit and
  - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the Enforcement Section of the Water Division of the ADEQ.
- c. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the Enforcement Section of the Water Division of the ADEQ.

## **7. Other Noncompliance**

The permittee shall report all instances of noncompliance not reported under Parts II.D.4., 5., and 6., at the time monitoring reports are submitted. The reports shall contain the information listed at Part III.D.6.

## **8. Changes in Discharge of Toxic Substances for Industrial Dischargers**

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(1); or
- b. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(2).

## **9. Duty to Provide Information**

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

# DRAFT

## 10. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

## 11. Signatory Requirements

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

- a. All **permit applications** shall be signed as follows:
  - (1) For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
    - (ii) The manager of one or more manufacturing, production, or operation facilities, provided: the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
  - (2) For a partnership or sole proprietorship: by a general partner or proprietor, respectively; or
  - (3) For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
    - (i) The chief executive officer of the agency, or
    - (ii) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- b. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - (1) The authorization is made in writing by a person described above.

# DRAFT

Permit Number: AR0021482

Page 11 of Part III

- (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
  - (3) The written authorization is submitted to the Director.
- c. Certification. Any person signing a document under this section shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

## **12. Availability of Reports**

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.

## **13. Penalties for Falsification of Reports**

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part III.A.2. and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

## PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. **“Act”** means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
2. **“Administrator”** means the Administrator of the U.S. Environmental Protection Agency.
3. **“Applicable effluent standards and limitations”** means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
4. **“Applicable water quality standards”** means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
5. **“Bypass”** means the intentional diversion of waste streams from any portion of a treatment facility.
6. **“Daily Discharge”** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. *Mass Calculations:* For pollutants with limitations expressed in terms of mass, the “daily discharge” is calculated as the total mass of pollutant discharged over the sampling day. *Concentration Calculations:* For pollutants with limitations expressed in other units of measurement, determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the “daily discharge” determination of concentration shall be the arithmetic average (weighted by flow value) of all the samples collected during that sampling day by using the following formula: where C= daily concentration, F=daily flow and n=number of daily samples

$$\frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$

7. **“Monthly average”** means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. For Fecal Coliform Bacteria (FCB) report the monthly average (see 30-day average below).
8. **“Daily Maximum”** discharge limitation means the highest allowable “daily discharge” during the calendar month. The 7-day average for Fecal Coliform Bacteria (FCB) is the



- geometric mean of the values of all effluent samples collected during the calendar week in colonies per 100 ml.
9. **“Department”** means the Arkansas Department of Environmental Quality (ADEQ).
  10. **“Director”** means the Administrator of the U.S. Environmental Protection Agency and/or the Director of the Arkansas Department of Environmental Quality.
  11. **“Grab sample”** means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
  12. **“Industrial User”** means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
  13. **“National Pollutant Discharge Elimination System”** means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
  14. **“POTW”** means a Publicly Owned Treatment Works.
  15. **“Severe property damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
  16. **“APCEC”** means the Arkansas Pollution Control and Ecology Commission.
  17. **“Sewage sludge”** means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and stormwater runoff that are discharged to or otherwise enter a POTW.
  18. **“7-day average”** discharge limitation, other than for Fecal Coliform Bacteria (FCB), is the highest allowable arithmetic mean of the values for all effluent samples collected during the calendar week. The 7-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values of all effluent samples collected during the calendar week in colonies/100 ml. The Discharge Monitoring Report should report the highest 7-day average obtained during the calendar month. For reporting purposes, the 7-day average values should be reported as occurring in the month in which the Saturday of the calendar week falls in.
  19. **“30-day average”**, other than for Fecal Coliform Bacteria (FCB), is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The 30-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values for all effluent samples collected during a calendar month. For Fecal Coliform Bacteria (FCB), report the monthly average as a 30-day geometric mean in colonies per 100 ml.
  20. **“24-hour composite sample”** consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.

# DRAFT

21. **“12-hour composite sample”** consists of 12 effluent portions, collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.
22. **“6-hour composite sample”** consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow **or** a sample collected at frequent intervals proportional to flow over the 6-hour period.
23. **“3-hour composite sample”** consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow **or** a sample collected at frequent intervals proportional to flow over the 3-hour period.
24. **“Treatment works”** means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
25. **“Upset”** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless or improper operations.
26. **“For Fecal Coliform Bacteria (FCB)”**, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
27. **“Dissolved oxygen limit”**, shall be defined as follows:
  - a. When limited in the permit as a minimum monthly average, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
  - b. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
28. **The term “MGD”** shall mean million gallons per day.
29. **The term “mg/l”** shall mean milligrams per liter or parts per million (ppm).
30. **The term “µg/l”** shall mean micrograms per liter or parts per billion (ppb).
31. **The term “cfs”** shall mean cubic feet per second.
32. **The term “ppm”** shall mean parts per million.
33. **The term “s.u.”** shall mean standard units.
34. **The term “Instantaneous Maximum”** when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.

35. **Monitoring and Reporting:**

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25<sup>th</sup> of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25<sup>th</sup> of the month following the monitoring period end date.

**MONTHLY:**

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

**QUARTERLY:**

(1) is defined as a fixed calendar quarter or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or

(2) is defined as a fixed three month period (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

**SEMI-ANNUAL:**

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

**ANNUAL or YEARLY:**

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.

36. **The term “Weekday”** means Monday – Friday.



A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
40	STEP 2:														
41	INPUT AMBIENT AND EFFLUENT DATA														
42	CALCULATE IN-STREAM WASTE CONCENTRATIONS														
43															
44	DATA INPUT														
45															
46															
47															
48															
49															
50															
51															
52															
53															
54															
55															
56															
57															
58															
59															
60															
61															
62															
63															
64															
65															
66															
67															
68															
69															
70	Total Metals														
71															
72	Arsenic														
73	Cadmium														
74	Chromium(6)														
75	Copper														
76	Lead														
77	Mercury														
78	Nickel														
79	Zinc														
80	Silver														
81															

\*Note: Use this section to convert lab concentrations shown as "dissolved" to "total"









	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
278	STEP 3:	APPLICABLE WATER QUALITY-BASED LIMITS														
279																
280																
281																
282																
283	POLLUTANTS															
284		Permit Daily Maximum	ug/l	Permit Monthly Average	ug/l	Permit Daily Maximum	lb/day	Permit Monthly Average	lb/day	EPA Bloac Status						
288	Delta-BHC	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
296	Alpha-endosulfan	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
307	Copper Total	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
308	Lead Total	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
309	Mercury Total	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
310	Nickel Total	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
312	Silver Total	NO	NO	NO	NO	NO	NO	NO	NO	N/A						
313	Zinc Total	NO	NO	NO	NO	NO	NO	NO	NO	N/A						