

ADEQ

A R K A N S A S
Department of Environmental Quality

CERTIFIED MAIL: RETURN RECEIPT REQUESTED 91 7199 9991 7030 4906 4940

Honorable Frank Fogleman
Mayor, City of Marion
14 Military Rd.
Marion, AR 72364

SEP 9 2013

RE: Discharge Permit Number AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

Enclosed are the public notice, a copy of the draft permit and Fact Sheet which the Arkansas Department of Environmental Quality (ADEQ) has prepared and mailed to you on above date under the authority of the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision. Pursuant to 40 CFR Parts 124.14(b) and (c), only changes from the permit are open for public comment.

In accordance with Reg. 8.207, the enclosed second public notice will be or has been published by ADEQ in a newspaper of general circulation of your facility for one (1) day only.

The permit is being modified to include the following change:

The permit is being modified to include the addition of a new Outfall 002 that discharges directly into the Mississippi River as well as the removal of the rock-reed filters from the treatment process. No changes to Outfall 001 permit limits are occurring with this permit modification.

Only the modified portion of the permit can be reopened for comment pursuant to 40 CFR 122.62.

Comments must be received at ADEQ prior to the close of the public comment period as described in the enclosed public notice. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the draft permit, please contact Chris Randall at (501) 682-0617.

Sincerely,



Ryan Benefield, P.E.
Deputy Director

RB:cr

Enclosure

PUBLIC NOTICE OF DRAFT MODIFIED DISCHARGE PERMIT
AND 208 Plan
PERMIT NUMBER AR0021971, AFIN 18-00110

This is to give notice that the Arkansas Department of Environmental Quality (ADEQ), 5301 Northshore Drive, North Little Rock, Arkansas 72118-5317 at telephone number (501) 682-0622, proposes a draft modification of the permit number AR0021971 for which an application was received on 2/12/2013 with additional information received on 4/05/2013 for the following applicant under the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act.

Applicant: City of Marion, 5054 Hardin Road, Marion, AR 72364. Location: west of Highway 118 just south of Union Pacific Railroad; Latitude: 35° 11' 25"; Longitude: 90° 13' 42" in Crittenden County, Arkansas. The discharge of treated municipal wastewater from the plant site is through a pipeline to the Mississippi River in Segment 6C of the Mississippi River Basin.

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan has been updated to include the new outfall directly to the Mississippi River and the new outfall BOD5/TSS/DO limits of 30/90/2.0. These changes have also been incorporated into the draft discharge permit.

The permit is being modified to include the addition of a forcemain to a new Outfall 002 that discharges directly into the Mississippi River as well as the removal of the rock-reed filters from the treatment process. No changes to Outfall 001 permit limits are occurring with this permit modification.

Only the modified portion of the permit can be reopened for comment pursuant to 40 CFR 122.62.

ADEQ's contact person for submitting written comments, requesting information regarding the draft permit, or obtaining a copy of the permit and the Fact Sheet is Chris Randall, at the above address and telephone number or by email at Water-Draft-Permit-Comment@adeq.state.ar.us. For those with Internet access, a copy of the proposed draft permit as well as the publication date may be found on the ADEQ's website at: http://www.adeq.state.ar.us/water/branch_permits/individual_permits/pn_permits/pnpermits.asp.

The last day of the comment period is 30 days after the publication date. If the last day of the comment period is a Saturday, Sunday or legal holiday, the public comment period shall expire on the next day that is not a Saturday, Sunday or legal holiday. For information regarding the actual publication date along with the actual date and time the comment period will end, please contact Chris Randall at the above address and telephone number or by email at Water-Draft-Permit-Comment@adeq.state.ar.us. Public notice, comments, and hearings will be conducted in accordance with Regulation 6.104(A)(5) [40 CFR Parts 124.10 through 124.12 by reference] and Regulation 8.209 and 8.210 (Administrative Procedures). All persons, including the permittee, who wish to comment on ADEQ's draft permitting decision must submit written comments to ADEQ, along with their name and mailing address. A Public Hearing will be held when ADEQ finds a significant degree of public interest. After the public comment period, ADEQ will issue a final permitting decision. ADEQ will notify the applicant and each person who has submitted written comments or request notice of the final permitting decision. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the APCEC Regulation No. 8.603.

DRAFT

Fact Sheet

All changes to the fact sheet are italicized.

THIS IS A MODIFIED PERMIT. IN ACCORDANCE WITH 40 CFR 122.62, ONLY THE CONDITIONS WHICH ARE THE SUBJECT OF THE MODIFICATION ARE REOPENED. COMMENTS CONCERNING ANY PORTIONS OF THE PERMIT WHICH HAVE NOT BEEN REOPENED WILL NOT BE CONSIDERED.

For *major modification* of the discharge Permit Number AR0021971 with Arkansas Department of Environmental Quality (ADEQ) Facility Identification Number (AFIN) 18-00110 to discharge to Waters of the State.

1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317

2. APPLICANT.

The applicant's mailing address is:

City of Marion
P.O. Box 717
Marion, AR 72364

The facility address is:

City of Marion
5054 Hardin Road
Marion, AR 72364

3. PREPARED BY.

The permit was prepared by:

Chris Randall
Staff Engineer
Discharge Permits Section, Water Division
(501) 682-0617
E-mail: randall@adeq.state.ar.us

DRAFT

4. PERMIT ACTIVITY.

Previous Permit Effective Date: 7/1/2012
Previous Permit Expiration Date: 6/30/2017

The permittee submitted a permit modification application on 2/12/2013.

The permittee has proposed to replace Outfall 001 with Outfall 002. Outfall 002 will discharge directly to the Mississippi River. Because of the vast differences in the receiving streams for the two outfalls, the permit limitations in Outfall 002 are different from those for Outfall 001. Outfall 001 will be retained in the modified permit to allow the permittee time to construct the pipeline for the new outfall. The permittee will be required to notify the Department when they begin to discharge through Outfall 002. At that time, Outfall 001 will be removed from the permit.

It is proposed that the current NPDES permit be modified for the remainder of the 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

DOCUMENT ABBREVIATIONS

In the document that follows, various abbreviations are used. They are as follows:

BAT - best available technology economically achievable
BCT - best conventional pollutant control technology
BMP - best management practices
BOD₅ - five-day biochemical oxygen demand
BPJ - best professional judgment
BPT - best practicable control technology currently available
CBOD₅ - carbonaceous biochemical oxygen demand
CD - critical dilution
CFR - Code of Federal Regulations
cfs - cubic feet per second
COD - chemical oxygen demand
COE - United States Corp of Engineers
CPP - continuing planning process
CWA - Clean Water Act
DMR - discharge monitoring report
DO - dissolved oxygen
ELG - effluent limitation guidelines
EPA - United States Environmental Protection Agency
ESA - Endangered Species Act

DRAFT

FCB - fecal coliform bacteria
gpm - gallons per minute
MGD - million gallons per day
MQL - minimum quantification level
NAICS - North American Industry Classification System
NH₃-N - ammonia nitrogen
NO₃ + NO₂-N - nitrate + nitrite nitrogen
NPDES - National Pollutant Discharge Elimination System
O&G - oil and grease
Reg. 2 - APCEC Regulation No. 2
Reg. 6 - APCEC Regulation No. 6
Reg. 8 - APCEC Regulation No. 8
Reg. 9 - APCEC Regulation No. 9
RP - reasonable potential
SIC - standard industrial classification
TDS - total dissolved solids
TMDL - total maximum daily load
TP - total phosphorus
TRC - total residual chlorine
TSS - total suspended solids
UAA - use attainability analysis
USF&WS - United States Fish and Wildlife Service
WET - Whole effluent toxicity
WQMP - water quality management plan
WQS - Water Quality standards
WWTP - wastewater treatment plant

DMR Review:

The Discharge Monitoring Reports (DMR's) for the last two years were reviewed during the permit renewal process. There were 40 violations for NH₃-N occurring from August 2009 to July 2011, 12 violations for TRC occurring from March 2010 to February 2011, and 2 violations for FCB occurring in August 2011.

Legal Order Review:

A consent administrative order (CAO LIS 12-035) for the effluent limit violations has been signed by the Director on 2/9/2012 and public noticed on 2/25/2012. This CAO is scheduled to become effective on 3/25/2012 and requires the city, through the services of a professional engineer, develop and submit a comprehensive corrective action plan with milestone schedule to eliminate the violations of effluent limitations set forth in the NPDES permit.

DRAFT

Page 4 of Fact Sheet
Permit Number: AR0021971
AFIN: 18-00110

Site Visits/Inspections

A compliance inspection performed on 11/30/2011, 12/1/2011, and 12/2/2011 revealed the following violations:

1. Overflow of partially treated wastewater occurring over pond levee.
2. Inadequate freeboard in lagoons.
3. Excessive vegetative growth on lagoon levees.

A response letter was submitted dated 1/10/2012 containing the following corrective actions:

1. Stopped overflow with sandbags and stabilized levees with rip-rap.
2. Lowered pond levels by temporarily pumping to rock-reed filters using portable pump.
3. Bush hog the excessive levee vegetation as weather permits.

5. SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. Sample frequency for CBOD5 was reduced from three/week to two/week based on historical compliance with the effluent limit.
2. Sample frequency for DO and pH was reduced from three/week to once/week based on historical compliance with the effluent limit.
3. Monitoring and reporting requirements were added for Total Phosphorus and Nitrate + Nitrite Nitrogen in order to gather point source loading data from this facility.
4. Dissolved oxygen limits are now expressed as an instantaneous minimum instead of a monthly average minimum since dissolved oxygen standards must be met at all times, not on an average basis.
5. Outfall coordinates were revised to more accurate values.

The permit is being modified to include the addition of a new Outfall 002 that discharges directly into the Mississippi River as well as the removal of the rock-reed filters from the treatment process. No changes to Outfall 001 permit limits are occurring with this permit modification.

DRAFT

6. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.

The outfalls are located at the following coordinates based on Google Earth using WGS84 map datum:

Outfall 001: Latitude: 35° 11' 25" Longitude: 90° 14' 15"

The receiving waters named:

Fifteen Mile Bayou to Black Fish Bayou, thence to the St. Francis River in Segment 5A of the St. Francis River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 8020203 and reach #006 is a Water of the State classified for primary contact recreation, raw water source for domestic (public and private), industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

Outfall 002: Latitude: 35° 15' 06" Longitude: 90° 06' 06"

The receiving waters named:

from the plant site through a pipeline to the Mississippi River in Segment 6C of the Mississippi River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 8010100 and reach #005 is a Water of the State classified for primary contact recreation, raw water source for domestic (public and private), industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

7. 303(d) LIST, ENDANGERED SPECIES, AND ANTI-DEGRADATION CONSIDERATIONS.

A. 303(d) List:

The receiving streams are not listed on the 2008 303(d) list. Therefore, no permit action is needed.

B. Endangered Species:

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Statement of Basis will be sent to the USF&WS for their review.

DRAFT

C. Anti-Degradation:

The limitations and requirements set forth in this permit for discharge into waters of the State are consistent with the Antidegradation Policy and all other applicable water quality standards found in APC&EC Regulation No. 2.

8. OUTFALL, TREATMENT PROCESS DESCRIPTION, AND FACILITY CONSTRUCTION.

Until the pipeline to the Mississippi River is completed and the discharge flow is routed to the new pipeline, the facility will report "no discharge" on the DMRs for Outfall 002. After the switchover to the pipeline occurs and the facility ceases discharging to Fifteen Mile Bayou, the permittee shall submit a report to the Department (discharge permit section of water division) indicating when switchover occurred and Outfall 001 ceased discharging. Beginning in the month after the submittal of this report, the permittee shall no longer be required to submit DMRs for Outfall 001 and this outfall will be removed from the permit through a minor modification to the permit.

The following is a description of the facility described in the application:

A. Design Flow: 1.6 MGD

B. Type of Treatment:

Outfall 001: 3-cell lagoon with aeration in cell 1 and cell 3, followed by rock-reed filters, chlorine disinfection, and sulfur dioxide dechlorination.

Outfall 002: 3-cell lagoon with aeration in cell 1, chlorine disinfection, and sulfur dioxide dechlorination.

C. Discharge Description: treated municipal wastewater

D. Facility Status: This facility is classified as a major municipal since the design flow of the facility listed above is greater than 1.0 MGD.

E. Facility Construction: This permit does not authorize or approve the construction or modification of any part of the treatment system or facilities. Approval for such construction must be by permit issued under Reg. 6.202.

DRAFT

Page 7 of Fact Sheet
Permit Number: AR0021971
AFIN: 18-00110

9. ACTIVITY.

Under the Standard Industrial Classification (SIC) code of 4952 or North American Industry Classification System (NAICS) code of 221320, the applicant's activities are the operation of a sewage treatment plant.

10. INDUSTRIAL WASTEWATER CONTRIBUTIONS.

This facility receives industrial process wastewater from one significant industry as defined by 40 CFR Part 403.3(v). Standard boilerplate Pretreatment Prohibitions (40 CFR Part 403.5[b]) and reporting requirements are deemed appropriate at this time.

11. SEWAGE SLUDGE PRACTICES.

Sludge generated at this facility remains in the lagoons. According to conversations with the city, the lagoons were constructed in the early 1970's and sludge has never been removed. On 10/11/2011 and again on 1/24/2012, the permit writer requested that sludge levels be determined in four locations in each lagoon and report these levels to the Department. The sludge report was received on 5/17/2012 which included the measured sludge depths in twelve locations throughout the lagoons (four measurements in each of the three cells). According to the report, the sludge depths ranged from 7 to 13 inches with the thickest sludge layer being in the third cell. The total lagoon depth at each sample location ranged from 4 to 6 feet. Using the sludge depth and water depth measured at each location, the average sludge depth was calculated to be 17% of the average lagoon water depth. Therefore, no permit action is necessary at this time.

12. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a determination to issue a final permit for the discharge described in the application. Permit requirements are based on federal regulations (40 CFR Parts 122, 124, and Subchapter N), the National Pretreatment Regulation in 40 CFR Part 403 and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. 8-4-101 et. seq.).

DRAFT

Effluent Limitations

Outfall 001 - treated municipal wastewater

1. Conventional and/or Toxic Pollutants

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Max.)	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	200	15	22.5	two/week	composite
Total Suspended Solids (TSS)	267	20	30	three/week	composite
Ammonia Nitrogen (NH3-N)					
(April - October)	32	2.4	5.9	three/week	composite
(November - March)	90	6.7	12	three/week	composite
Dissolved Oxygen (DO)					
(May-Oct)	N/A	4.0 (Inst. Min.)		once/week	grab
(Nov-Apr)	N/A	6.0 (Inst. Min.)		once/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100 ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Residual Chlorine (TRC)	N/A	<0.1 mg/l (Inst. Max.)		three/week	grab
Total Phosphorus (TP)	Report	Report	Report	once/quarter	grab
Nitrate + Nitrite Nitrogen (NO3+NO2-N)	Report	Report	Report	once/quarter	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab
Chronic WET Testing	N/A	Report		once/quarter	composite

2. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

DRAFT

Effluent Limitations

Outfall 002 - treated municipal wastewater

2. Conventional and/or Toxic Pollutants

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Max.)	once/day	totalizing meter
Biochemical Oxygen Demand (BOD5)	400	30.0	45.0	two/week	composite
Total Suspended Solids (TSS)	1200	90.0	135.0	three/week	composite
Dissolved Oxygen (DO)	N/A	2.0 (Monthly Avg. Min.)		once/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100 ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Residual Chlorine (TRC)	N/A	<0.1 mg/l (Inst. Max.)		three/week	grab
Total Phosphorus (TP)	Report	Report	Report	once/quarter	grab
Nitrate + Nitrite Nitrogen (NO3+NO2-N)	Report	Report	Report	once/quarter	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week	grab
Acute WET Testing	N/A	Report		once/quarter	composite
<u>Pimephales promelas (Acute)</u> Pass/Fail Lethality (48-Hr NOEC) TEM6C Survival (48-Hr NOEC) TOM6C Coefficient of Variation (48-Hr NOEC) TQM6C		<u>48-Hr Minimum</u> Report (Pass=0/Fail=1) Report% Report%		once/quarter once/quarter once/quarter	composite composite composite
<u>Daphnia pulex (Acute)</u> Pass/Fail Lethality (48-Hr NOEC) TEM3D Survival (48-Hr NOEC) TOM3D Coefficient of Variation (48-Hr NOEC) TQM3D		<u>48-Hr Minimum</u> Report (Pass=0/Fail=1) Report% Report%		once/quarter once/quarter once/quarter	composite composite composite

2. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

DRAFT

13. BASIS FOR PERMIT CONDITIONS.

The following is an explanation of the derivation of the conditions of the final permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the decisions as required under 40 CFR Part 124.7.

Technology-Based Versus Water Quality-Based Effluent Limitations And Conditions

Following regulations promulgated at 40 CFR Part 122.44, the final permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44 (a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44 (d), whichever are more stringent.

OUTFALL 001

Parameter	Water Quality-Based		Technology-Based/BPJ		Previous Permit		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
CBOD5	15	22.5	25	40	15	22.5	15	22.5
TSS	N/A	N/A	20	30	20	30	20	30
NH3-N								
(April-October)	2.4	5.9	N/A	N/A	2.4	5.9	2.4	5.9
(Nov-March)	6.7	12	N/A	N/A	6.7	12	6.7	12
DO								
(May-Oct)	4.0 (Inst. Min.)		N/A		4.0 (Monthly Avg Min.)		4.0 (Inst. Min.)*	
(Nov-Apr)	6.0 (Inst. Min.)		N/A		6.0 (Monthly Avg Min.)		6.0 (Inst. Min.)*	
FCB (col/100 ml)								
(Apr-Sept)	200	400	N/A	N/A	200	400	200	400
(Oct-Mar)	1000	2000	N/A	N/A	1000	2000	1000	2000
TRC (Inst. Max)	N/A		< 0.1 mg/l		<0.1 mg/l		<0.1 mg/l	
TP	N/A	N/A	Report	Report	N/A	N/A	Report	Report
NO ₃ + NO ₂ - N	N/A	N/A	Report	Report	N/A	N/A	Report	Report

DRAFT

Parameter	Water Quality-Based		Technology-Based/BPJ		Previous Permit		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
pH	6.0-9.0 s.u.		6.0-9.0 s.u.		6.0-9.0 s.u.		6.0-9.0 s.u.	
Chronic WET Testing	Report		N/A		Report		Report	

* The DO requirements for this permit have changed from monthly average minimum to instantaneous minimum. As required in Reg. 2.505, dissolved oxygen standards must be met in streams at all times. Therefore, the permittee is not allowed to average DO readings throughout the month to demonstrate compliance with an instantaneous standard.

OUTFALL 002

Parameter	Water Quality-Based		Technology-Based/BPJ		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
BOD5	30*	N/A	30	45	30	45
TSS	N/A	N/A	90	135	90	135
DO	2.0, (Monthly Avg. Min.)		N/A		2.0, (Monthly Avg. Min.)	
FCB (col/100 ml)						
(Apr-Sept)	200	400	N/A	N/A	200	400
(Oct-Mar)	1000	2000	N/A	N/A	1000	2000
TRC (Inst. Max)	N/A		< 0.1 mg/l		< 0.1 mg/l	
TP	N/A	N/A	Report	Report	Report	Report
NO ₃ + NO ₂ - N	N/A	N/A	Report	Report	Report	Report
pH	6.0-9.0 s.u.		6.0-9.0 s.u.		6.0-9.0 s.u.	
Acute WET Testing	Report		N/A		Report	

* Technology limit for BOD5 was modeled to demonstrate compliance with DO water quality standards.

A. Justification for Limitations and Conditions for Outfall 001 of the permit:

Parameter	Water Quality or Technology	Justification
CBOD5 ¹	Water Quality	MultiSMP Model dated 4/21/2006
TSS ²	Technology	CPP, Previous Permit and 40 CFR 122.44(l)
NH3-N ³	Water Quality	Reg. 2.512 for all April-October limits. MultiSMP Model dated 4/21/2006 for Nov-March 7-day avg limit.
DO ⁴	Water Quality	Reg. 2.505 and MultiSMP Model dated 4/21/2006.
Fecal Coliform Bacteria ⁵	Water Quality	Reg. 2.507
TRC ⁶	Technology	CPP
Total Phosphorus ⁷	Technology	CPP
Nitrate + Nitrite Nitrogen ⁷	Technology	CPP
pH ⁸	Technology	Reg. 2.504 and 40 CFR 133.102(c)
Chronic WET testing ⁹	Water Quality	CPP

- 1 CBOD5 limits are continued from the previous permit and are included because domestic wastewater contains oxygen consuming organic material which consume dissolved oxygen in the receiving stream. The purpose of the CBOD5 limit is to ensure that the organic strength of the wastewater is sufficiently reduced by the treatment process so that the discharge of the treated wastewater does not cause a violation of dissolved oxygen standards in the receiving stream. The numerical value of the permit limit is based on desktop stream modeling performed on 4/21/2006.
- 2 TSS limits are continued from the previous permit and are included because domestic wastewater contains suspended solids that can cause turbidity in the receiving water if discharged without any reduction. TSS can also impact the benthic environment after settling in the receiving stream. TSS limits are included to ensure that the treatment system is properly reducing the TSS values in the wastewater to acceptable values. The numerical value of the TSS limit was assigned based on the value of the CBOD5 limit and the CPP, which states that TSS limits assigned in the permit are typically 1-3 times the CBOD5 limits.
- 3 NH3-N limits are continued from the previous permit and are included because domestic wastewater contains levels of ammonia that can cause toxicity if discharged to the receiving stream without any reduction. Ammonia will also exert an unacceptable oxygen demand on the receiving water if discharged without any reduction. The purpose of the NH3-N limits is to ensure that the ammonia levels in the wastewater is sufficiently

DRAFT

reduced by the treatment process so that the discharge of the treated wastewater does not cause a violation of dissolved oxygen standards, nor cause toxic conditions in the receiving stream. The numerical value of the NH₃-N limits is based on effluent values derived from the oxygen-based desktop stream modeling performed on 4/21/2006 or the values necessary to meet the toxicity-based standards in Reg. 2.512, whichever are more stringent.

- 4 DO limits are continued from the previous permit and are included to ensure the discharge of treated wastewater contains sufficient dissolved oxygen to not cause an oxygen sag below the minimum dissolved oxygen standards in the receiving stream. The numerical value of the instantaneous minimum dissolved oxygen limits is based on desktop stream modeling performed on 4/21/2006.
- 5 FCB limits are continued from the previous permit and are included for the purpose of maintaining the primary and secondary contact recreation designated use in the receiving stream. Domestic wastewater can contain elevated levels of FCB which require reduction prior to discharging to the receiving water. The FCB limits included in the permit serve the purpose of ensuring the disinfection process at the treatment facility is properly operated. The numerical value of the limits is based on the criteria in Reg. 2.507.
- 6 TRC limit is continued from the previous permit and is included because TRC is toxic to aquatic organisms in the receiving water at concentrations higher than 0.011 mg/l. To ensure that TRC is not discharged at toxic levels and the dechlorination process is properly operated, the permit includes a TRC limit equal to a non-detect level which is currently established as less than 0.1 mg/l.
- 7 In order to establish a data base of point source loading of nutrients to water of the state from all major municipal facilities, the permit includes monitoring for Total Phosphorus and Nitrate + Nitrite Nitrogen in accordance with the Continuing Planning Process.
- 8 pH limits are included in the permit to ensure compliance with the pH water quality standards in Reg. 2.504 and the secondary treatment regulations in 40 CFR Part 133.103(c).
- 9 Chronic Whole Effluent Toxicity reporting requirements are continued from the previous permit and are included in accordance with the CPP which states that all major facilities are subject to WET testing. WET testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics.

DRAFT

B. Justification for Limitations and Conditions for Outfall 002 of the permit:

<i>Parameter</i>	<i>Water Quality or Technology</i>	<i>Justification</i>
<i>BOD5¹</i>	<i>Technology</i>	<i>MultiSMP Model dated 4/16/2013 and 40 CFR 133.102(a)</i>
<i>TSS²</i>	<i>Technology</i>	<i>40 CFR 133.103(c) and Memo from EPA Region 6: Guidance on Implementing Secondary Treatment Regulations</i>
<i>DO³</i>	<i>Technology</i>	<i>Reg. 2.505, MultiSMP Model dated 4/16/2013, 40 CFR 122.44(d)(1)(vii)(B), and BEJ</i>
<i>Fecal Coliform Bacteria⁴</i>	<i>Water Quality</i>	<i>Reg. 2.507</i>
<i>TRC⁵</i>	<i>Technology</i>	<i>CPP</i>
<i>Total Phosphorus⁶</i>	<i>Technology</i>	<i>CPP</i>
<i>Nitrate + Nitrite Nitrogen⁶</i>	<i>Technology</i>	<i>CPP</i>
<i>pH⁷</i>	<i>Water Quality</i>	<i>Reg. 2.504</i>
<i>Acute WET testing⁸</i>	<i>Water Quality</i>	<i>CPP</i>

¹ Since the level of BOD5 treatment in the waste stabilization ponds does not exceed the requirements set forth in 40 CFR 133.102(a), BOD5 limitations have been based on the secondary treatment standards in 40 CFR 133.102(a). The technology limit for BOD5 was modeled to demonstrate compliance with DO water quality standards and the numerical value of the permit limit is based on desktop stream modeling performed on 4/16/2013. BOD5 limits have been included because domestic wastewater contains oxygen consuming organic material which consume dissolved oxygen in the receiving stream.

² TSS limits have been based on the regulations of 40 CFR 133.103(c). The numeric value of the permit limit is based on approved alternative state requirements and EPA Region 6 Memo: Guidance on Implementing Secondary Treatment Regulations. This memorandum states that waste stabilization pond treatment is considered equivalent to secondary treatment and defines the TSS limit for ponds to be 90 mg/l. TSS limits are included to ensure proper detention time is maintained with the lagoons to allow for proper settling of suspended solids.

³ The minimum required DO level has been included in the permit in order to ensure compliance with the requirements of Reg. 2.505. The Dissolved Oxygen limit of 2.0 mg/l has been based the MultiSMP model dated 4/16/2013, the large background flow of the receiving stream, and the Best Engineering Judgment of the permit writer that all secondary treatment plants are capable of meeting a DO limit of 2.0 mg/l when properly

operated. In addition, on 7/8/2013, EPA approved the WLA derived in the MultiSMP Model dated 4/16/2013. Therefore, the permit limit must be consistent with the EPA approved WLA in accordance with 40 CFR 122.44(d)(1)(vii)(B).

- ⁴ *FCB limits have been based on the requirements of Reg. 2.507 due to the receiving stream classification. FCB limits are included for the purpose of maintaining the primary and secondary contact recreation designated use in the receiving stream. Domestic wastewater can contain elevated levels of FCB which require reduction prior to discharging to the receiving water. The FCB limits included in the permit serve the purpose of ensuring the disinfection process at the treatment facility is properly operated.*
- ⁵ *TRC limit is included because TRC is toxic to aquatic organisms in the receiving water at concentrations higher than 0.011 mg/l. To ensure that TRC is not discharged at toxic levels, the permit includes a TRC limit equal to a non-detect level which is currently established as less than 0.1 mg/l in accordance with the Continuing Planning Process.*
- ⁶ *Total Phosphorus and Nitrate + Nitrite Nitrogen have been included in the permit in order to establish a data base of point source loadings of nutrients to water of the state from all major municipal facilities in accordance with the Continuing Planning Process. Since the monitoring requirements for these parameters were only included in the last renewal, there is insufficient monitoring data to have a representative database for an evaluation of these pollutants in the discharge. Therefore, these monitoring requirements will continue in effect for the duration of the permit for both outfalls.*
- ⁷ *pH limits are included in the permit to ensure compliance with the pH water quality standards in Reg. 2.504 and the secondary treatment regulations in 40 CFR Part 133.102(c).*
- ⁸ *Acute Whole Effluent Toxicity reporting requirements are included in accordance with the CPP which states that all major facilities are subject to WET testing. WET testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics.*

B. Anti-backsliding

The final permit is consistent with the requirements to meet Anti-backsliding provisions of the Clean Water Act (CWA), Section 402(o) [40 CFR 122.44(l)]. The final effluent limitations for reissuance permits must be as stringent as those in the previous permit, unless the less stringent limitations can be justified using exceptions listed in 40 CFR 122.44 (l)(2)(i).

The final permit maintains the requirements of the previous permit for Outfall 001. *The facility is being modified in accordance with State Construction Permit AR0021971C. These modifications include removing the rock filter, expanding the chlorine contact basin, and*

DRAFT

constructing a new force main to pipe effluent to the Mississippi River. Since the new Outfall location is in a different river in a different watershed, different limits apply. Therefore, new permit limits for Outfall 002 do not constitute backsliding in accordance with 40 CFR 122.44(A) due to substantial alterations and additions to the permitted facility.

C. Limits Calculations

1. Mass limits:

In accordance with 40 CFR 122.45(f)(1), all pollutants limited in permits shall have limitations expressed in terms of mass if feasible. 40 CFR 122.45(f)(2) allows for pollutants which are limited in terms of mass to also be limited in terms of other units of measurement.

The calculation of the loadings (lbs per day) uses a design flow of 1.6 MGD and the following equation:

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

2. 7-Day Average Limits for Outfall 001:

The 7-Day Average limits for CBOD5 and TSS are based on Section 5.4.2 of the Technical Support Document for Water Quality-Based Toxics Control using the following equation:

$$\text{7-Day Average limits} = \text{Monthly average limits} \times 1.5$$

The 7-Day Average NH3-N limits are based on the requirements of Reg. 2.512.

The 7-Day Average limits for FCB are based on Reg. 2.507.

3. 7-Day Average Limits for Outfall 002:

The 7-Day Average limit for TSS is based on Section 5.4.2 of the Technical Support Document for Water Quality-Based Toxics Control using the following equation:

$$\text{7-Day Average limits} = \text{Monthly average limits} \times 1.5$$

The 7-Day Average BOD5 limit is based on 40 CFR 133.102(a).

The 7-Day Average limits for FCB are based on Reg. 2.507.

4. Ammonia-Nitrogen (NH₃-N):

The water quality effluent limitations for Ammonia are based either on DO-based effluent limits or on toxicity-based standards, whichever are more stringent. The toxicity-based effluent limitations are based on Reg. 2.512 and the CPP.

D. **208 Plan (Water Quality Management Plan)**

Outfall 001:

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan has been updated to include the monthly average toxicity-based NH₃-N limits of 2.4 mg/l (April-October) and 6.7 mg/l (November-March).

Outfall 002:

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan has been updated to include the new outfall directly to the Mississippi River and the new outfall BOD₅/TSS/DO limits of 30/90/2.0. These changes have also been incorporated into the draft discharge permit.

E. **Priority Pollutant Scan (PPS)**

Outfall 001:

ADEQ has reviewed and evaluated the effluent in accordance with the potential toxicity of each analyzed pollutant using the procedures outlined in the Continuing Planning Process (CPP).

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards (AWQS), Regulation No. 2 (Reg. 2.508) and criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)".

Under Federal Regulation 40 CFR Part 122.44(d), as adopted by Regulation No. 6, if a discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard, the permit must contain an effluent limitation for that pollutant. Effluent limitations for the toxicants listed below have been derived in a manner consistent

DRAFT

with the Technical Support Document (TSD) for Water Quality-based Toxics Control (EPA, March 1991), the CPP, and 40 CFR Part 122.45(c).

The following items were used in calculations:

Parameter	Value	Source
Flow = Q	1.6 MGD = 2.47 cfs	Application
7Q10	0.5 cfs	U.S.G.S.
TSS	8 mg/l	CPP, delta ecoregion
Hardness as CaCo3	81 mg/l	CPP, delta ecoregion
pH	7.5 s.u.	ADEQ station FRA0028

The following pollutants were reported above the required MQL:

Pollutant	Concentration Reported, µg/l	MQL, µg/l
Arsenic	2.78	0.5
Copper	1.8	0.5
Nickel	4.69	0.5

ADEQ has determined from the submitted information that the discharge does not pose the reasonable potential to cause or contribute to an exceedance above a water quality standard.

Outfall 002:

The following information was based on the last permit application's PPS submitted to the Department on 9/20/2011 and the new receiving stream data. This information pertains only to Outfall 002:

The rock-reed filters will be removed from the treatment process after the facility commences discharge through Outfall 002. Granular media polishing filters such as rock-reed filters have a primary function of reducing TSS and BOD from wastewater but can also have secondary physic-chemical process effects of metal precipitation catalyzed by the bacteria growing on the rock media for some metals such as Iron and Manganese. Precipitation of metals from bacteria and plant life is assumed insignificant over long periods of time since the metals remain in the plant tissue until the plant life dies, then metals are released back into the wastewater. The Technology Review of Constructed Wetlands, Subsurface Flow Constructed Wetlands for Greywater and Domestic Wastewater Treatment by GIZ dated February 2011 states in reference to metals removal in rock-reed filters, "Heavy metals do not disappear, but still remain in the plant tissues." Assuming no significant removal

DRAFT

efficiencies for metals occur from the rock-reed filters, the existing PPS data is valid since the metal concentrations in the wastewater will remain the same.

ADEQ has reviewed and evaluated the effluent in accordance with the potential toxicity of each analyzed pollutant using the procedures outlined in the Continuing Planning Process (CPP).

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards (AWQS), Regulation No. 2 (Reg. 2.508) and criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)".

Under Federal Regulation 40 CFR Part 122.44(d), as adopted by Regulation No. 6, if a discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard, the permit must contain an effluent limitation for that pollutant. Effluent limitations for the toxicants listed below have been derived in a manner consistent with the Technical Support Document (TSD) for Water Quality-based Toxics Control (EPA, March 1991), the CPP, and 40 CFR Part 122.45(c).

The following items were used in calculations:

Parameter	Value	Source
Flow = Q	1.6 MGD = 2.47 cfs	Application
7Q10	119,000 cfs	U.S.G.S.
TSS	8 mg/l	CPP, delta ecoregion
Hardness as CaCo3	81 mg/l	CPP, delta ecoregion
pH	7.56 s.u.	2008 305b Report

The following pollutants were reported in the last submitted PPS above the required MQL:

Pollutant	Concentration Reported, $\mu\text{g/l}$	MQL, $\mu\text{g/l}$
Arsenic	2.78	0.5
Copper	1.8	0.5
Nickel	4.69	0.5

ADEQ has determined from the submitted information that the discharge does not pose the reasonable potential to cause or contribute to an exceedance above a water quality standard.

DRAFT

14. TOTAL RESIDUAL CHLORINE (TRC) REQUIREMENTS.

After dechlorination and prior to final disposal, the effluent shall contain NO MEASURABLE TRC at any time. NO MEASURABLE will be defined as no detectable concentration of TRC as determined by any approved method established in 40 CFR Part 136 as less than 0.1 mg/l. Thus, the “no measurable TRC concentration” for chlorine becomes the permit limit. The effluent limitation for TRC is the instantaneous maximum and cannot be averaged for reporting purposes. TRC shall be measured within fifteen (15) minutes of sampling.

15. WHOLE EFFLUENT TOXICITY.

OUTFALL 001:

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent toxicity (WET) testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992, and EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies, revised March 13, 2000. Whole effluent toxicity testing of the effluent is thereby required as a condition of this permit to assess potential toxicity. The whole effluent toxicity testing procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS

FREQUENCY

Chronic WET

Once/quarter

Requirements for measurement frequency are based on the CPP.

Since 7Q10 is less than 100 cfs (ft³/sec) and dilution ratio is less than 100:1, chronic WET testing requirements will be included in the permit.

DRAFT

The calculations for dilution used for chronic WET testing are as follows:

$$\text{Critical dilution (CD)} = (Q_d / (Q_d + Q_b)) \times 100$$

$$Q_d = \text{Design flow} = 1.6 \text{ MGD} = 2.47 \text{ cfs}$$

$$7Q_{10} = 0.5 \text{ cfs}$$

$$Q_b = \text{Background flow} = 0.67 \times 7Q_{10} = 0.335 \text{ cfs}$$

$$\text{CD} = (2.47) / (2.47 + 0.335) \times 100 = 88\%$$

Toxicity tests shall be performed in accordance with protocols described in "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", EPA/600/4-91/002, July 1994. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are 28%, 37%, 50%, 66%, and 88% (See the CPP). The low-flow effluent concentration (critical dilution) is defined as 88% effluent. The requirement for chronic WET tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species, *Ceriodaphnia dubia* and the Fathead minnow (*Pimephales promelas*) are representative of organisms indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The WET testing frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen conductivity, and alkalinity shall be reported according to EPA-821-R-02-013, October 2002 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further WET testing studies, Toxicity Reduction Evaluation (TRE) and/or effluent limits if WET testing data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

Administrative Records

During the past five years there have been two *P. promelas* lethal and sub-lethal WET test failures below the critical dilution, the second of which occurred during March 2011. During the past five years there has been one *C. dubia* lethal and sub-lethal WET test below the critical dilution. In March of 2011 the facility began dechlorination using sulfur dioxide gas. In response to the March test failures, and after dechlorination began, the facility reported

DRAFT

two consecutive monthly passing retests for all WET testing parameters. The facility has reported no WET failures since dechlorination began. After installation of dechlorination, the effluent showed a significant reduction in residual chlorine values as indicated by the reported values on the discharge monitoring reports. The average TRC value reported from March 2007 to February 2011 (prior to dechlorination) was 0.96 mg/l with reported values as high as 1.94 mg/l. Since dechlorination began in March 2011, all effluent TRC values reported have been < 0.1 mg/l.

In accordance with the November 2004 EPA guidance document titled “National Whole Effluent Toxicity (WET) Implementation Guidance under the NPDES Program” [EPA 832-B-04-003], data received on or before March 2011 can and should be considered unrepresentative of the current effluent since the facility began a new process of dechlorination using sulfur dioxide gas after March 2011. Any data received and considered after this point should be considered representative of the current effluent.

Section 4.1.4 of the 2004 EPA Guidance referenced above provides that the “effluent data used as the basis for effluent characterization should be representative of the monitored activity (*i.e.*, the discharge under current conditions with current treatment and management practices at the plant [40 CFR 122.41 (j) (1)].” The guidance also conveys that WET data may not be representative if such data was obtained prior to “significant treatment, pretreatment, or pollution prevention modifications.” When the WET data is no longer representative, the EPA Region 6, WET Permitting Strategy, May 2005 (pg. 3) indicates that the permitting authority (*i.e.* ADEQ) may “exclude such data in the [reasonable potential] determination... because the data pre-date current operating conditions and treatment at the facility.”

At this time, there is insufficient evidence to support the inclusion of limits since no WET failures have occurred after installing dechlorination. Additional WET testing data is needed to confirm the effects of adding dechlorination, therefore WET limits are not required at this time. The inclusion of requirements for retests for failures will provide sufficient documentation concerning the necessity for a TRE, and the potential for inclusion of WET limits if appropriate. The following information summarized toxicity test submitted by the permittee during the term of the current permit at outfall 001:

DRAFT

Permit Number:	AR0021971	AFIN:	18-00110	Outfall Number:	001
Date of Review:	2/8/2012	Reviewer:	M. Barnett		
Facility Name:	City of Marion				
Previous Dilution series:	28, 37, 50, 66, & 88	Proposed Dilution Series:	28, 37, 50, 66, & 88		
Previous Critical Dilution:	88	Proposed Critical Dilution:	88		
Previous TRE activities:	None				

Frequency recommendation by species

<i>Pimephales promelas</i> (Fathead minnow):	once per quarter
<i>Ceriodaphnia dubia</i> (water flea):	once per quarter

TEST DATA SUMMARY

TEST DATE	Vertebrate		Invertebrate		
	Lethal NOEC	Sub-Lethal NOEC	Lethal NOEC	Sub-Lethal NOEC	
6/5/2007	88	88	88	88	
9/5/2007	88	88	88	88	
12/5/2007	88	88	88	88	
3/5/2008	88	88	88	88	
6/5/2008	88	88	88	88	
9/5/2008	88	88	88	88	
12/5/2008	88	88	88	88	
3/5/2009	88	88	88	88	
6/5/2009	88	88	88	88	
9/1/2009	88	88	88	88	
12/31/2009	28	28	88	28	
3/31/2010	88	88	88	88	
6/30/2010	88	88	88	88	
9/30/2010	88	88	88	88	
12/31/2010	88	88	88	88	
3/31/2011	50	50	66	88	88 1st quarter
4/30/2011	88	88	88	88	88 retest 1
5/31/2011	88	88	88	88	88 retest 2
6/30/2011	88	88	88	88	
9/30/2011	88	88	88	88	
12/31/2011	88	88	88	88	

Failures are noted in BOLD

NOTE: SO2 dechlorination installed March 2011

REASONABLE POTENTIAL CALCULATIONS

	Vertebrate Lethal	Vertebrate Sub-Lethal	Invertebrate Lethal	Invertebrate Sub-Lethal
Min NOEC Observed	28	28	66	28
TU at Min Observed	3.57	3.57	1.52	3.57
Count	21	21	21	21
Failure Count	2	2	1	1
Mean	1.293	1.293	1.154	1.252
Std. Dev.	0.555	0.555	0.083	0.531
CV	0.4	0.4	0.1	0.4
RPMF	1.2	1.2	1.1	1.2
Reasonable Potential	3.771	3.771	1.467	3.771
I00/Critical dilution	1.136	1.136	1.136	1.136
Does Reasonable Potential Exist	Yes	Yes	Yes	Yes

PERMIT ACTION

- P. promelas* lethal - monitoring
- P. promelas* sub-lethal - monitoring
- C. dubia* lethal - monitoring
- C. dubia* sub-lethal - monitoring

DRAFT

OUTFALL 002:

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent toxicity (WET) testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992.

Whole effluent toxicity testing of the effluent is thereby required as a condition of this permit to assess potential toxicity. The whole effluent toxicity testing procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS

FREQUENCY

48 hour Acute WET

Once/quarter

Requirements for measurement frequency are based on the CPP.

Since 7Q10 is greater than 100 cfs (ft³/sec) and dilution ratio is greater than 100:1, acute WET testing requirements will be included in the permit.

The calculations for dilution used for the acute WET testing are as follows:

$$\text{Critical Dilution (CD)} = (Q_d / (Q_d + Q_b)) \times 100$$

$$Q_d = \text{Design Flow} = 1.6 \text{ MGD} = 2.475 \text{ Cfs}$$

$$7Q_{10} = 119,000 \text{ Cfs}$$

$$Q_b = \text{Background flow} = 0.1 \times (0.25) \times 7Q_{10} = 2975$$

$$CD = (2.475 / (2.475 + 2975)) \times 100 = 0.083\%$$

Based on the judgment of the permit writer, the critical dilution will be set at 1%.

DRAFT

*Toxicity tests shall be performed in accordance with protocols described in "Methods for Measuring the Acute Toxicity of Effluent to Freshwater and Marine Organisms", EPA/600/4-90/027. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are 0.42%, 0.56%, 0.75%, 1.0%, and 1.3% (See the CPP). The low-flow effluent concentration (critical dilution) is defined as 1% effluent. The requirement for acute WET tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species *Daphnia pulex* and the Fathead minnow (*Pimephales promelas*) are representative of organisms indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The WET testing frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.*

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen, conductivity, and alkalinity shall be reported according to EPA-821-R-02-012, October 2002 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further WET testing studies, Toxicity Reduction Evaluation (TRE) and/or effluent limits if WET testing data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

Administrative Records

The permittee has not yet performed any acute whole effluent toxicity testing.

16. SAMPLE TYPE AND FREQUENCY.

Outfall 001:

Regulations require permits to establish monitoring requirements to yield data representative of the monitored activity [40 CFR Part 122.48(b)] and to ensure compliance with permit limitations [40 CFR Part 122.44(i)(1)]. Requirements for sample type and sampling frequency have been based on the current discharge permit for Flow, TSS, NH₃-N, FCB, TRC, and WET. Monitoring frequency for TP and NO₃ + NO₂ - N was set at once/quarter based on the minimum required frequency specified in sections 5.36 and 5.37 of the CPP. The permit writer conducted a review of effluent data from the past 24 months for all parameters and determined that CBOD₅, DO, and pH were eligible for monitoring frequency reductions. The ratio of the long term average of the data for each of these parameters to the

DRAFT

monthly average permit limit was calculated. This determined what frequency reduction each of these parameters were eligible for based on section 4.8.2 of the CPP. This monitoring frequency reduction for CBOD5, DO, and pH is being granted only once and no further reductions for these parameters will be granted (See Condition No. 9 of Part II of the permit).

Parameter	Previous Permit		Final Permit	
	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
Flow	once/day	totalizing meter	once/day	totalizing meter
CBOD5	three/week	6-hr Composite	two/week	composite ¹
TSS	three/week	6-hr Composite	three/week	composite ¹
NH3-N	three/week	6-hr Composite	three/week	composite ¹
DO	three/week	grab	once/week	grab
FCB	three/week	grab	three/week	grab
TRC	three/week	grab	three/week	grab
TP	n/a	n/a	once/quarter	grab
NO ₃ + NO ₂ - N	n/a	n/a	once/quarter	grab
pH	three/week	grab	once/week	grab
Chronic WET testing	once/quarter	24-hr composite	once/quarter	composite ²

1 “6-hr composite” changed to “composite” for CBOD5, TSS, and NH3-N in accordance with revised definition of “composite” in Part IV of the permit.

2 Composite sample for WET testing is defined in Part II.8.3.d of the permit as a minimum of 12 subsamples gathered at equal time intervals during a 24-hr period.

Outfall 002:

Requirements for sample type and sampling frequency have been based on the current NPDES permit. The requirements for Outfall 001 have remain unchanged. Sample type and sampling frequency for Outfall 002 have been based on the requirements for Outfall 001.

17. STORMWATER REQUIREMENTS

The facility has obtained a No Exposure Certification Permit under the tracking number ARR000189.

DRAFT

18. PERMIT COMPLIANCE.

A Schedule of Compliance has not been included in this permit. Compliance with all permit requirements is required on the effective date of the permit.

19. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis and report the results monthly. The monitoring results will be available to the public.

20. SOURCES.

The following sources were used to modify the permit:

- A. *Modification application received 2/12/2013 with additional information received on 4/05/2013.*
- B. Arkansas Water Quality Management Plan (WQMP).
- C. APCEC Regulation No. 2.
- D. APCEC Regulation No. 3.
- E. APCEC Regulation No. 6.
- F. 40 CFR Parts 122, 125, 133 and 403.
- G. Discharge permit file AR0021971.
- H. Discharge Monitoring Reports (DMRs).
- I. "Arkansas Water Quality Inventory Report 2008 (305B)", ADEQ.
- J. Continuing Planning Process (CPP).
- K. Technical Support Document For Water Quality-based Toxic Control.
- L. No Exposure General Stormwater Permit No. ARR000189.
- M. Inspection Report dated 11/30/2011.
- N. Sludge measurement report received on 5/17/2012.
- O. *Email dated 4/05/2013 from Jerome Alford to Chris Randall, containing design calculations of the chlorine contact chamber.*
- P. *MultiSMP Model dated 4/16/2013*
- Q. *"Technology Review of Constructed Wetlands, Subsurface Flow Constructed Wetlands for Greywater and Domestic Wastewater Treatment" GIZ, dated February 2011.*
- R. *Email dated 8/29/2013, from Mike Tillman to Morteza Shafii.*

21. PUBLIC NOTICE.

The public notice describes the procedures for the formulation of final determinations and shall provide for a public comment period of 30 days. During this period, any interested persons may submit written comments on the permit and may request a public hearing to clarify issues involved in the permitting decision. A request for a public hearing shall be in writing and shall state the nature of the issue(s) proposed to be raised in the hearing.

DRAFT

Page 28 of Fact Sheet
Permit Number: AR0021971
AFIN: 18-00110

A copy of the permit and public notice will be sent via email to the Corps of Engineers, the Regional Director of the U.S. Fish and Wildlife Service, the Department of Arkansas Heritage, the EPA, and the Arkansas Department of Health.

22. POINT OF CONTACT.

For additional information, contact:

Chris Randall
Permits Branch, Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317
Telephone: (501) 682-0617

DRAFT

Permit Number: AR0021971
AFIN: 18-00110

AUTHORIZATION TO DISCHARGE WASTEWATER UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. § 1251 et seq.),

The applicant's mailing address is:

City of Marion
P.O. Box 717
Marion, AR 72364

The facility address is:

City of Marion
5054 Hardin Road
Marion, AR 72364

is authorized to discharge treated municipal wastewater from a facility located as follows: west of Highway 118 just south of Union Pacific Railroad in Crittenden County, Arkansas.

Latitude: 35° 11' 25"; Longitude: 90° 13' 42"

to receiving waters named:

Outfall 001: Fifteen Mile Bayou to Black Fish Bayou, thence to the St. Francis River in Segment 5A of the St. Francis River Basin.

Outfall 002: from the plant site through a pipeline to the Mississippi River in Segment 6C of the Mississippi River Basin.

The outfall is located at the following coordinates:

Outfall 001: Latitude: 35° 11' 25"; Longitude: 90° 14' 15"

Outfall 002: Latitude: 35° 15' 06"; Longitude: 90° 06' 06"

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in this permit. Per Part III.D.10, the permittee must re-apply on or before 180 days prior to the expiration date for permit coverage past the expiration date.

Original Effective Date:	July 1, 2012
Original Issue Date:	June 12, 2012
Modification Effective Date:	
Expiration Date:	June 30, 2017

Ryan Benefield, P.E.
Deputy Director
Arkansas Department of Environmental Quality

Modification Issue Date

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001 - treated municipal wastewater.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	200	15	22.5	two/week ³	composite
Total Suspended Solids (TSS)	267	20	30	three/week	composite
Ammonia Nitrogen (NH3-N)					
(April - October)	32	2.4	5.9	three/week	composite
(November - March)	90	6.7	12	three/week	composite
Dissolved Oxygen (DO)					
(May-Oct)	N/A	4.0, (Inst. Min.)		once/week ³	grab
(Nov-Apr)	N/A	6.0, (Inst. Min.)		once/week ³	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Residual Chlorine (TRC) ¹	N/A	<0.1 mg/l (Inst. Max.)		three/week	grab
Total Phosphorus (TP)	Report	Report	Report	once/quarter	grab
Nitrate + Nitrite Nitrogen (NO3 + NO2-N)	Report	Report	Report	once/quarter	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/week ³	grab
Chronic WET Testing ²	N/A	Report		once/quarter	composite
<u>Pimephales promelas (Chronic)²</u>		<u>7-Day Average</u>			
Pass/Fail Lethality (7-day NOEC) TLP6C		Report (Pass=0/Fail=1)		once/quarter	composite
Pass/Fail Growth (7-day NOEC)TGP6C		Report (Pass=0/Fail=1)		once/quarter	composite
Survival (7-day NOEC) TOP6C		Report %		once/quarter	composite
Coefficient of Variation (Growth) TQP6C		Report %		once/quarter	composite
Growth (7-day NOEC) TPP6C		Report %		once/quarter	composite

DRAFT

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
<u>Ceriodaphnia dubia (Chronic)²</u> Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC)TGP3B Survival (7-day NOEC) TOP3B Coefficient of Variation (Reproduction) TQP3B Reproduction (7-day NOEC) TPP3B			<u>7-Day Average</u> Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %	once/quarter once/quarter once/quarter once/quarter once/quarter	composite composite composite composite composite

- 1 See Condition No. 7 of Part II. (TRC Condition).
- 2 See Condition No. 9 of Part II (WET Testing Condition).
- 3 See Condition No. 11 of Part II (Monitoring frequency reduction for CBOD5, DO, and pH).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen as defined in Part IV of this permit.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples shall be taken after the discharge from the final treatment unit (chlorine disinfection).

All and each unauthorized Sanitary Sewer Overflow (SSO) must be reported to ADEQ. See Condition No. 5 of Part II.

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 002* - treated municipal wastewater.

During the period beginning on the effective date of the modification and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Monthly Avg.	7-Day Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Biochemical Oxygen Demand (BOD5)	400	30	45	two/week	composite
Total Suspended Solids (TSS)	1200	90	135	three/week	composite
Dissolved Oxygen (DO)	N/A	2.0, (Monthly Avg. Min.)		once/week ³	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
(Apr-Sept)	N/A	200	400	three/week	grab
(Oct-Mar)	N/A	1000	2000	three/week	grab
Total Residual Chlorine (TRC) ¹	N/A	<0.1 mg/l (Inst. Max.)		three/week	grab
Total Phosphorus (TP)	Report	Report	Report	once/quarter	grab
Nitrate + Nitrite Nitrogen (NO3 + NO2-N)	Report	Report	Report	once/quarter	grab
pH	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	once/week ³	grab
Acute Wet Testing ²	N/A	Report		once/quarter	composite
<u>Pimephales promelas (Acute)</u> ² Pass/Fail Lethality (48-Hr NOEC) TEM6C Survival (48-Hr NOEC) TOM6C Coefficient of Variation (48-Hr NOEC) TQM6C		48-Hr Minimum Report (Pass=0/Fail=1) Report% Report%		once/quarter once/quarter once/quarter	composite composite composite
<u>Daphnia pulex (Acute)</u> ² Pass/Fail Lethality (48-Hr NOEC) TEM3D Survival (48-Hr NOEC) TOM3D Coefficient of Variation (48-Hr NOEC) TQM3D		48-Hr Minimum Report (Pass=0/Fail=1) Report% Report%		once/quarter once/quarter once/quarter	composite composite composite

* See Condition No. 8 of Part II (New Outfall Condition).
 1 See Condition No. 7 of Part II (TRC Condition).
 2 See Condition No. 10 of Part II (WET Testing Condition).
 3 See Condition No. 11 of Part II (Monitoring frequency reduction for (DO, and pH).

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 4 of Part IA

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen as defined in Part IV of this permit.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples shall be taken after the discharge from the final treatment unit (chlorine disinfection).

All and each unauthorized Sanitary Sewer Overflow (SSO) must be reported to ADEQ. See Condition No. 5 of Part II.

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 1 of Part IB

SECTION B. PERMIT COMPLIANCE

Compliance is required on the effective date of the permit.

PART II OTHER CONDITIONS

1. The operator of this wastewater treatment facility shall be licensed as Class II by the State of Arkansas in accordance with APCEC Regulation No. 3.
2. For publicly owned treatment works, the 30-day average percent removal for Carbonaceous Biochemical Oxygen Demand (CBOD5) or Biochemical Oxygen Demand (BOD5) and Total Suspended Solids shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR Part 133.102, as adopted by reference in APCEC Regulation No. 6. The permittee must monitor the influent and effluent CBOD5 or BOD5 and TSS at least once per year and calculate the percent removal to ensure compliance with the required 85 percent removal. This information must be maintained on site and provided to Department personnel upon request.
3. In accordance with 40 CFR Parts 122.62 (a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.
4. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the Permits Section of the Water Division of the ADEQ for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or approved in accordance with 40 CFR Part 136.5; and
- All associated devices are installed, calibrated, and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period.

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 2 of Part H

ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

5. Sanitary Sewer Overflow (SSO):

A. An overflow is any spill, release or diversion of sewage from a sanitary sewer collection system, including:

1. An overflow that results in a discharge to waters of the state; and
2. An overflow of wastewater, including a wastewater backup into a building (other than a backup caused solely by a blockage or other malfunction in a privately owned sewer or building lateral), even if that overflow does not reach waters of the state.

B. Immediate Reporting

All overflows shall be reported to the Enforcement Branch of the Water Division by telephone (501-682-0638), facsimile (501-682-0910), or by using the Department web site at waterenfsso@adeq.state.ar.us within 24 hours from the time the permittee becomes aware of the circumstance.

At a minimum the report shall identify:

1. The location(s) of overflow;
2. The receiving water (If there is one);
3. The duration of overflow;
4. Cause of overflow; and
5. The estimated volume of overflow (MG).

C. Discharge Monitoring Reports (DMRs)

The permittee shall report every month all overflows with the Discharge Monitoring Report (DMR) submittal. These reports shall be summarized and reported in tabular format with the minimum following information. The permittee may use the ADEQ Forms which may be obtained from the following web sites:

http://www.adeq.state.ar.us/water/branch_permits/pdfs_forms/sso_tabular_report.pdf
or http://www.adeq.state.ar.us/water/branch_enforcement/forms/sso_report.asp

1. The location(s) of overflow;
2. The receiving water (If there is one);
3. The duration of overflow;
4. Cause of overflow;
5. The estimated volume of overflow (MG);

DRAFT

Permit Number: AR0021971

AFIN: 18-00110

Page 3 of Part II

6. A description of the sewer system component from which the release occurred (e.g., manhole, constructed overflow pipe, crack in pipe);
7. The estimated date and time when the overflow began and stopped or will be stopped;
8. The cause or suspected cause of the overflow;
9. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
10. If reasonably made, an estimate of the number of persons who came into contact with wastewater from the overflow; and
11. Steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps.

6. Contributing Industries and Pretreatment Requirements

A. The following pollutants may not be introduced into the treatment facility:

- (1) pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21;
- (2) pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, unless the works are specifically designed to accommodate such discharges;
- (3) solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference* or Pass Through**;
- (4) any pollutant, including oxygen demanding pollutants (e.g., BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Pass Through** or Interference* with the POTW;
- (5) heat in amounts which will inhibit biological activity in the POTW resulting in Interference*, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40 deg. C (104 deg. F) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits;
- (6) Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference* or Pass Through**;
- (7) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
- (8) Any trucked or hauled pollutants, except at discharge points designated by the POTW.

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 4 of Part II

- B. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Act, including any requirements established under 40 CFR Part 403.
- C. The permittee shall provide adequate notice to the Department of the following:
- (1) any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 or 306 of the Act if it were directly discharging those pollutants; and
 - (2) any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

* According to 40 CFR Part 403.3(k) the term *Interference* means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

** According to 40 CFR 403.3(p) the term *Pass Through* means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 5 of Part II

7. After dechlorination and prior to final disposal, the effluent shall contain NO MEASURABLE TRC at any time. NO MEASURABLE will be defined as no detectable concentration of TRC as determined by any approved method established in 40 CFR Part 136 as less than 0.1 mg/l. Thus, the “no measurable TRC concentration” for chlorine becomes the permit limit. The effluent limitation for TRC is the instantaneous maximum and cannot be averaged for reporting purposes. TRC shall be measured within fifteen (15) minutes of sampling.
8. Until the pipeline is completed and the discharge flow is routed to the new pipeline, the facility will report “no discharge” on the DMRs for Outfall 002. After the switchover to the pipeline occurs and the facility ceases discharging to Fifteen Mile Bayou, the permittee shall submit a report to the Department (discharge permit section of water division) indicating when switchover occurred and Outfall 001 ceased discharging. Beginning in the month after the submittal of this report, the permittee shall no longer be required to submit DMRs for Outfall 001 and this outfall will be removed from the permit through a minor modification to the permit.
9. WHOLE EFFLUENT TOXICITY TESTING (7-DAY CHRONIC NOEC FRESHWATER)

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S):	001
REPORTED ON DMR AS FINAL OUTFALL:	001
CRITICAL DILUTION (%):	88
EFFLUENT DILUTION SERIES (%):	28-37-50-66-88
TESTING FREQUENCY	once/quarter
COMPOSITE SAMPLE TYPE:	Defined at PART I
TEST SPECIES/METHODS:	40 CFR Part 136

Ceriodaphnia dubia chronic static renewal survival and reproduction test, Method 1002.0, EPA-821-R-02-013, or the most recent update thereof. This test should be terminated when 60% of the surviving females in the control produce three broods or at the end of eight days, whichever comes first.

DRAFT

Pimephales promelas (Fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA-821-R-02-013, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is herein defined as the greatest effluent dilution at and below which toxicity (lethal or sub-lethal) that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution. Chronic sub-lethal test failure is defined as a demonstration of a statistically significant sub-lethal effect (i.e., growth or reproduction) at test completion to a test species at or below the critical dilution.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

2. PERSISTENT LETHAL and/or SUB-LETHAL EFFECTS

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal and/or sub-lethal effects at or below the critical dilution. The purpose of additional tests (also referred to as 'retests' or confirmation tests) is to determine the duration of a toxic event. A test that meets all test acceptability criteria and demonstrates significant toxic effects does not need additional confirmation. Such testing cannot confirm or disprove a previous test result.

If a frequency reduction, as specified in Item 6, has been granted and any subsequent valid test demonstrates significant lethal or sub-lethal effects to a test species at or below the critical dilution, the frequency of testing for that species is automatically increased to once per quarter for the life of the permit. In addition:

- a. Part I Testing Frequency Other Than Monthly
 - i. The permittee shall conduct a total of three (3) additional tests for any species that demonstrates significant toxic effects at or below the critical dilution. The additional tests shall be conducted monthly during the next three consecutive months. If testing on a quarterly basis, the permittee may substitute one of the additional tests in lieu of one routine toxicity test. A full report shall be

procedures outlined in Item 4 of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.

- ii. **IF LETHAL EFFECTS HAVE BEEN DEMONSTRATED** If any of the additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests. A TRE required based on lethal effects should consider any sub-lethal effects as well.
- iii. **IF SUB-LETHAL EFFECTS ONLY HAVE BEEN DEMONSTRATED** If any two of the three additional tests demonstrates significant sub-lethal effects at 75% effluent or lower, the permittee shall initiate the Sub-Lethal Toxicity Reduction Evaluation (TRE_{SL}) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the Sub-Lethal Effects TRE initiation date will be the test completion date of the first failed retest. A TRE may be also be required for failure to perform the required retests.
- iv. The provisions of Item 2.a.i. are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section when any two of three consecutive monthly toxicity tests exhibit significant toxic effects at or below the critical dilution. A TRE may also be required due to a demonstration of intermittent lethal and/or sub-lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 8 of Part II

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- ii. The mean number of Ceriodaphnia dubia neonates produced per surviving female in the control (0% effluent) must be 15 or more.
- iii. 60% of the surviving control females must produce three broods. The mean dry weight of surviving Fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- iv. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: the young of surviving females in the Ceriodaphnia dubia reproduction test; the growth and survival endpoints of the Fathead minnow test.
- v. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal or sub-lethal effects are exhibited for: the young of surviving females in the Ceriodaphnia dubia reproduction test; the growth and survival endpoints of the Fathead minnow test.
- vi. If a test passes, yet the percent coefficient of variation between replicates is greater than 40% in the control (0% effluent) and/or in the critical dilution for: the young of surviving females in the Ceriodaphnia dubia reproduction test; the growth and survival endpoints of the Fathead minnow test, the test is determined to be invalid. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.
- vii. If a test fails, test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%.
- viii. A Percent Minimum Significant Difference (PMSD) range of 13 - 47 for Ceriodaphnia dubia reproduction;
- ix. A PMSD range of 12 - 30 for Fathead minnow growth.

b. Statistical Interpretation

- i. For the Ceriodaphnia dubia survival test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be Fisher's Exact Test as described in EPA/821/R-02-013 or the most recent update thereof.
- ii. For the Ceriodaphnia dubia reproduction test and the Fathead minnow larval survival and growth test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/821/R-02-013 or the most recent update thereof.
- iii. If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report a survival NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
 - (A) toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
 - (B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.
- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:

DRAFT

- (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
- (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 7 days);
- (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 4 below; and
- (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect a minimum of three flow-weighted composite samples from the outfall(s) listed at Item 1.a above. Unless otherwise stated in this section, a composite sample for WET shall consist of a minimum of 12 subsamples gathered at equal time intervals during a 24-hour period.
- ii. The permittee shall collect second and third composite samples for use during 24-hour renewals of each dilution concentration for each test. The permittee must collect the composite samples such that the effluent samples, on use, are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on a regular or intermittent basis.
- iii. The permittee must collect all three flow-weighted composite samples within the monitoring period. Second and/or third composite samples shall not be collected into the next monitoring period; such tests will be determined to be invalid. Monitoring period definitions are listed in Part IV.
- iv. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 72 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to between 0 and 6 degrees

Centigrade during collection, shipping, and/or storage.

- v. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 4 of this section.
- vi. MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in item 1.a. above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.
- vii. If chlorination is part of the treatment process, the permittee shall not allow the sample to be dechlorinated at the laboratory. At the time of sample collection the permittee shall measure the TRC of the effluent. The measured concentration of TRC for each sample shall be included in the lab report submitted by the permittee.

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/821/R-02-013, or the most current publication, for every valid or invalid toxicity test initiated whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.7 of this permit. The permittee shall submit full reports. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. A valid test for each species must be reported on the DMR during each reporting period specified in PART I of this permit unless the permittee is

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 12 of Part II

performing a TRE which may increase the frequency of testing and reporting. Only ONE set of WET test data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST lethal and sub-lethal effects results for each species during the reporting period. The full reports for all invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for Agency review.

- c. The permittee shall submit the results of each valid toxicity test on the subsequent monthly DMR for that reporting period in accordance with PART III.D.4 of this permit, as follows below. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.

i. Pimephales promelas (Fathead minnow)

- (A) If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TLP6C
- (B) Report the NOEC value for survival, Parameter No. TOP6C
- (C) Report the NOEC value for growth, Parameter No. TPP6C
- (D) If the NOEC for growth is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TGP6C
- (E) Report the highest (critical dilution or control) Coefficient of Variation for growth, Parameter No. TQP6C

ii. Ceriodaphnia dubia

- (A) If the NOEC for survival is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TLP3B
- (B) Report the NOEC value for survival, Parameter No. TOP3B
- (C) Report the NOEC value for reproduction, Parameter No.

TPP3B

- (D) If the NOEC for reproduction is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TGP3B
- (E) Report the higher (critical dilution or control) Coefficient of Variation for reproduction, Parameter No. TQP3B

5. TOXICITY REDUCTION EVALUATIONS (TREs)

TREs for lethal and sub-lethal effects are performed in a very similar manner. EPA Region 6 is currently addressing TREs as follows: a sub-lethal TRE (TRE_{SL}) is triggered based on three sub-lethal test failures while a lethal effects TRE (TRE_L) is triggered based on only two test failures for lethality. In addition, EPA Region 6 will consider the magnitude of toxicity and use flexibility when considering a TRE_{SL} where there are no effects at effluent dilutions of 75% or lower.

- a. Within ninety (90) days of confirming persistent toxicity, the permittee shall submit a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The goal of the TRE is to maximally reduce the toxic effects of effluent at the critical dilution and includes the following:
 - i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents 'Methods for Aquatic Toxicity Identification

DRAFT

Permit Number: AR0021971

AFIN: 18-00110

Page 14 of Part II

Evaluations: Phase I Toxicity Characterization Procedures' (EPA-600/6-91/003) and 'Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I' (EPA-600/6-91/005F), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents 'Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity' (EPA/600/R-92/080) and 'Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity' (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (703) 487-4650, or by writing:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161

- ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 48 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and

- iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).

- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.

- c. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
 - 1. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
 - 2. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - 3. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant toxicity at the critical dilution.

A copy of the TRE Activities Report shall also be submitted to the state agency.

- d. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming toxicity in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant toxicity at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.

A copy of the Final Report on Toxicity Reduction Evaluation Activities shall also be submitted to the state agency.

- e. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).

DRAFT

6. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters or first twelve consecutive months (in accordance with Item 1.a.) of testing for one or both test species, with no lethal or sub-lethal effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the Ceriodaphnia dubia).
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal and sub-lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance System section to update the permit reporting requirements.
- c. SUB-LETHAL OR SURVIVAL FAILURES - If any test fails the survival or sub-lethal endpoint at any time during the life of this permit, three monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.

Any monitoring frequency reduction granted applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.

10. WHOLE EFFLUENT TOXICITY TESTING (48-HOUR ACUTE NOEC FRESHWATER)

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S): 002

REPORTED ON DMR AS FINAL OUTFALL: 002

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 17 of Part II

CRITICAL DILUTION (%):	1%
EFFLUENT DILUTION SERIES (%):	0.42%, 0.56%, 0.75%, 1.0%, 1.3%
TESTING FREQUENCY	once/quarter
COMPOSITE SAMPLE TYPE:	Defined at PART I
TEST SPECIES/METHODS:	40 CFR Part 136

Daphnia pulex acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

Pimephales promelas (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is defined as the greatest effluent dilution at and below which toxicity that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Acute test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

2. PERSISTENT LETHALITY

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal effects at or below the critical dilution. Significant lethal effects are herein defined as a statistically significant difference at the 95% confidence level between the survival of the appropriate test organism in a specified effluent dilution and the control (0% effluent). The purpose of additional tests (also referred to as 'retests' or confirmation tests) is to determine the duration of a toxic event. A test that meets all test acceptability criteria and demonstrates significant toxic effects does not need additional confirmation.

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 18 of Part-II

Such testing cannot confirm or disprove a previous test result.

If any valid test demonstrates significant lethal effects to a test species at or below the critical dilution, the frequency of testing for this species is automatically increased to once per quarter with no option for frequency reduction.

a. Part I Testing Frequency Other Than Monthly

- i. The permittee shall conduct a total of three (3) additional tests for any species that demonstrates significant lethal effects at or below the critical dilution. The additional tests shall be conducted monthly during the next three consecutive months. If testing on a quarterly basis, the permittee may substitute one of the additional tests in lieu of one routine toxicity test. A full report shall be prepared for each test required by this section in accordance with procedures outlined in Item 4 of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.
- ii. If any of the additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may be also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.
- iii. The provisions of Item 2.a are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section when any two of three consecutive monthly toxicity tests exhibit significant lethal effects at or below the critical dilution. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

DRAFT

Permit Number: AR0021971

AFIN: 18-00110

Page 19 of Part II

- i. Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- ii. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: Daphnia pulex survival test; and Fathead minnow survival test.
- iii. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for: Daphnia pulex survival test; and Fathead minnow survival test.
- iv. If a test passes, yet the percent coefficient of variation between replicates is greater than 40% in the control (0% effluent) and/or in the critical dilution for: the survival in the Daphnia pulex survival test or the survival endpoint of the Fathead minnow test, the test is determined to be invalid. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.
- v. If a test fails, test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%.

b. Statistical Interpretation

For the Daphnia pulex survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA-821-R-02-012 or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;

(A) toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and

DRAFT

Permit Number: AR0021971

AFIN: 18-00110

Page 20 of Part II

(B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.

ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:

(A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;

(B) the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);

(C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 4 below; and

(D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

i. The permittee shall collect two flow-weighted composite samples from the outfall(s) listed at Item 1.a above. Unless otherwise stated in this section, a composite sample for WET shall consist of a minimum of 12 subsamples gathered at equal time intervals during a 24-hour period.

ii. The permittee shall collect a second composite sample for use during the 24-hour renewal of each dilution concentration for both tests. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to between 0 and 6 degrees Centigrade during collection, shipping, and/or storage.

iii. The permittee must collect both flow-weighted composite samples within the monitoring period. The second composite sample shall not be collected into the next monitoring period; such tests will be determined to be invalid. Monitoring period definitions are listed in Part IV.

DRAFT

Permit Number: AR0021971

AFIN: 18-00110

Page 21 of Part II

- iv. The permittee must collect the composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on a regular or intermittent basis.
- v. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 4 of this section.

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA-821-R-02-012, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.7 of this permit. The permittee shall submit full reports. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. A valid test for each species must be reported on the DMR during each reporting period specified in PART I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of WET test data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. The full report for all invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for Agency review.
- c. The permittee shall report the following results of each valid toxicity test on the subsequent monthly DMR for that reporting period in accordance with PART III.D.4 of this permit. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.
 - i. Pimephales promelas (Fathead minnow)
 - (A) If the No Observed Effect Concentration (NOEC) for survival is less than or equal to the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.

DRAFT

(B) Report the NOEC value for survival, Parameter No. TOM6C.

(C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.

ii. Daphnia pulex

(A) If the NOEC for survival is less than or equal to the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D

(B) Report the NOEC value for survival, Parameter No. TOM3D.

(C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

5. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days of confirming lethality in the retests, the permittee shall submit a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The TRE Action Plan shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:
- i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA-600/6-91/003) or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification

Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (703) 487-4650, or by writing:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161

- ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 24 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
 - iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
 - c. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
 - i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;

DRAFT

Permit Number: AR0021971

AFIN: 18-00110

Page 24 of Part II

- ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - iii. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.
- d. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.
- e. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).

6. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters or first twelve consecutive months (in accordance with Item 1.a.) of testing for one or both test species, with no lethal effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the Daphnia pulex).
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance System section to update the permit reporting requirements.

DRAFT

Permit Number: AR0021971
AFIN: 18-00110
Page 25 of Part II

- c. SURVIVAL FAILURES - If any test fails the survival endpoint at any time during the life of this permit, three monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.
 - d. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.
11. This permit includes a reduced monitoring frequency for CBOD5, DO, and pH. No further monitoring frequency reduction for these parameters will be granted.

PART III STANDARD CONDITIONS

SECTION A – GENERAL CONDITIONS

1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. **Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.**

2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than twenty-five thousand dollars (\$25,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- A. Violation of any terms or conditions of this permit; or
- B. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- C. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- D. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- E. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part III.A.11 herein.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

4. Toxic Pollutants

Notwithstanding Part III.A.3, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, or prohibitions established under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Civil and Criminal Liability

Except as provided in permit conditions for “Bypass of Treatment Facilities” (Part III.B.4), and “Upset” (Part III.B.5), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statutes or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 et seq.).

6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Clean Water Act.

7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

8. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Applicable Federal, State or Local Requirements

Permittees are responsible for compliance with all applicable terms and conditions of this permit. Receipt of this permit does not relieve any operator of the responsibility to comply with any other applicable federal such as endangered species, state or local statute, ordinance or regulation.

11. Permit Fees

The permittee shall comply with all applicable permit fee requirements for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5(d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

A. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

B. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of

treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

4. Bypass of Treatment Facilities

A. Bypass not exceeding limitation

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.B.4.b and 4.c.

B. Notice

1. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
2. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part III.D.6 (24-hour notice).

C. Prohibition of bypass

1. Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and
 - (c) The permittee submitted notices as required by Part III.B.4.b.
2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part III.B.4.c.(1).

5. Upset Conditions

- A. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part III.B.5.b of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- B. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
1. An upset occurred and that the permittee can identify the specific cause(s) of the upset;
 2. The permitted facility was at the time being properly operated.
 3. The permittee submitted notice of the upset as required by Part III.D.6; and
 4. The permittee complied with any remedial measures required by Part III.B.3.
- C. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of waste waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. Written approval must be obtained from the ADEQ prior to removal of substances. Additionally, the permittee shall give at least 120 days prior notice to the Director of any change planned in the permittee's sludge disposal practice or land use applications, including types of crops grown (if applicable). Produced sludge shall be disposed of by land application only when meeting the following criteria:

- A. Sewage sludge from treatment works treating domestic sewage (TWTDS) must meet the applicable provisions of 40 CFR Part 503; and
- B. The sewage sludge has not been classified as a hazardous waste under state or federal regulations.

7. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

SECTION C – MONITORING AND RECORDS

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharge shall be monitored.

2. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

Calculated Flow Measurement

For calculated flow measurements that are performed in accordance with either the permit requirements or a Department approved method (i.e., as allowed under Part II.3), the +/- 10% accuracy requirement described above is waived. This waiver is only applicable when the method used for calculation of the flow has been reviewed and approved by the Department.

3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof

shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

5. Reporting of Monitoring Results

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form provided by the Department or other form/method approved in writing by the Department (e.g., electronic submittal of DMR once approved). Monitoring results obtained during the previous monitoring period shall be summarized and reported on a DMR form postmarked no later than the 25th day of the month or submitted electronically by 6:00 p.m. of the 25th (after NETDMR is approved), following the completed reporting period beginning on the effective date of the permit. When mailing the DMRs, duplicate copies of the forms signed and certified as required by Part III.D.11 and all other reports required by Part III.D, shall be submitted to the Director at the following address:

Enforcement Branch
Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

8. Record Contents

Records and monitoring information shall include:

- A. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- B. The individuals(s) who performed the sampling or measurements;
- C. The date(s) and time analyses were performed;
- D. The individual(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The measurements and results of such analyses.

9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- D. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

SECTION D – REPORTING REQUIREMENTS

1. Planned Changes

The permittee shall give notice within 180 days and provide plans and specification (if applicable) to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. In no case are any new connections, increased flows, removal of substances, or significant changes in influent quality permitted that cause violation of the effluent limitations specified herein.

2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part III.C.5. **Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.**

5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

6. Twenty-four Hour Report

A. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:

1. A description of the noncompliance and its cause;
2. The period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
3. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

B. The following shall be included as information which must be reported within 24 hours:

1. Any unanticipated bypass which exceeds any effluent limitation in the permit;
2. Any upset which exceeds any effluent limitation in the permit and
3. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the Enforcement Section of the Water Division of the ADEQ.

C. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the Enforcement Section of the Water Division of the ADEQ.

7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Parts III.D.4, 5, and 6, at the time monitoring reports are submitted. The reports shall contain the information listed at Part III.D.6.

8. Changes in Discharge of Toxic Substances for Industrial Dischargers

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- A. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(1); or
- B. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(2).

9. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

10. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

11. Signatory Requirements

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

A. All **permit applications** shall be signed as follows:

- 1. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:

- (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
 - (b) The manager of one or more manufacturing, production, or operation facilities, provided: the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
2. For a partnership or sole proprietorship: by a general partner or proprietor, respectively; or
 3. For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
 - (a) The chief executive officer of the agency, or
 - (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- B. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
1. The authorization is made in writing by a person described above.
 2. The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
 3. The written authorization is submitted to the Director.
- C. Certification. Any person signing a document under this section shall make the following certification:
- “I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my

knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

12. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.

13. Penalties for Falsification of Reports

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part III.A.2. and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 et seq.).

14. Applicable Federal, State or Local Requirements

Permittees are responsible for compliance with all applicable terms and conditions of this permit. Receipt of this permit does not relieve any operator of the responsibility to comply with any other applicable federal, state, or local statute, ordinance, policy, or regulation.

PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act and 40 CFR 122.2 shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. **“Act”** means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
2. **“Administrator”** means the Administrator of the U.S. Environmental Protection Agency.
3. **“APCEC”** means the Arkansas Pollution Control and Ecology Commission.
4. **“Applicable effluent standards and limitations”** means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
5. **“Applicable water quality standards”** means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
6. **“Bypass”** As defined at 122.41(m).
7. **“Composite sample”** is a mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing a minimum of 4 effluent portions collected at equal time intervals (but not closer than one hour apart) during operational hours, within the 24-hour period, and combined proportional to flow or a sample collected at more frequent intervals proportional to flow over the 24-hour period.
8. **“Daily Discharge”** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.
 - A. **Mass Calculations:** For pollutants with limitations expressed in terms of mass, the “daily discharge” is calculated as the total mass of pollutant discharged over the sampling day.
 - B. **Concentration Calculations:** For pollutants with limitations expressed in other units of measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the day.
9. **“Daily Maximum”** discharge limitation means the highest allowable “daily discharge” during the calendar month. The 7-day average for Fecal Coliform Bacteria (FCB) or E-Coli is the geometric mean of the values of all effluent samples collected during the calendar week in colonies per 100 ml.
10. **“Department”** means the Arkansas Department of Environmental Quality (ADEQ).
11. **“Director”** means the Director of the Arkansas Department of Environmental Quality.
12. **“Dissolved oxygen limit”**, shall be defined as follows:
 - A. When limited in the permit as a minimum monthly average, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
 - B. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.

13. **“E-Coli”** a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For E-Coli, report the monthly average as a 30-day geometric mean in colonies per 100 ml.
14. **“Fecal Coliform Bacteria (FCB)”**a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
15. **“Grab sample”** means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
16. **“Industrial User”** means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
17. **“Instantaneous Maximum”** when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.
18. **“Instantaneous Minimum”** an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
19. **“Monthly average”** means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. For Fecal Coliform Bacteria (FCB) or E-Coli, report the monthly average, (see 30-day average below).
20. **“National Pollutant Discharge Elimination System”** means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
21. **“POTW”** means a Publicly Owned Treatment Works.
22. **“Severe property damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
23. **“Sewage sludge”** means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and stormwater runoff that are discharged to or otherwise enter a POTW.
24. **“7-day average”** Also known as Average weekly. means the highest allowable average of “daily discharges” over a calendar week, calculated as the sum of all “daily discharges” measured during a calendar week divided by the number of “daily discharges” measured during that week.
25. **“Treatment works”** means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
26. **“Upset”** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond

the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless of improper operations.

27. **“Visible sheen”** means the presence of a film or sheen upon or a discoloration of the surface of the discharge. A sheen can also be from a thin glistening layer of oil on the surface of the discharge.
28. **“MGD”** shall mean million gallons per day.
29. **“mg/l”** shall mean milligrams per liter or parts per million (ppm).
30. **“µg/l”** shall mean micrograms per liter or parts per billion (ppb).
31. **“cfs”** shall mean cubic feet per second.
32. **“ppm”** shall mean parts per million.
33. **“s.u.”** shall mean standard units.
34. **“Weekday”** means Monday – Friday.
35. **Monitoring and Reporting:**

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25th of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25th of the month following the monitoring period end date.

A. MONTHLY:

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

B. BI-MONTHLY:

is defined as two (2) calendar months or any portion of 2 calendar months for monitoring requirement frequency of once/2 months or more frequently.

C. QUARTERLY:

1. is defined as a **fixed calendar quarter** or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or
2. is defined as a **fixed three month period** (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

D. SEMI-ANNUAL:

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

E. ANNUAL or YEARLY:

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.