

Gage, Hannah

From: Gilliam, Allen
Sent: Monday, December 12, 2016 12:58 PM
To: chuck jones
Cc: Gage, Hannah; Yates, Adam; McWilliams, Carrie; Leamons, Bryan; arkadelphia david green; Arkadelphia - Brenda Gills
Subject: AR0020605_Danfoss ARP001040 Dec 2016 quarterly Pretreatment report_20161216
Attachments: 20161212102219935.pdf

Chuck,

Danfoss' quarterly Pretreatment report was electronically received, reviewed, deemed complete and compliant with the reporting requirements in 40 CFR 403.12(e) and more specifically in compliance with the Federal Metal Finishing standards in 40 CFR 433.17. There are no further requirements deemed necessary at this time.

Please submit Danfoss' reports to Adam Yates, Permit Engineer @ yates@adeq.state.ar.us in the future.

Thank you for your timely report.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: David Green, Arkadelphia Utilities Manager

E/NPDES/NPDES/Pretreatment/Reports

From: Jones Chuck [<mailto:Chuck.Jones@danfoss.com>]
Sent: Monday, December 12, 2016 11:57 AM
To: Gilliam, Allen
Subject: this quarters waste water report

Happy holidays sir and have a good time off

SEMI-ANNUAL REPORT FOR INDUSTRIAL USERS REGULATED BY 40 CFR 433

Use of this form is not an ADEQ requirement, but satisfies the reporting requirements in 40 CFR 403.12(e).

Attn: Water Div/NPDES Pretreatment

(1) IDENTIFYING INFORMATION and NPDES Pretreatment Tracking # ARP001040

A. LEGAL NAME & MAILING ADDRESS
 Danfoss LCC
 One Scroll Drive
 Arkadelphia AR 71923

B. FACILITY & LOCATION ADDRESS
 Danfoss LCC
 One Scroll Drive
 Arkadelphia AR 71923

C. FACILITY CONTACT: Chuck Jones **TELEPHONE NUMBER:** 870-246-0714 **e-mail:** chuck.jones@danfoss.com

(2) REPORTING PERIOD--FISCAL YEAR From to (Both Semi-Annual Reports must cover Fiscal Year)

A. MONTHS WHICH REPORTS ARE DUE

 1st Quarter through April 2016

B. PERIOD COVERED BY THIS REPORT

FROM: Sept **TO:** DEC

(3) DESCRIPTION OF OPERATION

A. REGULATED PROCESSES

CORE PROCESS(ES)

CHECK EACH APPLICABLE BLOCK

- Electroplating
- Electroless Plating
- Anodizing
- Coating (conversion)
- Chemical Etching and Milling
- Printed Circuit Board Manufacture

ANCILLARY PROCESS(ES)*

LIST BELOW EACH PROCESS USED IN THE FACILITY

B. CHANGES:

SUMMARIZE ANY CHANGES IN THE REGULATED PROCESSES SINCE THE LAST REPORT. ATTACH AN ADDITIONAL SHEET IF THE SPACE BELOW IS INADEQUATE. PROVIDE A NEW SCHEMATIC IF APPROPRIATE.

**DEC 2016 QR
 ARP 001040
 AR0020605
 AFIN 10-00102
 Filed Date 2016 12 12**

*SEE 40CFR433.10(a) FOR THE 40 ANCILLARY OPERATIONS

C. Number of Regular Employees at this Facility 195

D. [Reserved]

(4) FLOW MEASUREMENT

INDIVIDUAL & TOTAL PROCESS FLOWS DISCHARGED TO POTW IN GALLONS PER DAY

Process	Average	Maximum	Type of Discharge*
Regulated (Core & Ancillary)		62100	Continuous
Regulated (Cyanide)	18142	62100	Continuous
' 403.6(e) Unregulated*	0	0	N/A
' 403.6(e) Dilute	0	0	Batch
Cooling Water	0	0	Continuous
Sanitary	5800	10150	Continuous
Total Flow to POTW	23942	72250	***** *

*If batch discharged please list the period of time of each batch discharge (300 gallons/day; 500 gallons/week, 2,000 gallons/3 months, etc). Do not normalize over that period for the average flow.
 "Unregulated" has a precise legal meaning; see 40CFR403.6(e).

(5) MEASUREMENT OF POLLUTANTS

A. TYPE OF TREATMENT SYSTEM

CHECK EACH APPLICABLE BLOCK

- Neutralization
- Chemical Precipitation and Sedimentation
- Chromium Reduction
- Cyanide Destruction
- Other _____
- None

B. COMMENTS ON TREATMENT SYSTEM

C. THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES-- CORE & ANCILLARY--(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE ANALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ACCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT.

40 CFR 433.17 Pollutant(mg/l) limits	Cd	Cr	Cu	Pb	Ni	Ag	Zn	CN	TTO*
Max for 1 day	0.11	2.77	3.38	0.69	3.98	0.43	2.61	1.20	2.13
Monthly Avg	0.07	1.71	2.07	0.43	2.38	0.24	1.48	0.65	--
Max Measured	.00052	.0104	0.018	0.0183	0.135	.0208	.0052	.010	*
Avg Measured**	.00052	.0104	0.018	0.0183	0.135	.0208	.0052	.010	*

Sample Location After Pre-Treatment

Sample Type (Grab* or Composite) Composite

*If Grab, list # of grabs over what period of time

Number of Samples and Frequency Collected 1

40CFR136 Preservation and Analytical Methods Use: Yes No (include complete Chain of Custody)

*If a TOMP has been submitted and approved by ADEQ place N/A.


****A value here is the average of all samples taken during one (1) calendar month regardless of number of samples taken. If only one (1) sample is taken it must meet the monthly average limitation.**

(6) CERTIFICATION (ONLY IF A TOMP HAS BEEN SUBMITTED/APPROVED BY ADEQ)

B. CHECK ONE: '433.11(e) TOXIC ORGANIC ANALYSIS ATTACHED '433.12(a) TTO CERTIFICATION

Based on my inquiry of the person or persons directly responsible for managing compliance with the pretreatment standard for total toxic organics (TTO), I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing of the last semi-annual compliance report. I further certify that this facility is implementing the toxic organic management plan submitted to Arkansas Department of Environmental Quality.

Chuck Jones
(Typed/Printed Name)


(Corporate Officer or authorized representative signature)

Date of Signature 12.12.16

(7) POLLUTION PREVENTION ACT OF 1990 [42 U.S.C. 13101 et seq.]

*6602 [42 U.S.C. 13101] Findings and Policy para (b) Policy--The Congress hereby declares it to be the national policy of the United States that pollution should be prevented or reduced at the source whenever feasible; pollution that cannot be prevented should be recycled in an environmentally safe manner, whenever feasible; pollution that cannot be prevented or recycled should be treated in an environmentally safe manner whenever feasible; and disposal or other release into the environment should be employed only as a last resort and should be conducted in an environmentally safe manner.

The User may list any new or ongoing Pollution Prevention practices including Best or Environmental Management Practices, Source Reduction, Waste Minimization, Lean Manufacturing, Water and/or Energy Conservaton:


1. We continue to use mechanical separation of oil and grease prior to pre-treatment.
2. _____
3. _____
4. _____
5. _____

(8) GENERAL COMMENTS

(9) SEMI-ANNUAL/PERIODIC REPORT CERTIFICATION STATEMENT REQUIRED UNDER 40 CFR 403.12(l)

I certify under penalty of law that I have personally examined and am familiar with the information in this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Chuck Jones
NAME OF CORPORATE OFFICER OR AUTHORIZED REPRESENTATIVE


SIGNATURE

EHS Manager
OFFICIAL TITLE

12/12/16
DATE SIGNED

09 November 2016



Chuck Jones
Danfoss - Scroll Technologies
1 Scroll Drive
Arkadelphia, AR 71923-8813
Project: Industrial Wastewater Effluent Sample
Project Number: November 2016
Date Received: 02-Nov-16 11:08

ANALYTICAL RESULTS

Lab Number: 1611034-01
Sample Name: Effluent Grab
Date/Time Collected: 11/1/16 6:00
Sample Matrix: Water

Total Metals	Units	Result	Qualifier(s)	Date/Time Analyzed	Batch	Method
Arsenic	mg/L	< 0.0104		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Cadmium	mg/L	< 0.000520		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Chromium	mg/L	< 0.0104		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Copper	mg/L	0.018		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Lead	mg/L	< 0.0156		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Manganese	mg/L	6.86		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Nickel	mg/L	0.135		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Silver	mg/L	< 0.0208		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Zinc	mg/L	0.052		11/3/16 18:50	B611063	200.7, Rev 4.4 (1994)
Wet Chemistry	Units	Result	Qualifier(s)	Date/Time Analyzed	Batch	Method
Cyanide (total)	mg/L	0.205	ET	11/7/16 14:54	B611087	4500-CN B.E-1999

QUALITY CONTROL RESULTS

Total Metals -- Batch: B611063 (Water)

Prepared: 03-Nov-16 15:50 By: HF -- Analyzed: 03-Nov-16 17:14 By: HF

Analyte	BLK	LCS / LCSD	MS / MSD	Dup	RPD	Qualifiers
Arsenic	<0.0104 mg/L	97.7% / NA	105% / 108%		2.73%	
Cadmium	<0.000520 mg/L	100% / NA	101% / 103%		2.88%	
Chromium	<0.0104 mg/L	103% / NA	103% / 107%		2.25%	
Copper	<0.005 mg/L	101% / NA	93.6% / 97.7%		3.22%	
Lead	<0.0156 mg/L	104% / NA	96.7% / 99.8%		3.18%	
Manganese	<0.0104 mg/L	101% / NA	94.3% / 97.5%		3.29%	
Nickel	<0.0104 mg/L	103% / NA	101% / 105%		1.88%	
Silver	<0.0208 mg/L	102% / NA	95.5% / 98.0%		2.68%	
Zinc	<0.005 mg/L	101% / NA	106% / 109%		2.42%	

Wet Chemistry -- Batch: B611087 (Water)


Prepared: 04-Nov-16 13:20 By: CAS -- Analyzed: 07-Nov-16 14:54 By: CAS

Analyte	BLK	LCS / LCSD	MS / MSD	Dup	RPD	Qualifiers
Cyanide (total)	<0.010 mg/L	106% / 107%	73.0% / NA		1.25%	

QUALIFIER(S)

*ET: Estimated Result; Temperature Upon Receipt Exceeded 6 Degrees Centigrade

09 November 2016



Chuck Jones
Danfoss - Scroll Technologies
1 Scroll Drive
Arkadelphia, AR 71923-8813
Project: Industrial Wastewater Effluent Sample
Project Number: November 2016
Date Received: 02-Nov-16 11:08

All Analysis performed according to EPA approved methodology when available :
SW 846, Revised December, 1996; EPA 600/4-79-020, Revised March, 1983; Standard Methods.
Instrument calibration and quality control samples performed at or above frequency specified in analytical method.

Reviewed by: *Norma James / Teresa Coins*
Norma James and/or Teresa Coins
Technical Director and/or QA Officer

