

SEARCY WATER AND SEWER SYSTEM

300 NORTH ELM STREET

P. O. BOX 1319

SEARCY, ARKANSAS

72145-1319

CLARENCE O. BUCKNER, MANAGER

March 4, 2009

CERTIFIED MAIL, Return Receipt Requested: 7008 1830 0000 2485 7070

Mr. Allen Gilliam
Pretreatment Coordinator
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, AR 72218-5317

Re: NPDES Permit No. AR0021601
Pretreatment Program Annual Status Report

Dear Allen:

In accordance with Part III (7)(d) of the above referenced NPDES permit, I am sending you the enclosed information.

The Searcy Pretreatment Program did not have any Significant Industrial Users that met the definition for Significant Noncompliance (SNC), as defined by 40 CFR 403.8(f)(2)(viii).

Referring to the subparagraphs of Part III (7)(d) in the permit, we submit the following information:

- (1) The updated list of significant industrial users is enclosed with this letter as Attachment "A". With the exception of the categorical IU's Semi-Annual Report, this information only reflects monitoring activity by the Utility and does not include all the self-monitoring activity as performed by each IU.
- (2) There were no service terminations or permit cancellations during this reporting period.
- (3) The Searcy POTW has not observed any interference, pass through, upset, or POTW permit violations known to be caused by contributions from our significant industrial users.
- (4) The results of the latest 40 CFR 122 Appendix D Table II and Table III analysis on the POTW influent and effluent is enclosed with this letter as Attachment "B".
- (5) Since there were no SIUs in Significant Noncompliance in this period, there is no newspaper publication of the SNC report.
- (6) See Attachment "A" enclosed.
- (7) Attachment "B" includes this information.

Also enclosed with this letter is our completed Pretreatment Performance Summary (PPS) form.

I trust that this information will meet with your approval. If there is any more information that you require in this regard, please do not hesitate to call me.

Sincerely,

SEARCY WATER AND SEWER SYSTEM

A handwritten signature in black ink, appearing to read 'Dawson', with a long horizontal stroke extending to the right.

Daniel K. Dawson
Assistant Manager/Pretreatment Coordinator

Enclosures: Attachment A, Status Report
Attachment B, Annual Analysis Report Summary
Attachment C, PPS Form

**INDUSTRY INFORMATION for 12 months ending February 15, 2009
Pretreatment Program Status Report**

NPDES Permit No. AR0021601

Part III (8)(D)(1)

<u>IU No.</u>	<u>Industry Name</u>	<u>SIC Code</u>	<u>Categorical</u>	<u>Control Document Status</u>			<u>Monitoring Activity</u>		<u>Compliance Status</u>				
			<u>Determination</u>	<u>Exists?</u>	<u>Type</u>	<u>Issued</u>	<u>Insp.</u>	<u>Samples</u>	<u>BMR</u>	<u>90</u>	<u>S-A</u>	<u>S-M</u>	<u>LIM</u>
1	The Bryce Company	2641	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	C
2	White County Med S	8062	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	C
3	Land O' Frost, Inc.	2013	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	NC
4	Road Systems, Inc.	3715	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	C
5	Kohler	3469	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	C
7	Cintas, Inc.	7213	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	NC
9	Eaton Hydraulics	3494	Metal Finishing	Yes	Permit	3/16/2008	1	2	NA	NA	C	C	C
10	White County Med.	8062	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	C
11	Yarnell Ice Cream	2024	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	NC
12	Wal-Mart Dist. Ctr. 18	4224	Non-Categorical	Yes	Permit	3/16/2008	1	2	NA	NA	NA	C	C

Monitoring Activity:

Numeral indicates the number of times inspected or sampled during reporting period.

Compliance Status Codes:

- C--No violations during reporting period
- NC--One or more violations during reporting period, but not SN
- SN--Significantly Non-compliant, per EPA definition
- BMR--Baseline Monitoring Report submitted (new IUs only)
- 90--90-day Compliance Report submitted (new IUs only)
- S-A--Semi-Annual Report submitted (categorical IUs only)
- S-M--Compliance with Self-Monitoring requirements
- LIM--Compliance with effluent permit limitations

MONITORING RESULTS FOR THE ANNUAL PRETREATMENT REPORT
REPORTING YEAR: February 16, 2008 TO February 15, 2009
TREATMENT PLANT: City of Searcy, Board of Public Utilities NPDES PERMIT #AR0021601
AVERAGE POTW FLOW: 4.08 MGD % IU FLOW: 8.2 %

METALS, CYANIDE and PHENOLS (Total)	MAHC ug/l (2)	INFLUENT DATES SAMPLED (ug/l) Once/quarter				WQ level/ limit ug/l (2)	EFFLUENT DATES SAMPLED (ug/l) Once/quarter				LABORATORY ANALYSIS		
		2/27/08	5/01/08	7/31/08	10/29/08		2/27/08	5/01/08	7/31/08	10/29/08	EPA MQL (µg/l) (1)	EPA Method Used (1)	Detection Level Achieved (µg/l)
		Antimony	N/A	0	0		0	0	N/A	0	0	0	0
Cadmium	17	0	0.84	0	0	0.0095	0	0	0	0	0.5	200.8	0.5
Copper	112.5	21	21	20	15	29.6	6.5	6.0	6.5	5.0	0.5	200.8	0.5
Lead	35.9	2.1	2.2	0	3.7	14	1.1	0	0	1.7	0.5	200.8	0.5
Mercury	0.18	0.029	0.027	0.180	0	0.07	0	0	0	0	.005	245.7	.005
Nickel	95.8	10	5.1	7.2	5.9	500	5.2	2.9	12	3.2	0.5	200.8	0.5
Selenium	19.2	0	0	0	0	23	0	0	0	0	5	200.8	5
Silver	12.4	7.3	1.7	1.6	1.0	2.8	0	0	0	0	0.5	200.8	0.5
Zinc	300	120	81	180	80	261	72	48	69	47	20	200.7	20
Chromium	350.5	0	0	0	0	1520	0	0	0	0	10	200.8	10
Cyanide	96.7	0	0	0	0	30	0	0	0	0	10	SM4500- CN C,E	10
Arsenic	160	0	2.7	0	0	N/A	0	2.2	0	0	0.5	200.8	0.5
Molybdenum	14.4	0	0	0	0	N/A	0	0	0	0	--	200.8	8
Phenols	N/A	66	70	60	130	N/A	0	0	0	0	5	420.1	5
Beryllium	N/A	0	0	0	0	N/A	0	0	0	0	0.5	200.8	0.5
Thallium	N/A	0	0.54	0	0	N/A	0	1.2	0	0	0.5	200.8	0.5
Flow, MGD	N/A	4.63	4.25	2.69	2.79	N/A							
(3) Chloroform					5.6					7.7		624	1.6
Methylene Chloride					12					0		624	10
Dichlorobromo- methane					0					2.9		624	2.2
Tetrachloro- ethylene					4.4					0		624	4.1
Toluene					7.7					0		624	6

11
B

- (1) It is advised that the influent and effluent samples are collected considering flow detention time through each plant. **Analytical MQLs must be met for the effluent (and SHOULD be met for the influent) so the data can also be used for Local Limits assessment and NPDES application purposes.**
- (2) This value was calculated during the development of TBLL based on State WQ criteria, EPA guidance and ADEQ Pretreatment staff Excel spreadsheets.
- (3) Record the name of any pollutant [40 CFR 122, Appendix D, Table II and/or Table V] detected and the quantity at which they were detected.

MAHL - Maximum Allowable Headworks Level

WQ - "Water Quality Levels not to exceed" OR actual permit limit.

"C"

PRETREATMENT PERFORMANCE SUMMARY (PPS)

NOTE: ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY THE EPA. THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT EPA AUTHORIZATION.

I. General Information

Control Authority Name Searcy Board of Public Utilities

Address P O Box 1319

City Searcy State/Zip AR 72145

Contact Person Daniel K Dawson Asst. Manager (Position)

Contact Telephone (501) 268-2481 (Area Code)

NPDES Permit Nos. AR0021601

Reporting Period February 16, 2008 February 15, 2009 (Beginning month and year) (Ending month and year)

Total Number of Categorical IUs 1

Total Number of Significant Noncategorical IUs 9

II. Significant Industrial User Compliance

Table with 3 columns: Description, Categorical, Noncategorical. Rows include: 1) No. of SIUs Submitting BMRs/Total, 2) No. of SIUs Submitting 90-Day Compliance, 3) No. of SIUs Submitting Semiannual Reports, 4) No. of SIUs Meeting Compliance Schedule, 5) No. of SIUs in Significant Noncompliance, 6) Rate of Significant Noncompliance for all SIUs.

III. Compliance Monitoring Program


1) No. of Control Documents Issued/Total No.		
Required	<u>1/1</u>	<u>9 / 9</u>
2) No. of Nonsampling Inspections Conducted . .	<u>1</u>	<u>9</u>
3) No. of Sampling Visits Conducted	<u>2</u>	<u>18</u>
4) No. of Facilities Inspected (nonsampling) . .	<u>1</u>	<u>9</u>
5) No. of Facilities Sampled	<u>1</u>	<u>9</u>

IV. Enforcement Actions

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>Noncategorical</u>
1) No. of Compliance Schedules Issued/No. of Schedules Required	<u>0 / 0</u>	<u>0 / 0</u>
2) No. of Notices of Violations Issued to SIUs	<u>0</u>	<u>3</u>
3) No. of Administrative Orders Issued to SIUs	<u>0</u>	<u>0</u>
4) No. of Civil Suits Filed	<u>0</u>	<u>0</u>
5) No. of Criminal Suits Filed	<u>0</u>	<u>0</u>
6) No. of Significant Violators (attach newspaper publication)	<u>0</u>	<u>0</u>
7) Amount of Penalties Collected (total dollars/IUs assessed)	<u>0 / 0</u>	<u>0 / 0</u>
8) Other Actions (sewer bans, etc.)	<u>0</u>	<u>0</u>

The following certification must be signed in order for this form to be considered complete:

I certify that the information contained herein is complete and accurate to the best of my knowledge.




 Authorized Representative



3/04/2009

 Date

CERTIFIED MAIL™



7008 1830 0000 2485 7070

U.S. POSTAGE
PAID
SEARCY, AR
72143
MAR 04, 09
AMOUNT

\$6.07
00051413-05

0000 72118

SEARCY WATER AND SEWER SYSTEM

300 NORTH ELM STREET
P. O. BOX 1319
SEARCY, ARKANSAS 72145-1319

**RETURN RECEIPT
REQUESTED**



Mr. Allen Gilliam
Pretreatment Coordinator
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, AR ~~72118~~ 5317

72118

