

BOARD MEMBERS
Roger Vaughan
Mel Sansom
Steve Lightle
Donnie Miller
Reynie Rutledge



GENERAL MANAGER
Daniel K. Dawson

ASSISTANT GENERAL
MANAGER
Tim W. Cleveland

October 2, 2013

CERTIFIED MAIL, Return Receipt Requested: 7012 1010 0002 3969 8014

Mr. Rufus J. Torrence
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: NPDES Permit No. AR0021601
August 2013 Pretreatment Program Audit

Dear Mr. Torrence:


We are in receipt of the above referenced report from the recently completed audit of our Industrial Pretreatment Program.

In response to Sections B and C that contains a summary of the significant findings of the audit which require action, and recommendations of the POTW, you will note the following:

1. The POTW will be monitoring the headworks loading of Molybdenum to ensure that the loading does not exceed the MAHC. The POTW will be corresponding with Eaton to make sure they have switched to products that contain no Molybdenum.
2. Annual reports will contain the noted updates to the Water Quality Standard/Level for Arsenic and Beryllium.
3. Free hand sketches of Eaton's flows will be part of the annual inspection.
4. All recommendations will be put into action as the report says.


Sincerely,

Searcy Water Utilities




Jimmy Smith
Pretreatment Coordinator

CERTIFIED MAIL™



7012 1010 0002 3969 8014



1000

72118

U.S. POSTAGE
PAID
SEARCY, AR
72143
OCT 02, 13
AMOUNT

\$6.77
00023179-09

SEARCY WATER AND SEWER SYSTEM

300 NORTH ELM STREET

P.O. BOX 1319

SEARCY, ARKANSAS 72145-1319

**RETURN RECEIPT
REQUESTED**



Arkansas Department of Environmental Quality

Rufus J. Torrence

5301 Northshore Drive

North Little Rock, AR 72118-5317

**RETURN RECEIPT
REQUESTED**

