

**Peltier, Hannah**

---

**From:** Torrence, Rufus  
**Sent:** Friday, March 15, 2013 4:14 PM  
**To:** Jimmy Smith (jsmith67@cablelynx.com)  
**Cc:** Peltier, Hannah  
**Subject:** AFIN 73-00055 AR0021601 City of Searcy 2011 Annual Report  
**Attachments:** SRCY 2012 Annual Report.pdf



March 15, 2013

Jimmy Smith, Pretreatment Inspector  
Searcy Water and Sewer System  
300 North Elm Street  
Searcy, Arkansas 72145-1319

Re: City of Searcy 2012 Pretreatment Annual Report  
(Permit No. AR0021601, AFIN 73-00055)

Dear Mr. Smith:

The Department has reviewed the City's 2012 Annual Report and the report has been deemed "complete". Nonetheless, the report did not contain all the required information. Please note that the 2010 and 2011 report had the same deficiencies and were listed in the Department letters dated March 10, 2011 and March 16, 2012. The two deficiencies are relisted below:

*"Please note that the Water Quality Standard/Level for Arsenic is 1596.7µg/l and for Beryllium is 30.5 µg/l.*

*The City listed four (4) NOVs on Attachment C. The City must list the Industrial User(s) which received the NOVs on Attachment B."*

If you have any questions or concerns, please contact the Department at (501) 682-0626 or by email at [torrence@adeq.state.ar.us](mailto:torrence@adeq.state.ar.us) .

Sincerely,



Rufus Torrence, Pretreatment Engineer  
Water Division

ARKANSAS DEPARTMENT OF E  
5301 NORTHSIDE DRIVE - NORTH LITTLE ROCK, ARKANSAS 72  
[www.adeq.state.ar.us](http://www.adeq.state.ar.us)

BOARD MEMBERS  
Roger Vaughan  
Mel Sansom  
Steve Lightle  
Donnie Miller  
Reynie Rutledge



GENERAL MANAGER  
Daniel K. Dawson  
ASSISTANT GENERAL  
MANAGER  
Tim W. Cleveland


ARRY B  
RT

March 7, 2013

CERTIFIED MAIL, Return Receipt Requested: 7012 1010 0002 3969 7918

Mr. Rufus Torrence  
Arkansas Department of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, AR 72118-5317

Re: NPDES Permit No. AR0021601, AFIN No. 73-00055  
Pretreatment Program Annual Status Report



Dear Rufus:

In accordance with Part III (7)(d) of the above referenced NPDES permit, I am sending you the enclosed information.

The Searcy Pretreatment Program did not have any Significant Industrial Users that met the definition for Significant Noncompliance (SNC), as defined by 40 CFR 403.8(f)(2)(viii).

Referring to the subparagraphs of Part III (7)(d) in the permit, we submit the following information:

- (1) The updated list of significant industrial users is enclosed with this letter (see attachment). With the exception of the categorical IU's Semi-Annual Report, this information only reflects monitoring activity by the Utility and does not include all the self-monitoring activity as performed by each IU.
- (2) The Searcy POTW has not observed any interference, pass through, upset, or POTW permit violations known to be caused by contributions from our significant industrial users.
- (3) The results of the latest 40 CFR 122 Appendix D Table II and Table III analysis on the POTW influent and effluent is enclosed with this letter.
- (4) Since there were no SIUs in Significant Noncompliance in this period, there is no newspaper publication of the SNC report.
- (5) See attachment of significant industrial users enclosed.
- (6) The attached laboratory analysis summary includes this information.


Also enclosed with this letter is our completed Pretreatment Performance Summary (PPS) form.

I trust that this information will meet with your approval. If there is any more information that you require in this regard, please do not hesitate to call me.

① inf-eff  
② ICIS/Cover letter  
③ IU's checked  
④ Annual Report Form Up

Sincerely,

Searcy Water Utilities

A handwritten signature in black ink, appearing to read "Jimmy Smith". The signature is written in a cursive style with a large, looping initial "J" and a long, sweeping tail.

Jimmy Smith  
Pretreatment Coordinator

Enclosures

*Word/Pretreatment/Annual Report*



- (1) It is advised that the influent and effluent samples are collected considering flow detention time through each plant. **Analytical MQLs must be met for the effluent (and SHOULD be met for the influent) so the data can also be used for Local Limits assessment and NPDES application purposes.**
- (2) This value was calculated during the development of TBLL based on State WQ criteria, EPA guidance and ADEQ Pretreatment staff Excel spreadsheets.
- (3) Record the name of any pollutant [40 CFR 122, Appendix D, Table II and/or Table V] detected and the quantity at which they were detected.

MAHL - Maximum Allowable Headworks Level

WQ - "Water Quality Levels not to exceed" OR actual permit limit.







**ATTACHMENT C**

PRETREATMENT PERFORMANCE SUMMARY (PPS)

**NOTE:** ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY ADEQ. THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT DEPARTMENT AUTHORIZATION.

I. General Information

Control Authority Name Searcy Board of Public Utilities

Address P. O. Box 1319

City Searcy State/Zip AR, 72145-1319

Contact Person Daniel Dawson Position General Manager

Contact Telephone 51-268-2481 NPDES Permit Nos. AR0021601

Reporting Period February 16, 2012 February 15, 2013  
(Beginning Month and Year) (Ending Month and Year)

Total Number of Categorical IUs 1

Total Number of Significant Noncategorical IUs 10

Total Number of Non-Significant (yet permitted) IUs 0

II. Significant Industrial User Compliance

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of SIUs Submitting BMRs/Total No. Required. . . . .	<u>0 / 0</u>	<u>N/A*</u>
2) No. of SIUs Submitting 90-Day Compliance Reports/No. Required. . . . .	<u>0 / 0</u>	<u>N/A*</u>
3) No. of SIUs Submitting Semiannual Reports/ Total No. Required. . . . .	<u>1 / 1</u>	<u>0 / 0</u>
4) No. of SIUs Meeting Compliance Schedule/ Total No. Required to Meet Schedule . . . . .	<u>0 / 0</u>	<u>0 / 0</u>
5) No. of SIUs in Significant Noncompliance/ Total No. of SIUs . . . . .	<u>0 / 0</u>	<u>0 / 0</u>
6) Rate of Significant Noncompliance for all SIUs (categorical and noncategorical) . . . . .	<u>0 / 0</u>	

III. Compliance Monitoring Program

	<u>SIGNIFICANT</u> <u>Categorical</u>	<u>INDUSTRIAL USERS</u> <u>NonCategorical</u>
1) No. of Control Documents Issued/Total No. Required. . . . .	<u>1 / 1</u>	<u>10 / 10</u>
2) No. of Nonsampling Inspections Conducted. . . . .	<u>1 / 1</u>	<u>10 / 10</u>
3) No. of Sampling Visits Conducted. . . . .	<u>2 / 2</u>	<u>20 / 20</u>
4) No. of Facilities Inspected (nonsampling) . . . . .	<u>1 / 1</u>	<u>10 / 10</u>
5) No. of Facilities Sampled . . . . .	<u>1 / 1</u>	<u>10 / 10</u>

IV. Enforcement Actions

	<u>SIGNIFICANT</u> <u>Categorical</u>	<u>INDUSTRIAL USERS</u> <u>NonCategorical</u>
1) No. of Compliance Schedules Issued/No. of Schedules Required . . . . .	<u>0 / 0</u>	<u>0 / 0</u>
2) No. of Notices of Violations Issued to SIUs	<u>0</u>	<u>4</u>
3) No. of Administrative Orders Issued to SIUs	<u>0</u>	<u>0</u>
4) No. of Civil Suits Filed. . . . .	<u>0</u>	<u>0</u>
5) No. of Criminal Suits Filed . . . . .	<u>0</u>	<u>0</u>
6) No. of Significant Violators (attach newspaper publication). . . . .	<u>0</u>	<u>0</u>
7) Amount of Penalties (not surcharges) Collected (total dollars/IUs assessed) . . . . .	<u>0 / 0</u>	<u>0 / 0</u>
8) Other Actions (sewer bans, etc.). . . . .	<u>0</u>	<u>0</u>

The following certification must be signed in order for this form to be considered complete:

I certify that the information contained herein is complete and accurate to the best of my knowledge.

  
 \_\_\_\_\_  
 Authorized Representative

Date 3/7/13

# PPS Program Report

\* NPDES ID: AR0021601 Permittee's Name Jearcy

\* Report Received/Event Date: 03/13/2013 Date 3-14-13

## Report Type

- Biosolids Program Report
- CAFO Annual Report
- CSO Event Report
- Local Limits Report
- MS4 Program Report
- Pretreatment Performance Summary Report
- SSO Annual Report
- SSO Event Report
- SSO Monthly Event Report
- Storm Water Event Report

## Report Information

\* Pretreatment Performance Summary Start Date: 02/16/2012

## Significant Industrial Users (SIUs)

- SIUs: 11
- SIUs Without Control Mechanism: 0
- SIUs Not Inspected: 0
- SIUs Not Sampled: 0
- SIUs in SNC with Pretreatment Standards: 0
- SIUs in SNC with Reporting Requirements: 0
- SIUs in SNC with Pretreatment Schedule: 0
- SIUs in SNC Published in Newspaper: 0
- SIUs Schedules: 0
- Violation Notices Issued to SIUs: 4
- Administrative Orders Issued to SIUs: 0
- Civil Suits Filed Against SIUs: 0
- Criminal Suits Filed Against SIUs: 0

## Categorical Industrial Users (CIUs)

- CIUs: 1
- CIUs in SNC: 0

## Penalties

Dollar Amount of Penalties Collected: \$                     

Industrial Users (IUs) from which Penalties have been collected:                     

## Other Information

SUO Reference:                     

SUO Date:                     

Annual Pretreatment Budget: \$                     

Pass-Through/Interference Indicator:

Adherence of IU Schedule for Remedial Measures:  No

Timely Response to Violation of IU Schedule for Remedial Measures:

## Local Limits

Date of Most Recent Technical Evaluation & or Local Limits:                     

Date of Most Recent Adoption of Technically Based Local Limits:                     

Local Limit Pollutants:                     

## Removal Credits

Removal Credits Application Status: Not Applicable

Date of Most Recent Removal Credits Approval:                     

Removal Credits:                     

## Acceptance of Waste

Acceptance of Hazardous Waste:  No

Acceptance of Non-Hazardous Industrial Waste:  No

Acceptance of Hauled Domestic Wastes:  No

## Deficiencies

Deficiencies Identified During IU File Review:  No

Control Mechanism Deficiencies:  No

Legal Authority Deficiencies:  No

Deficiencies in Data Management and Public Participation:  No

Deficiencies in Interpretation and Application of Pretreatment Standards:  No

Inadequacy of Sampling and Inspections:  No

Adequacy of Pretreatment Resources:  Yes

## Annual Frequency

Annual Frequency of Influent Toxicant Sampling:                     

Annual Frequency of Effluent Toxicant Sampling:                     

Annual Frequency of Sludge Toxicant Sampling: