

Torrence, Rufus

From:
Sent:
To:
Subject:

Torrence, Rufus
Wednesday, March 02, 2011 12:35 PM
RBradley@citycorporation.com
AFIN 58-00105 AR0021768 City of Russellville 2010 Annual Report



March 3, 2011

Randy Bradley, Pretreatment Coordinator
City Corporation
Russellville Water and Sewer System
P O Box 3186
Russellville, Arkansas 72811-3186

Re: City of Russellville 2010 Annual Pretreatment Report
(Permit No. AR0021768, AFIN 58-00105)

Dear Mr. Bradley:

The Department has reviewed the City's 2010 Annual Report. The report is complete. Nonetheless, the Department has concerns.


Please note that on two occasions the effluent concentrations (9.4 ug/l & 9.3 ug/l) exceeded the permit limit (9.2 ug/l) for Copper. Furthermore, the effluent concentrations (0.025 ug/l & 0.06 ug/l) exceeded the applicable Water Quality Standard (0.013 ug/l) for Mercury.

In reference to Attachment B, the City simply inserted "X's" into the chart for NOV's. Please note that the heading is "Number of Action Taken". The City must show how many NOV's were issued to each SIU.

The Department appreciates the City's continued efforts in annual reporting and the City will not be required to submit any additional information for the 2010 annual report.

If you have any questions or concerns, please contact the Department at (501) 682-0626 or by email at torrence@adeq.state.ar.us .

Sincerely,



Rufus Torrence, Pretreatment Engineer
Water Division

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
3301 NORTHSORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72113-5337 / TELEPHONE 501-682-0744 / FAX 501-682-0745
www.adeq.state.ar.us