

Gilliam, Allen

From: Gilliam, Allen
Sent: Monday, February 14, 2011 8:43 AM
To: 'Jennifer Enos'; 'Brad Stewart'
Subject: AR0022063_Springdale's January 2011 Annual Pretreatment Report Reply_20110214

Dear Ms. Enos and Mr. Stewart,

Your annual pretreatment report was received on 1/28/11, reviewed, deemed complete and compliant with your reporting requirements in your NPDES permit and 40 CFR 403.12(i). No further actions are deemed necessary at this time.

We may have to revise your removal efficiency for Hg using more recent influent readings as some have exceeded your current ones as 2 of the 4 influent readings exceeded the MAHLs. However, your effluent values reported were well below calculated water quality "levels not to exceed". Your currently used 60% removal should be increased to 90 to 95% which is indicative of most secondary treatment plants nationwide. This would effectively increase your MAHL for Hg.

Thank you for your timely reporting remaining compliant with the National Pretreatment Regulations in 40 CFR 403.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625