

Henderson, Katie

From: Gilliam, Allen
Sent: Wednesday, May 23, 2012 1:59 PM
To: tim.barry@st-ji.com
Cc: Henderson, Katie
Subject: AR0022381_Saint Jean (ARP001050) May 2012 Semi Annual Pretreatment No Discharge Report Reply_20120523

Tim,

Your May 2012 semi-annual Pretreatment Report was received, reviewed, deemed complete and compliant with the Federal Pretreatment Regulations in 40 CFR 403.

You've certified there has been no regulated wastewater discharged for the period of November 1, 2011 through April 2012.

- 1) If there are any changes in processes to cause regulated wastewater to be discharged on a more frequent basis than "7 to 10 years", Saint Jean Industries must immediately report that change to ADEQ per 40 CFR 403.12(j), "Notification of changed Discharge. [Saint Jean] shall promptly notify [ADEQ] in advance of any substantial change in the volume or character of pollutants in their Discharge..."
- 2) Please notify this office two (2) weeks prior to the next anticipated regulated wastewater discharge so a compliance assurance visit can be coordinated with that event.
- 3) Please keep this and all Pretreatment related correspondence on file for a minimum of three (3) years per 40 CFR 403.12(o)(2), "*Record-keeping requirements*. Any Industrial User subject to the reporting requirements established in this section shall maintain records of all information resulting from any monitoring activities required by this section..."

Thank you for your cooperation maintaining compliance with the Federal Pretreatment Regulations.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625