

Peltier, Hannah

From: Gilliam, Allen
Sent: Monday, May 13, 2013 4:12 PM
To: tim.barry@st-ji.com
Cc: Fuller, Kim; Peltier, Hannah; 'heber springs'
Subject: AR0022381_Saint Jean ARP001050 May 2013 Semi Annual Pretreatment Report reply_20130513

Tim,

Saint Jean's May 2013 semi-annual Pretreatment Report was received on 5/2/13, reviewed and deemed complete with the reporting requirements in 40 CFR 403.12(e). No further action is deemed necessary at this time.

You've once again certified there has been no regulated process wastewater discharged from your solution heat treatment (recycled cooling vault) to the City's sewage system over the last six (6) month period. This wastewater was determined to be regulated under Subpart D of the Aluminum Forming category in 40 CFR 467.46, but is only discharged to the City once every 7 to 10 years.

Please keep this office apprised of any intended/future discharge from this heat treatment's cooling tower as I would like to conduct sampling along with you at that time.

Thank for your timely semi-annual report.

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Don Knight, Heber Springs General Manager

E-drive scanned