

Waller, Scott

From: Gilliam, Allen
Sent: Thursday, November 08, 2012 2:24 PM
To: tim.barry@st-ji.com
Cc: hswd@sbcglobal.net; Fuller, Kim; Waller, Scott
Subject: AR0022381_Saint Jean ARP001050 Nov 2012 Semi-Annual Pretreatment Report and ADEQ reply_2012110

Tim,

Your November 2012 semi-annual pretreatment report was received and deemed compliant with the provisions in the Federal Pretreatment Regulation located in 40 CFR 403.

You've certified there has been no wastewater discharged from your process waste stream (from May 1 through October 31, 2012) federally regulated under Aluminum Forming per 40 CFR 467.46 (your original was corrected from "CFR Title 40, Volume 27").

During the compliance assurance visit conducted by this office at your facility on 11/8/11 it was discovered the regulated quench (solution heat treatment contact cooling) water which is circulated through its cooling tower had not been discharged in about 7 years. Information included that quench water is discharged every 7 to 10 years. It has been about 8 years since its last discharge and appears it is nearing time for that quench wastewater to be discharged. Is this not correct?

Please continue with semi-annual reporting (during May and November), but when that quench water is discharged, please submit the volume of wastewater discharged; lbs of Aluminum quenched over the period of time since the last quench water was discharged and an analysis of that wastewater for chromium, cyanide, zinc and oil & grease along with the contract lab's results and a complete chain of custody.

It would be advisable to contact the appropriate city official in advance of the quench water allowing them knowledge this slug of wastewater is being discharged to their collection system.

Alternate concentration limits will be calculated by this office and compared to your analytical results for compliance.

Thank you for your continuing compliance with the Federal Pretreatment Regulations.

If there are any questions or comments please feel free to contact this office.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Don Knight/Heber Springs General Manager

A P S N D

SAINT JEAN INDUSTRIES



Saint Jean Industries, Inc
424 Industrial Park Road
Heber Springs, AR 72543
Telephone: 501-362-9540
Fax: 501-362-9539

*Oct. Semi-Annual Report
"No discharge"
-AE*

To: Allen Gilliam-ADEQ Pretreatment Coordinator

11-1-12

The Saint Jean Industry facility in Heber Springs AR. has not discharged any regulated wastewater (CFR Title 40, Volume 27) for the period of May 1, 2012 through Oct. 31, 2012.

CFR 461.25

I certify under penalty of law that I have personally examined the facility's waste water program, in consultation with the facility Maintenance Dept. Leader, and understand that all wastewater associated with our industrial processes are contained within closed-loop cooling systems with "0" discharge.

I believe that this information is true, accurate, and complete. I am aware that there are significant penalties for submitting information, including possibility of fine and imprisonment.

Please contact me for any questions/concerns.

Tim Barry
Environmental, Health and Safety Coordinator